



Report:

Clean Harbors Canada Inc.
Mercury Emission Testing Program at the Clean Harbors Sarnia
Incineration Facility

Date: September 16, 2022



Report:

Clean Harbors Canada Inc. Mercury Emission Testing Program at the Clean Harbors Sarnia Incineration Facility

Submitted to: Mr. Frank Wagner
Vice President Environmental Compliance
Clean Harbors Canada Inc.
4090 Telfer Road, Corunna, Ontario N0N 1G0
Tel: (519) 648-2291, Ext. 75269
Cell: (519) 240-5870
E-mail: frank.wagner@safety-kleen.com

Prepared by: Tina Sanderson, B.Sc.
Senior Project Manager, Emission Testing
ORTECH Consulting Inc.
804 Southdown Rd., Mississauga, Ontario L5J 2Y4
Tel: (905) 822-4120, Ext. 522
E-mail: tsanderson@ortech.ca

Report No.: 22196
25 pages, 19 Appendices

Revision History

Version	Date	Summary Changes/Purpose of Revision
1	September 16, 2022	None

NOTICE:

This report was prepared by ORTECH Consulting Inc. (ORTECH) solely for the Client identified above and is to be used exclusively for the purposes set out in the report. The material in this report reflects the judgment of ORTECH based on information available to them at the time of preparation. Unless manifestly incorrect, ORTECH assumes information provided by others is accurate. Changed conditions or information occurring or becoming known after the date of this report could affect the results and conclusions presented. Unless otherwise required by law or regulation, this report shall not be shared with any Third Party without the express written consent of ORTECH. ORTECH accepts no responsibility for damages, if any, suffered by any Third Party which makes use of the results and conclusions presented in this report.

Table of Contents

	Page
EXECUTIVE SUMMARY	5
1. INTRODUCTION	6
2. SOURCE DESCRIPTION	6
2.1 Process Description	6
2.2 Process Operations.....	7
3. SAMPLING LOCATIONS.....	8
4. SAMPLING AND ANALYTICAL PROCEDURES	9
4.1 US EPA Method 29 Sampling at the Incinerator Exhaust Stack	9
4.2 US EPA Method 30B Sampling at the Incinerator Exhaust Stack	11
4.3 Mercury Sampling Prior to the PAC Injection	13
4.4 Acid Gases	13
4.5 Combustion Gases.....	14
4.6 Process Sample Collection.....	15
5. INTERNAL AND EXTERNAL QA/QC PROGRAM	16
5.1 General.....	16
5.2 Pre-Test Activities.....	16
5.3 Emission Testing QA/QC Results.....	17
5.4 Sample Recovery, Handling and Custody	18
5.5 Analytical Results	18
5.5.1 US EPA Method 29 Mercury Analysis QA/QC.....	19
5.5.2 US EPA Method 30B Mercury Analysis QA/QC.....	19
5.5.3 Acid Gas Sample Analysis QA/QC.....	20
6. RESULTS AND DISCUSSION	21
6.1 Stack Gas Sampling Parameters	21
6.2 Stack Gas Physical Parameters	21
6.3 Volumetric Flowrate Data	22
6.4 Particulate Emission Data.....	22
6.5 Acid Gases Emission Data.....	23
6.6 Combustion Gas Emission Data	23
6.7 Mercury Emission Data	24
7. FACILITY PROCESS DATA	25

List of Appendices

- APPENDIX 1 Data Tables
- APPENDIX 2 Environmental Compliance Approval No. 8-1030-94-006
- APPENDIX 3 Method 29 Train Field Data Sheets Incinerator Exhaust Stack
- APPENDIX 4 Method 29 Train Recovery Data Sheets
- APPENDIX 5 Method 29 Analytical Reports
- APPENDIX 6 Method 30B Train Field Data Sheets Incinerator Exhaust Stack
- APPENDIX 7 Method 30B Analytical Report
- APPENDIX 8 Method 29 Train Field Data Sheets Pre-PAC Injection
- APPENDIX 9 Acid Gas Field Data Sheets
- APPENDIX 10 Acid Gas Recovery Data Sheet
- APPENDIX 11 Acid Gas Analytical Report
- APPENDIX 12 Feed Sample Analytical Report
- APPENDIX 13 Equipment Calibration Data
- APPENDIX 14 Pre-Test Plan Acceptance Letter
- APPENDIX 15 ORTECH CEM Calibration Data
- APPENDIX 16 Particulate and Mercury Test Emission Calculations Incinerator Exhaust
- APPENDIX 17 ORTECH One-Minute Average Combustion Gas Results
- APPENDIX 18 Clean Harbors One-Minute Average Combustion Gas Results
- APPENDIX 19 Clean Harbors One-Minute Average Process Data

EXECUTIVE SUMMARY

ORTECH Consulting Inc. (ORTECH) was requested by Clean Harbors to conduct a mercury emission testing program at the incineration facility located at 4090 Telfer Road in Corunna, Ontario. The testing program was conducted on August 17, 2022.

To satisfy a requirement of a Provincial Officers Order (Order Number 5857-9ZWQ44) that was issued in 2015, Clean Harbors conducts mercury emission testing three times per year, with one mercury testing program being part of the annual compliance emission testing program. Three mercury test programs were completed at the Clean Harbor’s facility in February, April and May of 2022, however they failed to meet the required quality control criteria of the sampling method. Clean Harbors sent a notification to the Ministry of the Environment, Conservation and Parks (MECP) on June 20, 2022 stating that there was a potential exceedance of mercury from the Incinerator Exhaust Stack. Clean Harbors committed to repeat the mercury testing as soon as practical after the July 2022 maintenance shutdown. During the shutdown the facility replaced the Incinerator Exhaust Stack and performed maintenance on the powdered activated carbon (PAC) injection system and the baghouse. During this shutdown new PAC was also acquired. This report details the results of the comprehensive mercury testing program completed after the maintenance shutdown to demonstrate compliance with the Provincial Officers Order and Environmental Compliance Approval (ECA) No. 8-1030-94-006.

Mercury testing was conducted at the Incinerator Exhaust Stack (Post PAC-Injection) following both US EPA Method 29 (modified) and US EPA Method 30B. Sampling for particulate matter, acid gases and combustion gases was also conducted at the Incinerator Exhaust Stack.

Sampling for mercury using US EPA Method 29 (modified) was conducted after the Spray Dryer and just before the PAC injection point (Pre PAC-Injection) concurrently with the sampling at the Incinerator Exhaust Stack in order to calculate the mercury removal efficiency of the control system.

The following table summarizes the average test results and the corresponding emission criteria:

Mercury Emission Data	ECA Limit	Pre-PAC Injection	Post PAC-Injection	
		Method 29	Method 29	Method 30B
Dry Reference Conc. ($\mu\text{g}/\text{Rm}^3$)*	-	191	2.16	2.34
Dry Adjusted Conc. ($\mu\text{g}/\text{Rm}^3$)**	50	163	1.85	1.98

* At 25°C and 1 atm

** At 25°C and 1 atm, adjusted to 11% oxygen

The results for both test methods show that the mercury measured on August 17, 2022 at the Incinerator Exhaust Stack (Post PAC-Injection) was well below the limit stated in the ECA.

All tables referenced in this report are provided in Appendix 1.

1. INTRODUCTION

ORTECH Consulting Inc. (ORTECH) was requested by Clean Harbors to conduct a mercury emission testing program at the incineration facility located at 4090 Telfer Road in Corunna, Ontario. The testing program was conducted on August 17, 2022.

To satisfy a requirement of a Provincial Officers Order (Order Number 5857-9ZWQ44) that was issued in 2015, Clean Harbors conducts mercury emission testing three times per year, with one mercury testing program being part of the annual compliance emission testing program. Three mercury test programs were completed at the Clean Harbor's facility in February, April, and May of 2022, however they failed to meet the required quality control criteria of the sampling method. Clean Harbors sent a notification to the Ministry of the Environment, Conservation and Parks (MECP) on June 20, 2022 stating that there was a potential exceedance of mercury from the Incinerator Exhaust Stack. Clean Harbors committed to repeat the mercury testing as soon as practical after the July 2022 maintenance shutdown. During the shutdown the facility replaced the Incinerator Exhaust Stack and performed maintenance on the powdered activated carbon (PAC) injection system and the baghouse. During this shutdown new PAC was also acquired. This report details the results of the comprehensive mercury testing program completed after the maintenance shutdown to demonstrate compliance with the Provincial Officers Order and Environmental Compliance Approval (ECA) No. 8-1030-94-006. A copy of the ECA is provided in Appendix 2.

Mercury testing was conducted at the Incinerator Exhaust Stack (Post PAC-Injection) following both US EPA Method 29 (modified) and US EPA Method 30B. Sampling for particulate matter, acid gases and combustion gases was also conducted at the Incinerator Exhaust Stack.

Sampling for mercury using US EPA Method 29 (modified) was conducted after the Spray Dryer and just before the PAC injection point (Pre PAC-Injection) concurrently with the sampling at the Incinerator Exhaust Stack in order to calculate mercury removal efficiency of the control system.

2. SOURCE DESCRIPTION

2.1 Process Description

The incineration system, shown in Figure 1, consists of a refractory-lined, fixed-chamber combustion reactor and a three-stage gas conditioning and cleaning system. In the combustion chamber there are two reaction zones referred to as the primary zone and secondary zone. In the primary zone, high heating value ("rich") wastes are intimately mixed with combustion air and ignited to produce a turbulent, luminous flame. Intermediate heating value ("emulsion") wastes are also injected into the primary zone. Reaction temperatures are continuously monitored and controlled to maintain temperatures normally in excess of 1300°C.

Downstream of the luminous primary reaction zone, aqueous (“lean”) wastes with a much lower heating value are sprayed into the combustion chamber. This portion of the chamber is known as the secondary zone and temperatures within this zone are maintained in excess of 800°C.

Upon exiting the secondary zone of the combustion chamber, the combustion gases are cooled in a quench chamber to about 550°C by the injection of process water. The combustion gases are further cooled and acid gases are removed in a spray dryer where alkaline waste liquid (“alkaline”) and/or reagent grade lime slurry is injected. The exit temperature of the gases leaving the spray dryer is typically between 160°C and 195°C, and should not exceed 220°C. Powdered activated carbon (PAC) is injected into the air pollution control system to adsorb contaminants.

Finally, the gases are directed to a four-compartment baghouse where the fine suspended particulate matter and PAC in the gas phase is filtered out. The hot, humid gases exiting the baghouse are then discharged to the atmosphere through a 68.8 meter high, 1.47 meter inside diameter, insulated steel main stack. The stack gases are monitored by continuous emission monitors (CEMs) located in the induced draft fan discharge ducting with opacity being measured in-situ eight stack diameters downstream of the breaching inlet to the stack (approximately fifteen meters above grade, accessible by a ladder). The CEMs record the oxygen, carbon monoxide, total hydrocarbon, sulphur dioxide and hydrochloric acid concentrations. As well, stack gas flowrate and temperature are recorded.

During the testing program the incinerator was operated normally, as specified in Part 15, “Limitation on Wastes”, and Part 16, “Detailed Operating Conditions”, of the ECA, while maintaining high feed rates in order to demonstrate compliance with emission guidelines, with the following exception.

Clean Harbors was granted Amended ECA No. 4650-8N6L9N, dated May 29, 2012, to treat up to 36 tonnes per hour of hazardous waste at the Thermal Desorber Unit (TDU). The thermal desorption system uses standard rotary kiln technology to remove organic contaminants from solid wastes. The kiln off-gas is directed through a multi-stage treatment sequence before being released to the atmosphere. Kiln off-gas is drawn through a cyclone to remove coarse particulate matter. The gas then enters a set of scrubbers to reduce acid levels and any other condensable material. The gas is then directed to the hazardous waste liquid incinerator to combust organic constituents at temperatures up to 1300°C. The Thermal Desorber Unit (TDU) was exhausting to the incinerator during each test.

2.2 Process Operations

During the emission testing program, the incinerator was operated with an average primary zone temperature of 1359°C. Normal operating temperature must be in excess of 1300°C while achieving the maximum thermal and feed loading practical within the incineration system. The average spray dryer outlet temperature was 193.9°C (must not exceed 220°C).

Average feed rates for the rich, lean and emulsion streams during the testing program were as follows:

Feed Stream	Flow (L/min)
Rich	33.6
Lean	152
Emulsion	6.40
Total	192

The powdered activated carbon (PAC) injection rate during the test program was 15.6 kg/h (34.4 lb/h).

3. SAMPLING LOCATIONS

The Incinerator Exhaust Stack has an inside diameter of 1.47 meters at the sampling platform and 1.22 meters at the stack exit. The stack height above grade is 68.6 meters.

Sampling for particulate and mercury, using US EPA Method 29 (Modified), was conducted at the sampling platform permanently installed on the stack, through two ports at 90° to each other and at the same vertical height. Mercury, using US EPA Method 30B, and acid gases were sampled through a third port located on the same sampling platform.

The sampling ports are located at an “ideal” location as defined by the Ontario Source Testing Code. An “ideal” location is defined as being at least eight stack diameters downstream and at least two stack diameters upstream of flow disturbances.

The combustion gases sampling probe was inserted into the breaching connecting the induced draft fan to the stack. Previous testing programs conducted by ORTECH at the Clean Harbors Incinerator Exhaust Stack have shown that there is no stack gas stratification between the breaching connecting the induced draft fan to the stack and the stack sampling platform location.

Mercury sampling, using US EPA Method 29 (Modified), was also conducted prior to the PAC injection to determine the mercury removal efficiency. A single sample port, at a non-ideal location, between the spray dryer and the PAC injection was used to determine the inlet mercury concentration.

4. SAMPLING AND ANALYTICAL PROCEDURES

Equipment calibrations, analyzer linearizations and other pre-test and QA/QC activities were performed prior to the commencement of the emission testing program. These results are presented and discussed in Section 8 of this report.

4.1 US EPA Method 29 Sampling at the Incinerator Exhaust Stack

Particulate matter and mercury were sampled together using a modified version of the sampling train and sampling procedures outlined in United States Environmental Protection Agency (US EPA) Method 29. The multi-metals sampling method was modified to collect and analyze mercury only. Two US EPA Method 29 (Modified) tests were conducted at the Incinerator Exhaust Stack. Each test was conducted concurrently with three US EPA Method 30B tests performed at the same sampling location.

Major components of the sampling train are as follows:

- A glass nozzle and glass probe liner assembly
- A glass fiber filter
- The first impinger initially contained 50 mL of 4% potassium permanganate/10% sulphuric acid solution
- The second knockout impinger initially contained 100 mL of 4% potassium permanganate/10% sulphuric acid solution
- The third impinger initially contained 50 mL of 4% potassium permanganate/10% sulphuric acid solution
- The fourth and fifth impingers initially contained 100 mL of 4% potassium permanganate/10% sulphuric acid solution
- The sixth impinger was initially empty
- The seventh impinger contained silica gel

All test train and auxiliary glassware was cleaned according to the appropriate methods as outlined in the Pre-Test Plan.

A single test for particulate matter and mercury involved the collection of stack gas sampled at ten points centered on equal areas along each of the two stack traverses. Each point was sampled for nine minutes for a total actual sampling time of one hundred and eighty minutes per test.

At three-minute time increments the following information was measured and recorded:

- Elapsed sampling time
- Dry gas meter volume
- Pitot tube pressure
- Stack gas temperature
- Probe, oven, and impinger outlet temperatures
- Dry gas meter temperatures
- Control module orifice pressure
- Sampling pump vacuum

At the start and finish of sampling each traverse, the sampling trains were leak-checked. A valid leak-check as specified by each of the sampling methods is a leakage rate of less than 0.00057 cubic meters per minute (m^3/min) or 4% of the sampling rate, whichever is less. The leak checks performed for all tests were less than this maximum permitted leakage rate.

Field data sheets for the two particulate and mercury tests performed at the Incinerator Exhaust Stack using US EPA Method 29 (Modified) are provided in Appendix 3.

The blank train was prepared in an identical manner to the test trains, transported to site as a spare test train, and then recovered at the end of the test day in a manner identical to the test trains.

Following the conclusion of each test performed with the US EPA Method 29 sampling train, the probe was disconnected and all openings sealed with Teflon tape. The probe was recovered at the sampling location and the test trains were taken to the on-site ORTECH laboratory for sample recovery. The train recovery procedure is briefly described as follows. The recovery data sheets are provided in Appendix 4.

The test trains were visually inspected to ensure that no damage had occurred during movement. The condition of the test train was noted. Filter and impinger content colors were recorded. The filter housing was disassembled and the filter carefully transferred to its pre-test petri dish with the use of Teflon coated tweezers.

All the impingers were wiped dry on the outside then weighed and the results used to determine the exhaust gas moisture content.

The front half of the sampling train was brushed and rinsed thoroughly with acetone. A nylon bristle probe brush was used to assist in dislodging any particulate matter that may have adhered to the inside surfaces of the nozzle and probe assembly. This front half rinse was then repeated using 0.1N nitric acid, however no brushing was performed.

The contents of the first to sixth impingers are transferred to an amber glass sample bottle and the impingers with connecting glassware are rinsed in triplicate with approximately 100 mL of fresh acidified potassium permanganate solution followed by a triplicate rinse with 100 mL of distilled, de-ionized water. All the rinsing of this glassware was added to the impinger solution sample.

Any brown residue present in the impingers was removed by rinsing with 8N hydrochloric acid (HCl). These acid rinses are added to a separate amber glass sample bottle that initially contains 150 mL of distilled, de-ionized water. The impingers are then rinsed with distilled, de-ionized water to remove remaining traces of 8N HCl and this rinse is also added to the sample bottle.

Each sample container was sealed and labeled once that portion of the recovery was completed. The samples were then checked against the master sample log/chain of custody form and refrigerated until they were transported to the ALS Environmental laboratory for analysis.

Particulate samples (front half acetone rinse and filter) collected from the trains underwent gravimetric determination before mercury analysis.

The particulate matter and mercury analytical report is provided in Appendix 5.

4.2 US EPA Method 30B Sampling at the Incinerator Exhaust Stack

Six pairs of tube samples were collected at the Incinerator Exhaust Stack following the procedures outlined in US EPA Method 30B.

A dual probe assembly was used so that the paired mercury traps are positioned 1 to 2 inches apart. Each probe is heated to approximately 135°C to prevent condensation of the stack gas on the sampling media. The mercury traps used for sampling are specially designed for use at wet sources; each tube has an extended section of glass to allow for the heating of the stack gas before it comes into contact with the sampling media.

The sampling methodology is briefly described as follows. Each sorbent trap is removed from the clean sorbent trap storage container, the end caps are removed from the traps and the traps are attached to the end of the sampling probe and leak checked. The probe is inserted into the stack and the sample pumps are started. Stack gas is drawn through the traps and into the sampling probe and the sampled gas stream then passed through a series of empty impingers followed by a silica gel trap to remove any remaining traces of moisture prior to the pump and dry gas meter.

A run consists of paired mercury traps, identified as either A or B, sampled simultaneously. In each tube pair one of either the A or B tube was spiked with a known quantity of mercury. Due to the variability in the mercury concentration in the stack gas and the necessity to have the spiked tubes prepared at least two weeks in advance of the testing program, six pairs of tubes were used for the sampling program to ensure that at least one of the spike concentrations falls within the concentration range requirements of the test method.

The test method states that the recovery spike must be within 50 to 150 percent of the expected mass collected in the traps during sampling. To ensure that at least one of the spike concentrations fall within the concentration range requirements of the test method one tube from each of the six pairs of adsorbent tubes was spiked with increasing amounts of mercury, ranging from 150 ng to 2200 ng, by the analytical laboratory (Ohio Lumex) prior to commencing the test program.

Each test run was sixty minutes in duration at an approximate sampling rate of one liter per minute.

Throughout each test, the following information was measured and recorded for each sampling train:

- Elapsed sampling time
- Dry gas meter volume
- Dry gas meter temperatures
- Control module orifice pressure
- Sampling pump vacuum

At the start and finish of each sampling run the sampling trains are leak-checked. The leakage rate for each train must not exceed 4% of the average sampling rate for the collection period. If a trap pair does not have an acceptable initial leak check, the leak is found and repaired and/or the traps are replaced with a new pair until an acceptable leak check is obtained.

Field data sheets for the six mercury tests performed at the Incinerator Exhaust Stack using US EPA Method 30B are provided in Appendix 6.

At the end of each successful sampling run, the mercury traps were removed from the test train, capped and placed in their appropriate sample container. Each trap was appropriately labeled prior to being shipped to Ohio Lumex for analysis.

The traps were analyzed by thermal decomposition with atomic absorption following the procedures detailed in US EPA Method 7473 (direct thermal desorption with atomic absorption and no gold amalgamation). The method is applicable for total mercury “direct” testing of 40 CFR Part 75 Appendix K and EPA Method 30B sorbent traps.

The mercury analytical report from Ohio Lumex is provided in Appendix 7.

4.3 Mercury Sampling Prior to the PAC Injection

Particulate matter and mercury were sampled together using a modified version of the sampling train and sampling procedures outlined in United States Environmental Protection Agency (US EPA) Method 29. The sampling was conducted concurrently with the sampling at the Incinerator Exhaust Stack so that the mercury removal efficiency could be determined.

The sampling loosely followed the methodology detail in Section 4.1, with the following exceptions:

- The sampling was conducted at a constant sampling rate at a single point in the duct (non-isokinetic); and
- The sampling was stopped when the vacuum on the test train increased significantly enough that the operator could not maintain the sampling rate.

Field data sheets for the two particulate and mercury tests performed prior to the PAC Injection using US EPA Method 29 (Modified) are provided in Appendix 8.

The recovery data sheets are provided in Appendix 4. The particulate matter and mercury analytical report is provided in Appendix 5.

4.4 Acid Gases

Hydrogen chloride, hydrogen fluoride, hydrogen bromide and hydrogen iodide were sampled at the Incinerator Exhaust Stack using the sampling train and sampling procedures outlined in US EPA Method 26.

A single test for these components involved the collection of stack gas sampled at a single point in the stack using a sampling flowrate of approximately two liters per minute for sixty minutes.

At five-minute time increments throughout each test, the following information was measured and recorded for the Method 26 sampling train:

- Elapsed sampling time
- Dry gas meter volume
- Stack gas temperature
- Probe, oven and impinger outlet temperatures
- Dry gas meter temperatures
- Control module orifice pressure
- Sampling pump vacuum

At the start and finish of each test the sampling train was leak-checked. A valid leak check as specified by US EPA Method 26 is a leakage rate of less than 0.04 L/min. The leak checks performed for each of the acid gases tests met this criterion. All leak checks were performed through the entire sampling system by sealing the probe end. The leak check data for the acid gases tests is summarized in Section 8 of this report.

All test train components were cleaned according to the procedures outlined in US EPA Method 26. Field data sheets for the four Method 26 tests performed are provided in Appendix 9.

One Method 26 reagent blank was prepared during the test program.

Prior to loading of the field test trains, a recovery data sheet was prepared to record initial volumes of the test train components. This sheet was also used during sample recovery to record final volumes. The train recovery data sheet is provided in Appendix 10.

On site, the train was disassembled, and the volumes of the first impinger to the fifth impinger were measured. The impingers with connecting glassware back to but not including the three-way valve were rinsed in triplicate with distilled, deionized water and made up to a known volume which was recorded on the sample recovery sheet.

The samples were then sealed, labeled and the fluid levels marked. The samples were then refrigerated until they were delivered to the ALS laboratory for analysis.

The analytical reports for the acid gas analysis are provided in Appendix 11.

4.5 Combustion Gases

Sampling by ORTECH for the combustion gases involved the insertion of a 9 millimeter inside diameter stainless steel probe into the breaching leading to the Incinerator Exhaust Stack. The combustion gases were drawn through the probe and heated filter oven and transferred to the Mobile Source Monitoring Laboratory (MSML) by way of a heated Teflon sampling line that was maintained at a temperature of approximately 160°C throughout the test program to prevent possible condensation.

The combustion gas sample was then conditioned through another heated filter and dried using a two-pass refrigeration unit. The gas was then split into several portions that were metered with rotameters and delivered to each continuous combustion gas analyzer except for the total hydrocarbon analyzer; a portion of the hot, wet gas stream was delivered directly to the total hydrocarbon analyzer.

A Siemens Ultramat 23 analyzer was used to measure oxygen and carbon dioxide concentrations. The method used for sampling was US EPA (40 CFR 60) Method 3A.

A CAI CLD 700 analyzer was used to measure the nitrogen oxides concentrations. The method used for sampling was US EPA (40 CFR 60) Method 7E.

An Ametek 922 analyzer was used to measure sulphur dioxide concentrations. The method used was EPA (40 CFR 60) Method 6C.

A Siemens Ultramat 23 analyzer was used to measure carbon monoxide concentrations. The method used for sampling was US EPA (40 CFR 60) Method 10.

A VIG 20 flame ionization analyzer was used to measure total hydrocarbons (THC) concentrations. The method used was US EPA (40 CFR 60) Method 25A.

The following data acquisition devices were used in conjunction with the continuous analyzers:

Data Logger: Modicon TSX Momentum data acquisition system, 16 channels
Data Software: CEMView
Data Processing: Lap Top Computer

These data acquisition devices were used to transfer the electrical signals from each analyzer into a data file for later processing in a spreadsheet format.

Calibrations were completed before and after each test run according to the sampling protocols.

Linearization checks were performed on the CEMs prior to and at the conclusion of testing. Zero and span drifts, and bias checks were performed prior to and at the completion of each test.

Leak checks of the CEM system were conducted sporadically throughout the program. ORTECH generally relied on other indicators of leakage problems, such as oxygen interference. However, it should be noted that all leak checks performed were acceptable.

4.6 Process Sample Collection

Liquid waste (rich, lean, alkaline, emulsion, TDU and leachate) samples were collected and composited by Clean Harbors personnel. Clean Harbors submitted the samples to Lambton Scientific for mercury analysis. The mercury analytical report for the process samples is provided in Appendix 12.

5. INTERNAL AND EXTERNAL QA/QC PROGRAM

5.1 General

As with other emission testing programs conducted by ORTECH, a comprehensive internal quality assurance/quality control (QA/QC) program was included. Testing was conducted in accordance with ECA No. 8-1030-94-006 and the Notice of Amendment, and the Pre-Test Plan detailing the sampling and analytical methodologies submitted to and approved by the MECP.

Blank sampling trains were recovered and analyzed or reagent blanks were analyzed using the same procedures as the test trains to provide background concentrations of the emission test components.

5.2 Pre-Test Activities

Prior to the commencement of the emission testing program, the following activities were performed:

- Preparation and pre-cleaning of the manual stack sampling trains and sample containers;
- Preparation and quality checks of chemicals, reagents, filters and mercury tubes;
- Calibration of all sampling and monitoring equipment, as well as CEM system linearity and bias checks;
- Development (and review) of data acquisition, data reduction and summary procedures;
- Development of internal QA/QC field data sheets;
- Review of equipment calibration logs; and
- Review of proposed field and laboratory procedures.

All equipment used in the field testing program was calibrated and checked prior to the field testing program. Pertinent equipment calibration data is supplied in Appendix 13.

As part of ORTECH's internal QA/QC, data acquisition, data reduction and summary procedures were already in place and periodic spot checks of the computer programs was performed using known data sets.

A Pre-Test Plan detailing the proposed sampling and analytical methodology was sent to the MECP for review and approval. Provided in Appendix 14 is a copy of the letter, dated August 2, 2022, from the MECP accepting the testing methodology. Testing was conducted following the sampling and analytical methodologies detailed in the Pre-Test Plan under normal operating conditions.

5.3 Emission Testing QA/QC Results

On the day of set up for the field testing program, the following activities were performed. Preliminary testing involved collecting data necessary to perform the required calculations for choosing a nozzle size to permit isokinetic sampling. Much of the preliminary data used in the initial calculations was collected during previous testing programs conducted by ORTECH at this location, and also by reference to the on-site CEM system.

The internal diameter of the stack was verified and the appropriate number of sampling points was marked on the sampling probes. The number of sampling points to be used was stated in the Pre-Test Plan as well as the required sampling time per point.

The following general QA/QC criteria were satisfied for each of the test trains where applicable:

- All sampling equipment was cleaned prior to the commencement of the field testing program.
- All sampling equipment passed a visual and operational check prior to use.
- Oil filled manometer gauges which had been properly leveled and zeroed were used to measure the velocity pressure.
- A test was only considered acceptable if the proper number and location of traverse points had been sampled.
- All sampling data was recorded in ink on preformatted data sheets at least once every three minutes and at least twice during sampling each point.
- Any unusual occurrences were noted on the appropriate data form.
- The team leader reviewed all calibration and sampling data forms daily.
- Only tapered edge sampling nozzles and S-type pitot tubes that had been visually inspected and caliper measured, and deemed acceptable, were used.
- Each leg of the S-type pitot was leak-checked before the start of testing. The leak-checks were all acceptable (no change in pressure occurred).
- Each entire sampling train, met acceptable leak-check criteria before and after each test, and during any move from one traverse to another.
- The S-type pitot tube and sampling nozzle were maintained parallel to the flow during testing and care was taken to ensure that they did not scrape the ports when being inserted and removed from the stack.
- The probe and filter components were maintained at $120^{\circ}\text{C} \pm 14^{\circ}\text{C}$ during testing.

The average percent isokineticity fell within the QA/QC criteria limits of 90 to 110% for each test.

Prior to and at the end of each test, ORTECH's CEMs were calibrated. Also, prior to commencing testing linearity and response/reproducibility checks were conducted on the CEMS. The calibration data for ORTECH's CEM systems is supplied in Appendix 15.

Note sulphur dioxide data was not recorded during Test No. 1 due to scrubbing issues in the sampling system prior to the analyzer. The issue was corrected prior to the start of Test No. 2.

5.4 Sample Recovery, Handling and Custody

ORTECH's sample identification scheme and system for handling and processing samples was initiated as part of ORTECH's sample tracking system for stack emission samples. All samples were identified by a unique sample number comprised of a series of numbers and letters. A master sample log/chain of custody form was maintained by the QA/QC designate and was made available to the ORTECH personnel designated to perform the sample recovery for a specific sampling train. Once a sample was collected it was labeled and checked against the sample log by the QA/QC designate.

The information contained within the sample number and the sample log enabled the sampling, recovery, data reduction and report writing personnel to easily determine the test date, test number, test type and train sample identification for a given sample. To ensure continuity, the analytical laboratories were requested to use the ORTECH number for sample identification.

The ORTECH personnel responsible for shipping samples used the master sample log/chain of custody form to document the transfer of the samples to the appropriate analytical laboratory. Care was taken when shipping the samples in order to maintain sample integrity. Once the samples and master sample log/chain of custody forms were received by the analytical laboratory, the laboratory personnel verified that all samples had been received and their integrity maintained. The laboratory personnel then signed the master log and made a photocopy which ORTECH personnel received as a record of the chain of custody for the samples.

5.5 Analytical Results

All analyses for the present emission testing program were performed using acceptable laboratory procedures in accordance with the specified analytical protocols. Adherence to the prescribed QA/QC procedures ensured data of consistent and measurable quality. Analytical quality control focused on the use of control standards to provide a measure of analytical accuracy. Replicate analyses (usually duplicate analysis) of the same sample were used as a means of determining precision of the various analytical procedures. Also specific acceptance criteria were defined for various analytical operations including calibrations, control standard analysis, drift checks, blanks, etc.

The following general QA/QC procedures were incorporated into the analytical effort:

- the on-site Field Supervisor reviewed all data and QA/QC data on a daily basis for completeness and acceptability
- master sample logs were maintained for all samples collected
- analytical QA/QC data was tabulated by the analytical laboratories using appropriate charts or forms
- all hard copy raw data was maintained in organized files

Specific analytical QA/QC procedures are discussed in the analytical reports and are briefly summarized below.

5.5.1 US EPA Method 29 Mercury Analysis QA/QC

The analyses for mercury on the Method 29 stack samples employed cold vapour atomic absorption (CVAA). The analytical QA/QC is described as follows and the results are provided in the analytical report.

- A 5 point calibration bracketing the expected range.
- An instrument check calibration standard was analyzed immediately after the calibration and must be within 90%-110% of the actual concentration.
- One mid-range calibration standard was analyzed after 10 samples and at the end of the run and must be within 85%-115% of the actual concentration.
- Instrument calibration blank check sample is analyzed with every 10 samples and must be within three times the minimum detection limit.
- One duplicate sample analysis was performed for this program on Test No. 1. The relative percent difference was less than 1.2% well within the acceptable limit of less than $\pm 20\%$, for fractions that are greater than 5 times the minimum detection limit.
- One blank spike (performed as a pre-digestion spike) was analyzed for this program. All of the results were between 94-97% within the acceptable limit of 80-120% of the true value.
- One matrix spike (performed as a post digestion spike) was analyzed for this program. All of the results were between 96-99% within the acceptable limit of 80-120% of the true value.

5.5.2 US EPA Method 30B Mercury Analysis QA/QC

The analysis of the Method 30B samples for mercury was performed by thermal decomposition with atomic absorption. Specific analytical QC procedures for the mercury analysis are summarized below:

- Calibrations are performed on the day of the analysis.
- Three or more calibration points are used for the calibration curve.
- The field samples analyzed must fall within a calibrated range.
- For each calibration curve, $R^2 \geq 0.99$, and the analyzer response must be within $\pm 10\%$ for each standard used in the calibration.
- Following calibration, a second source standard is analyzed. The measured value of the independently prepared standard must be within $\pm 10\%$ of the expected value.
- A blank analysis is conducted prior to analyzing the samples and must be less than the method detection limit.
- At the end of each set of analysis, a calibration standard is tested which must be within $\pm 10\%$ of the expected value.

US EPA Method 30B requires the paired sorbent trap agreement to be $\leq 10\%$ relative deviation for mercury concentrations greater than $1 \mu\text{g}/\text{Rm}^3$ or $\leq 20\%$ relative deviation for mercury concentrations less than $1 \mu\text{g}/\text{Rm}^3$. If the paired trap agreement is greater than the above stated limits the run is not valid. All of the traps collected during the test program had concentrations greater than $1 \mu\text{g}/\text{Rm}^3$. The average dry adjusted mercury concentration ranged from a low of $1.95 \mu\text{g}/\text{Rm}^3$ (Tube Pair No. 3) to a high of $2.55 \mu\text{g}/\text{Rm}^3$ (Tube Pair No. 1) for the first four tests. The first four tests met the paired trap agreement in the test method. Test No. 5 and Test No. 6 did not meet the paired trap agreement criterion stated in the method; however this is typical when the spike concentration is significantly higher than the in-stack mercury concentration. The data for Test No. 5 and Test No. 6 is reported but is excluded from the average calculations.

Six unspiked mercury traps and six pre-spiked mercury traps were ordered approximately two weeks before the field testing program from Ohio Lumex. The pre-spiked mercury traps were spiked with known quantities of mercury ranging from 150 ng to 2200 ng in order to ensure that at least one of the traps met the spiking criterion stated in the test method. The recovery spike must be within 50 to 150 percent of the expected mass collected in the traps during sampling according to the test method. The spiking levels for the field recovery traps was estimated using mercury emission data from previous testing programs conducted between 2014 and 2022. The pre-spiked mercury trap for Test No. 1 (150 ng) and Test No. 2 (250 ng) were used for spike recovery determination as the concentrations best fit the requirements of the QA/QC criteria.

The field spike recovery provides specific verification of the performance of the combined sampling and analytical approach for the test program. Six sets of paired samples, one of each pair which is spiked with a known quantity of mercury, were collected. The samples were analyzed and the spike concentration for Test No. 1 and Test No. 2 fell within the spike range criterion stated in the test method. The spike recovery for Test No. 1 and Test No. 2 was 95.2% and 103.7%, respectively. US EPA Method 30B requires the spike recovery to be between 85% and 115%. The field spike recovery calculations are provided in Appendix 7 with the analytical report.

5.5.3 Acid Gas Sample Analysis QA/QC

Analyses of the acid gas samples from the Method 26 sampling train involved suppressed ion chromatography-conductivity detection. The analytical QA/QC included the following:

- A 6 point calibration bracketing the expected range.
- An instrument check calibration standard was analyzed immediately after the calibration and must be within 90%-110% of the actual concentration.
- A complete set of calibration standards were analyzed at the end of the analysis and must be within 10% of the true value.
- One mid-range calibration standard was analyzed after 10 samples and at the end of the run and actual concentration and must be within 90%-110% of the actual concentration.

- Instrument calibration blank check samples are analyzed with every 10 samples and must be within three times the minimum detection limit for each ion.
- All samples were analyzed in duplicate for each compound and the results had a relative percent difference of less than 2.8%, for analyses that are greater than 5 times the minimum detection limit.
- One blank spike was analyzed for this program. All the results were between 93-96% within the acceptable limit of 80-120% of the true value.
- A matrix spike (spike confirmation) sample was analyzed with every 20 samples to confirm the identity of each peak. The results of the matrix spike sample must be within 80%-120% of the true value. The matrix spikes for this test program were between 80-106%.

6. RESULTS AND DISCUSSION

The mercury emission testing program was conducted on August 17, 2022. A detailed sampling schedule for the testing program is provided in Table 1.

6.1 Stack Gas Sampling Parameters

Emission test calculations for the particulate and mercury tests at the Incinerator Exhaust Stack are provided in Appendix 16.

Stack gas sampling parameters for the particulate and mercury tests are summarized in Table 2. These parameters include calibration data, nozzle diameter, dry gas volume sampled and average percentage of isokineticity for each test, where applicable.

6.2 Stack Gas Physical Parameters

Stack gas physical parameters for the particulate and mercury tests at the Incinerator Exhaust Stack are presented in Table 3 and are summarized below:

Stack Gas Parameter	Incinerator Exhaust Stack
Gas Temperature (°C)	193
Moisture by Volume (%)	48.7
Velocity (m/s)	29.7
Absolute Pressure (kPa)	99.7
Carbon Dioxide by Volume (%)*	7.68
Oxygen by Volume (%)*	9.29

* dry at 25°C and 1 atmosphere

6.3 Volumetric Flowrate Data

Stack gas volumetric flowrates for the particulate and mercury tests at the Incinerator Exhaust Stack are also given in Table 3 and are summarized below:

Stack Gas Parameter	Incinerator Exhaust Stack
Actual Flowrate (m ³ /s)	50.7
Dry Reference Flowrate (Rm ³ /s)*	16.4
Dry Adjusted Flowrate (Rm ³ /s)**	19.2
Wet Reference Flowrate (Rm ³ /s)*	31.9

* at 25°C and 1 atmosphere

** at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

The volumetric flowrates measured at the Incinerator Exhaust Stack were used to calculate emission data for the contaminants measured at the Pre-PAC Injection sampling location since this location was highly non-ideal for flow measurements.

6.4 Particulate Emission Data

Particulate emission data is given in Table 4 and the average particulate emission results are presented below:

Particulate Emission Parameter	Pre-PAC Injection	Incinerator Exhaust Stack
Actual Concentration (mg/m ³)	3438	1.48
Dry Reference Concentration (mg/Rm ³)*	10636	4.59
Dry Adjusted Concentration (mg/Rm ³)**	9069	3.91
Wet Reference Concentration (mg/Rm ³)*	5463	2.36
Particulate Emission Rate (g/s)	174	0.075

* at 25°C and 1 atmosphere

** at 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

6.5 Acid Gases Emission Data

Hydrogen chloride, hydrogen fluoride, hydrogen bromide and hydrogen iodide data obtained from each of the four acid gas tests are given in Table 5.

Hydrogen chloride, hydrogen fluoride and hydrogen bromide were detected in quantities greater than the detect limit in all four tests. Hydrogen iodide was not detected in quantities greater than the detection limit in any of the tests and the emission calculations are based on the value of the detection limit. The average acid gas emission results are presented below:

Parameter	Incinerator Exhaust Stack			
	HCl	HF	HBr	HI
Actual Conc. (mg/m ³)	24.8	14.4	3.50	<0.18
Dry Reference Conc. (mg/Rm ³)*	76.8	44.6	10.8	<0.57
Dry Adjusted Conc. (mg/Rm ³)**	65.5	38.1	9.24	<0.48
Wet Reference Conc. (mg/Rm ³)*	39.4	22.9	5.56	<0.29
Emission Rate (g/s)	1.26	0.73	0.18	<0.0093

* at 25°C and 1 atmosphere

** at 25°C and 1 atmosphere, adjusted to 11% oxygen

6.6 Combustion Gas Emission Data

Average combustion gas analysis data for each of the tests are summarized in Table 6 as dry concentrations except for total hydrocarbons, which was measured on a wet basis. The average combustion gas analysis data is also shown on a dry basis adjusted to 11% oxygen in Table 6.

Combustion gas emission data for the five tests performed at the Incinerator Exhaust Stack are given in Table 7.

The average combustion gas emission results were as follows:

Combustion Gas Parameter	Incinerator Exhaust Stack						
	CO ₂	CO	NO _x	NO	O ₂	SO ₂	THC
Actual Conc. (mg/m ³)	44531	23.7	67.8	43.6	39274	125	7.85
Dry Reference Conc. (mg/Rm ³)**	137830	73.3	210	135	121560	387	24.3
Dry Adjusted Conc. (mg/Rm ³ ***)	117537	62.5	179	115	143873	330	20.7
Dry Conc. (ppm)	76640	64.0	112	110	92940	148	19.1*
Emission Rate (g/s)	2256	1.20	3.43	2.21	1990	6.33	0.40

* wet basis as methane

** at 25°C and 1 atmosphere

*** at 25°C and 1 atmosphere, adjusted to 11% oxygen

Combustion gas concentrations measured by the ORTECH continuous emission monitoring system, expressed as 1-minute average concentrations, for the five tests performed at the Incinerator Exhaust Stack are provided in Appendix 17.

6.7 Mercury Emission Data

Mercury testing was conducted at the Incinerator Exhaust Stack (Post PAC-Injection) following both US EPA Method 29 (modified) and US EPA Method 30B. Sampling for mercury using US EPA Method 29 (modified) was also conducted after the Spray Dryer, just before the PAC injection point (Pre PAC-Injection), concurrently with the sampling at the Incinerator Exhaust Stack in order to calculate mercury removal efficiency.

The US EPA Method 30B mercury emission data for the Incinerator Exhaust Stack is detailed in Table 8. Four of the six tests met the paired trap agreement in the test method. Test No. 5 and Test No. 6 did not meet the paired trap agreement criterion stated in the method; however this is typical when the spike concentration is significantly higher than the in-stack mercury concentration. The data for Test No. 5 and Test No. 6 is reported but is excluded from the average calculations.

The US EPA Method 29 mercury emission data for the Incinerator Exhaust Stack and the PAC injection point is detailed in Table 9. The volumetric flowrates measured at the Incinerator Exhaust Stack were used to calculate emission data for the contaminants measured at the Pre-PAC Injection sampling location since this location was highly non-ideal for flow measurements.

The following table summarizes the average test results and the corresponding emission criteria:

Mercury Emission Data	ECA Limit	Pre-PAC Injection	Post PAC-Injection	
		Method 29	Method 29	Method 30B
Dry Reference Conc. ($\mu\text{g}/\text{Rm}^3$)*	-	191	2.16	2.34
Dry Adjusted Conc. ($\mu\text{g}/\text{Rm}^3$)**	50	163	1.85	1.98

* At 25°C and 1 atm

** At 25°C and 1 atm, adjusted to 11% oxygen

The mercury removal efficiency was calculated using the dry reference concentration data calculated from the US EPA Method 29 tests conducted Pre and Post PAC Injection. The mercury removal efficiency calculations are detailed in Table 10.

The average mercury removal efficiency for the two Method 29 tests conducted was 98.9%.

7. FACILITY PROCESS DATA

Incinerator process data was supplied by Clean Harbors personnel for the emission test periods. The process data is provided as average values for each test and as overall average values for the following process parameters:

- daily incineration report of analysis
- incinerator feed rates (rich, lean, emulsion, alkaline and leachate streams)
- volumetric flowrates (TDU, secondary air and stack gases)
- PAC feed rate
- temperatures (primary zone, secondary zone, spray dryer inlet and outlet)
- pressures (spray dryer outlet, baghouse differential)
- combustion gas stack concentrations (CO, THC, O₂, SO₂)
- stack gas opacity

The one-minute average CEM combustion gas results are provided in Appendix 18, and the one-minute average process data including waste flows, PAC feed and incinerator temperatures and pressures are provided in Appendix 19.

APPENDIX 1

**Data Tables
(10 pages)**

TABLE 1
Clean Harbors
Test Schedule

Mercury Tests (US EPA Method 30B)

Sampling Location	Test Number	Test Date	Sampling Period		Sampling Time min
			Start	Finish	
Incinerator Exhaust	1	August 17, 2022	9:27	10:27	60
Incinerator Exhaust	2	August 17, 2022	10:47	11:47	60
Incinerator Exhaust	3	August 17, 2022	12:11	13:11	60
Incinerator Exhaust	4	August 17, 2022	14:01	15:01	60
Incinerator Exhaust	5	August 17, 2022	15:24	16:29	60
Incinerator Exhaust	6	August 17, 2022	16:46	17:46	60

Particulate Matter and Mercury Tests (US EPA Method 29 Modified)

Sampling Location	Test Number	Test Date	Sampling Period		Sampling Time min
			Start	Finish	
Incinerator Exhaust	1	August 17, 2022	9:25	13:02	180
Incinerator Exhaust	2	August 17, 2022	13:53	17:28	180
Pre-PAC Injection	1	August 17, 2022	9:40	10:00	20
Pre-PAC Injection	2	August 17, 2022	14:21	14:46	25

Acid Gases Tests

Sampling Location	Test Number	Test Date	Sampling Period		Sampling Time min
			Start	Finish	
Incinerator Exhaust	1	August 17, 2022	10:10	11:10	60
Incinerator Exhaust	2	August 17, 2022	11:39	12:39	60
Incinerator Exhaust	3	August 17, 2022	14:18	15:18	60
Incinerator Exhaust	4	August 17, 2022	15:56	16:56	60

Combustion Gas Tests

Sampling Location	Test Number	Test Date	Sampling Period		Sampling Time min
			Start	Finish	
Incinerator Exhaust	1	August 17, 2022	10:30	11:00	30
Incinerator Exhaust	2	August 17, 2022	11:55	12:55	60
Incinerator Exhaust	3	August 17, 2022	13:25	14:25	60
Incinerator Exhaust	4	August 17, 2022	14:37	15:37	60
Incinerator Exhaust	5	August 17, 2022	16:00	17:30	90

TABLE 2
Clean Harbors
Stack Gas Sampling Parameters

US EPA Method 29 (modified) - Particulate Matter and Mercury Test

Sampling Location	Test No.	Pitot Tube Coefficient	Dry Gas Meter Factor	Nozzle Diameter mm	Gas Volume Sampled Rm ³ *	Percentage of Isokineticity %
Incinerator Exhaust	1	0.845	0.973	6.36	3.385	102.4
Incinerator Exhaust	2	0.845	0.973	6.36	3.349	101.7
Pre-PAC Injection	1	-	1.003	5.85	0.187	-
Pre-PAC Injection	2	-	1.003	5.85	0.252	-

* Dry at 25°C and 1 atmosphere

TABLE 3
Clean Harbors
Stack Gas Physical Parameters and Volumetric Flowrates

US EPA Method 29 (modified) - Particulate Matter and Mercury Test

Sampling Location	Test No.	Gas Temp. °C	Moisture by Volume %	Gas Velocity m/s	Static Pressure kPa	Absolute Pressure kPa	Carbon Dioxide by Volume %*	Oxygen by Volume %**	Actual Flowrate m ³ /s	Dry Reference Flowrate Rm ³ /s**	Dry Adjusted Flowrate Rm ³ /s***	Wet Reference Flowrate Rm ³ /s***
Incinerator Exhaust	1	193	48.6	29.7	-0.030	99.8	7.72	9.28	50.7	16.4	19.3	31.9
Incinerator Exhaust	2	193	48.7	29.7	-0.030	99.7	7.63	9.30	50.7	16.3	19.2	31.9
Incinerator Exhaust	Average	193	48.7	29.7	-0.030	99.7	7.68	9.29	50.7	16.4	19.2	31.9

* Dry basis, measured by the ORTECH CEMS

** At 25 °C and 1 atmosphere

*** At 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

TABLE 4
Clean Harbors
Particulate Emission Data

Sampling Location	Test No.	Particulate Collected		Dry Gas Volume Sampled Rm ³ *	Actual mg/m ³	Particulate Concentration		Wet Reference mg/Rm ³ *	Particulate Emission Rate g/s
		Probe Rinse mg	Main Filter mg			Dry Reference mg/Rm ³ *	Dry Adjusted mg/Rm ³ **		
Incinerator Exhaust	1	14.0	1.5	3.385	1.48	4.58	3.90	2.36	0.075
Incinerator Exhaust	2	10.3	5.1	3.349	1.48	4.60	3.93	2.36	0.075
Incinerator Exhaust	Average				1.48	4.59	3.91	2.36	0.075
Pre-PAC Injection	1	896	1220	0.187	3661	11306	9633	5814	186
Pre-PAC Injection	2	1110	1400	0.252	3215	9967	8504	5112	163
Pre-PAC Injection	Average				3438	10636	9069	5463	174

* At 25 °C and 1 atmosphere

** At 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

TABLE 5
Clean Harbors
Incinerator Exhaust Stack
Acid Gas Emission Data

Hydrogen Chloride

Test No.	HCl Collected	Dry Volume Sampled	Actual mg/m ³	Hydrogen Chloride Concentration			HCl Emission Rate g/s
	mg	Rm ^{3*}		Dry Reference mg/Rm ^{3*}	Dry Adjusted mg/Rm ^{3**}	Wet Reference mg/Rm ^{3*}	
1	7.74	0.1178	21.3	65.7	56.0	33.8	1.08
2	8.68	0.1184	23.7	73.3	62.4	37.7	1.20
3	10.7	0.1185	29.1	90.3	77.0	46.3	1.48
4	9.13	0.1173	25.1	77.9	66.4	39.9	1.27
Blank	0.0723	Average	24.8	76.8	65.5	39.4	1.26

Hydrogen Fluoride

Test No.	HF Collected	Dry Volume Sampled	Actual mg/m ³	Hydrogen Fluoride Concentration			HF Emission Rate g/s
	mg	Rm ^{3*}		Dry Reference mg/Rm ^{3*}	Dry Adjusted mg/Rm ^{3**}	Wet Reference mg/Rm ^{3*}	
1	5.39	0.1178	14.8	45.8	39.0	23.5	0.75
2	5.13	0.1184	14.0	43.3	36.9	22.3	0.71
3	5.37	0.1185	14.6	45.3	38.7	23.2	0.74
4	5.18	0.1173	14.2	44.2	37.7	22.7	0.72
Blank	0.0527	Average	14.4	44.6	38.1	22.9	0.73

Hydrogen Bromide

Test No.	HBr Collected	Dry Volume Sampled	Actual mg/m ³	Hydrogen Bromide Concentration			HBr Emission Rate g/s
	mg	Rm ^{3*}		Dry Reference mg/Rm ^{3*}	Dry Adjusted mg/Rm ^{3**}	Wet Reference mg/Rm ^{3*}	
1	0.615	0.1178	1.69	5.22	4.45	2.68	0.086
2	0.884	0.1184	2.42	7.46	6.36	3.84	0.12
3	1.26	0.1185	3.43	10.6	9.07	5.45	0.17
4	2.35	0.1173	6.46	20.0	17.1	10.3	0.33
Blank	<0.225	Average	3.50	10.8	9.24	5.56	0.18

Hydrogen Iodide

Test No.	HI Collected	Dry Volume Sampled	Actual mg/m ³	Hydrogen Iodide Concentration			HI Emission Rate g/s
	mg	Rm ^{3*}		Dry Reference mg/Rm ^{3*}	Dry Adjusted mg/Rm ^{3**}	Wet Reference mg/Rm ^{3*}	
1	<0.0643	0.1178	<0.18	<0.55	<0.47	<0.28	<0.0090
2	<0.0680	0.1184	<0.19	<0.57	<0.49	<0.30	<0.0094
3	<0.0671	0.1185	<0.18	<0.57	<0.48	<0.29	<0.0093
4	<0.0680	0.1173	<0.19	<0.58	<0.49	<0.30	<0.0095
Blank	<0.0671	Average	<0.18	<0.57	<0.48	<0.29	<0.0093

* At 25 °C and 1 atmosphere

** At 25 °C and 1 atmosphere, adjusted to 11% oxygen by volume

Note: All analytical results are reported as the average of duplicate analyses.

"<" indicates that the analyte was not detected (was less than the analytical detection limit), and the value of the detection limit was used to calculate the emission data.

TABLE 6
Clean Harbors
Incinerator Exhaust Stack
Combustion Gas Analyses

Average Combustion Gases - As Measured

Test No.	Carbon Dioxide %	Carbon Monoxide ppm	Nitrogen Oxides *	Nitric Oxide ppm	Oxygen %	Sulfur Dioxide ppm	Total Hydrocarbons ** ppm
1	7.71	65.8	108	107	9.37	-	19.4
2	7.74	70.7	107	105	9.19	132	22.1
3	7.93	60.9	117	115	8.93	166	19.7
4	7.12	49.8	114	112	9.84	138	15.3
5	7.82	73.0	112	111	9.14	156	18.9
Average	7.66	64.0	112	110	9.29	118	19.3

Average Combustion Gases - Dry Basis Adjusted to 11% Oxygen

Test No.	Carbon Dioxide %	Carbon Monoxide ppm	Nitrogen Oxides *	Nitric Oxide ppm	Oxygen %	Sulfur Dioxide ppm	Total Hydrocarbons ppm
1	6.62	56.5	92.7	91.9	-	-	32.4
2	6.54	59.8	90.5	88.8	-	112	36.4
3	6.56	50.4	96.8	95.1	-	137	31.8
4	6.37	44.6	102	100	-	124	26.7
5	6.58	61.5	94.3	93.4	-	131	31.0
Average	6.54	54.5	95.3	93.9	-	101	31.7

* Nitric oxide and nitrogen dioxide

** Wet basis as methane, one-minute average data

TABLE 7
Clean Harbors
Incinerator Exhaust Stack
Combustion Gas Emission Data

Test No.	Combustion Gas	Dry Actual Concentration	Dry Adjusted Concentration	Dry Concentration by Weight		Wet Concentration by Weight		Emission Rate
		ppm	ppm	Reference** mg/Rm ³	Adjusted *** mg/Rm ³	Actual mg/m ³	Reference** mg/Rm ³	
1	Carbon Dioxide	77100	65691	138658	118140	44897	71306	2275
	Carbon Monoxide	65.8	56.1	75.3	64.2	24.4	38.7	1.24
	Nitrogen Oxides ****	108	92.0	203	173	65.7	104	3.33
	Nitric Oxide	107	91.2	131	111.8	42.5	67.5	2.15
	Oxygen	93700	110000	122554	143873	39682	63024	2011
	Sulphur Dioxide	-	-	-	-	-	-	-
	Total Hydrocarbons	19.4 *	32.1	24.7	21.0	7.99	12.7	0.40
2	Carbon Dioxide	77400	65947	139197	118600	45072	71583	2284
	Carbon Monoxide	70.7	60.2	80.9	68.9	26.2	41.6	1.33
	Nitrogen Oxides ****	107	91.2	201	171	65.1	103	3.30
	Nitric Oxide	105	89.5	129	110	41.7	66.2	2.11
	Oxygen	91900	110000	120199	143873	38920	61814	1972
	Sulphur Dioxide	132	112	345	294	112	178	5.67
	Total Hydrocarbons	22.1 *	36.6	28.1	23.9	9.10	14.5	0.46
3	Carbon Dioxide	79300	67664	142614	121688	46008	73142	2330
	Carbon Monoxide	60.9	52.0	69.7	59.5	22.5	35.7	1.14
	Nitrogen Oxides ****	117	99.8	220	188	71.0	113	3.59
	Nitric Oxide	115	98.1	141	120	45.5	72.3	2.30
	Oxygen	89300	110000	116799	143873	37680	59902	1908
	Sulphur Dioxide	166	142	434	371	140	223	7.10
	Total Hydrocarbons	19.7 *	32.8	25.1	21.4	8.10	12.9	0.41
4	Carbon Dioxide	71200	60752	128047	109258	41309	65671	2092
	Carbon Monoxide	49.8	42.5	57.0	48.6	18.4	29.2	0.93
	Nitrogen Oxides ****	114.0	97.3	214	183	69.1	110	3.50
	Nitric Oxide	112.0	95.6	137	117	44.3	70.4	2.24
	Oxygen	98400	110000	128701	143873	41520	66007	2103
	Sulphur Dioxide	138	118	361	308	116	185	5.90
	Total Hydrocarbons	15.3 *	25.5	19.5	16.6	6.29	10.0	0.32
5	Carbon Dioxide	78200	66725	140636	120000	45370	72128	2298
	Carbon Monoxide	73.0	62.3	83.5	71.3	27.0	42.8	1.37
	Nitrogen Oxides ****	112	95.6	211	180	67.9	108	3.44
	Nitric Oxide	111	94.7	136	116	43.9	69.8	2.22
	Oxygen	91400	110000	119545	143873	38566	61311	1953
	Sulphur Dioxide	156	133	408	348	132	209	6.67
	Total Hydrocarbons	18.9 *	31.4	24.1	20.6	7.77	12.4	0.39
Average	Carbon Dioxide	76640	65356	137830	117537	44531	70766	2256
	Carbon Monoxide	64.0	54.6	73.3	62.5	23.7	37.6	1.20
	Nitrogen Oxides ****	112	95.2	210	179	67.8	108	3.43
	Nitric Oxide	110	93.8	135	115	43.6	69.2	2.21
	Oxygen	92940	110000	121560	143873	39274	62412	1990
	Sulphur Dioxide	148	126	387	330	125	199	6.33
	Total Hydrocarbons	19.1 *	31.7	24.3	20.7	7.85	12.5	0.40

* THC concentrations by volume (ppm) are provided on a wet basis

** At 25°C and 1 atmosphere

*** At 25°C and 1 atmosphere, adjusted to 11% oxygen by volume

**** Nitric oxide and nitrogen dioxide as the equivalent amount of nitrogen dioxide

TABLE 8
Clean Harbors
Incinerator Exhaust Stack
US EPA Method 30B Mercury Emission Data

Test/Run No.	Tube ID	Mercury Collected		Total	Dry Gas Volume Sampled Rm ³ *	Mercury Concentration		Paired Trap Agreement %
		Section 1 ng	Section 2 ng			Dry Reference µg/Rm ³ *	Dry Adjusted µg/Rm ³ **	
1	A	148.8	<0.39	149	0.0570	2.61	2.24	-
	B ***	156.1	1.0	157	0.0630	2.50	2.14	-
	Average					2.55	2.19	2.2
2	A ***	141.9	2.0	144	0.0578	2.49	2.14	-
	B	151.6	0.9	153	0.0654	2.33	2.01	-
	Average					2.41	2.08	3.3
3	A	115.8	1.5	117	0.0567	2.07	1.75	-
	B ***	99.6	1.3	101	0.0553	1.82	1.54	-
	Average					1.95	1.65	6.3
4	A ***	134.4	<0.39	134	0.0561	2.40	1.98	-
	B	150.8	0.3	151	0.0611	2.47	2.04	-
	Average					2.43	2.01	1.6
5	A	84.0	0.1	84.1	0.0591	1.42	1.32	-
	B ***	60.0	<0.39	60.0	0.0623	0.96	0.90	-
	Average					1.19	1.11	19.2
6	A ***	26.0	1.1	27.1	0.0569	0.48	0.40	-
	B	127.7	0.8	129	0.0619	2.08	1.74	-
	Average					1.28	1.07	62.7
Average				138		2.34	1.98	

Note: The results for Test No. 5 and Test No. 6 were excluded from the average as the paired trap agreement didn't meet the method QA/QC.

* This is typical for spike concentrations that are significantly higher than the stack mercury concentration.

** At 25°C and 1 atmosphere

*** At 25°C and 1 atmosphere, adjusted to 11% oxygen

**** Spiked tube, mercury collected corrected for the original spike.

TABLE 9
Clean Harbors
US EPA Method 29 (Modified) Mercury Emission Data

Sampling Location	Test No.	Mercury Collected		Dry Gas Volume Sampled Rm ³ *	Dry Reference µg/Rm ³ **	Mercury Concentration		Emission Rate mg/s
		Particulate Bound µg	Impingers & Rinses µg			Total µg	Dry Adjusted µg/Rm ³ **	
Incinerator Exhaust	1	0.15	7.84	3.385	2.36	2.01	0.039	
Incinerator Exhaust	2	0.20	6.39	3.349	1.97	1.68	0.032	
Incinerator Exhaust	Average				2.16	1.85	0.035	
Pre-PAC Injection	1	7.92	26.6	0.187	184	157	3.03	
Pre-PAC Injection	2	7.80	42.0	0.252	198	169	3.23	
Pre-PAC Injection	Average				191	163	3.13	
Blank		<0.015	<0.3					

* At 25°C and 1 atmosphere

** At 25°C and 1 atmosphere, adjusted to 11% oxygen

Note: The Pre-PAC Injection emission data was calculated using the volumetric flowrates measured at the Incinerator Exhaust Stack

TABLE 10
Clean Harbors
Mercury Removal Efficiency

US EPA Method 29 (modified)

Test No.	Mercury Dry Reference Concentration		Removal Efficiency %
	Pre-PAC Injection $\mu\text{g}/\text{Rm}^3^*$	Incinerator Exhaust $\mu\text{g}/\text{Rm}^3^*$	
1	184	2.36	98.7
2	198	1.97	99.0
Average	191	2.16	98.9

* At 25°C and 1 atmosphere

APPENDIX 2

**Environmental Compliance Approval No. 8-1030-94-006
(29 pages)**



Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A.I.
NUMBER 8-1030-94-06

Page 1 of 1

LIDLAW ENVIRONMENTAL SERVICES LTD.
265 N. Front Street,
Sarnia, Ontario
N7T 7X1

Located at: Part of Lot 9, Concession 10, Township of Moore,
County of Lambton

You have applied in accordance with Section 9 of the Environmental Protection Act for approval of:

to operate the facility to incinerate hauled liquid industrial waste class no(s). 111-114 inclusive, 121, 122, 123, 131-135 inclusive, 141-150 inclusive, 211-213 inclusive, 221, 222, 231-233 inclusive, 241, 242, 251-254 inclusive, 261-270 inclusive, 281, 282, 311 and 321 which may bring about the emissions of air pollutants from an exhaust stack with the height of approximately 68 metres above ground, with the diameter of approximately 1.5 metres and equipped with an exhaust cone 1.22 metres in diameter in accordance with the application from Laidlaw Environmental Services Ltd. dated December 23, 1994 and supporting documentation listed in Appendix A, subject to conditions as described in Schedule I.

This certificate replaces the Certificate of Approval (Air) Number 8-1039-91-006 dated May 23, 1991.

You are hereby notified that this approval is issued subject to the following terms and conditions outlined below:

TERMS AND CONDITIONS

DEFINITIONS

1. For the purpose of this Certificate of Approval:
 - a. "air pollution control system" means the entire air pollution control train consisting of a spray dryer and a baghouse as described in the Application for Certificate of Approval for Plant Modifications at Tricil (Sarnia) Limited, Corunna, Ontario by Tricil Limited dated July 15, 1981.
 - b. "ash" means solid residues from the incineration process;
 - c. "baghouse ash" means solids recovered from the baghouse;
 - d. "°C" means degrees Celsius;
 - e. "CEM" means continuous emission monitor;



- e. "CEM-CSA" means Continuous Emission Monitoring Methods, Canadian Standards Method: CAN/CSA-Z2223.2-M86, ISSN 0317-5669, September 1986, Canadian Standards Association;
- g. "certificate" means this entire certificate of approval including its schedules issued in accordance with Section 8 of the Environmental Protection Act;
- h. "company" means Laidlaw Environmental Services (Sarnia) Ltd. formerly called Tricil (Sarnia) Limited;
- i. "Director" means any Ministry employee appointed by the Minister pursuant to Section 5 of the Act;
- j. "District Manager" means the District Manager, Sarnia District Office of the Southwestern Region of the Ministry;
- k. "facility" consists of an incinerator, storage tanks for waste and the associated piping and pumps, and air pollution control system as described in the Application for Certificate of Approval for Plant Modifications at Tricil (Sarnia) Limited, Corunna, Ontario by Tricil Limited dated July 15, 1981; and in the document titled "Proposal to Provide Secondary Combustion Air for the L.E.S.L. Lambton Incinerator" and shown in drawings numbered D-32-2-043 and DX-03-0-192 by Four Nines, Inc.; and in the document titled Modifications to Existing Sarnia Tank Farm, Conceptual Scope of Work, February 1991, and modified to allow the introduction of vent gases from the existing storage tanks and purge gases from the centrifuge and the steam still into the combustion air plenum at the incinerator as described in the application for a certificate of approval (air) dated August 7, 1991 and supporting documentation listed in Appendix; and further modified as described in the application letter to Mr. H.O. Wigle dated November 16, 1992 and signed by Mr. Dean C. Edwardson along with a document titled: Proposal; Incineration of Intermediate Heat Value Waste and drawings by the MIG Engineering Ltd. of Sarnia, Ontario numbered 8881/8745/8562 and No. 8562;
- l. "GCM-THC" means Guideline for Continuous Monitoring of Total Hydrocarbons (Draft), Ontario Ministry of the Environment;
- m. "incinerator" means equipment for thermal destruction of waste as described in the Application for Certificate of Approval for Plant Modifications at Tricil (Sarnia) Limited, Corunna, Ontario by Tricil Limited dated July 15, 1981;
- n. "intermediate heat value waste" means an emulsion containing rich and lean waste with a total heating value of more than 4 MJ/kg and less than 25 MJ/kg;



- o. "kPa" means kiloPascals;
- p. "lean waste" means waste water contaminated with small quantity of liquid organic waste with a heating value of not more than 4 MJ/Kg;
- q. "lpm" means liters per minute averaged over a one minute period;
- r. "Manager" means the Manager, Environmental Engineering Services Section, Science and Technology Branch, or any other person who represents and carries out the duties of the Manager, Environmental Engineering Services Section, Science and Technology Branch, as those duties relate to the conditions of this certificate;
- s. "Ministry" means the Ontario Ministry of Environment and Energy;
- t. "MJ/kg" means megajoules per kilogram;
- u. "ppm" means parts per million by volume;
- v. "Regional Director" means the Director of the Southwestern Region of the Ministry of the Environment and Energy;
- w. "rich waste" means liquid organic waste with a heat value of at least 25 MJ/kg;
- x. "Source Testing Code" means the Ministry's publication ISBN 0-7748-6419-X "Source Testing Code", Version #2, Report # ARB-66-80, November 1980;
- y. "U.S. opacity guideline" means Performance Specification 1 - Specifications and Test Procedures for Opacity Continuous Emission Monitoring Systems in Stationary Sources, Title 40, Part 60 under Code of Federal Regulations Ch. I, July 1, 1987 Edition.

Applicability of the Certificate

- 2. The company shall operate the facility and shall fulfil the requirements of this certificate in full compliance with each and every condition contained in Provisional Certificate of Approval No. A 031813 issued for a Waste Disposal Site.

Requirements

- 3. The conditions of this certificate are imposed pursuant to Section 8 of the Environmental Protection Act. The issuance of this certificate in no way abrogates the company's legal obligation to comply with all of the requirements of Ontario Regulation 346, and all other applicable legislation and regulations.



Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A I R

NUMBER 8-1030-94-004

Page 4 of 12

Interpretation (Severability and Conflicts)

4. a. The requirements of this certificate are severable. If any requirement of this certificate, or the application of any requirement of this certificate to any circumstance, is held invalid, the application of such requirement to other circumstances and the remainder of this certificate shall not be affected thereby.
- b. In all matters requiring the interpretation and implementation of this certificate, the conditions of the certificate shall take precedence, followed in descending order by the company's application and the documentation, referred to in this certificate, which is submitted in support of this application.

Compliance

5. The company shall ensure compliance with all the terms and conditions of this certificate. Non-compliance constitutes a violation of the Environmental Protection Act and is grounds for enforcement.

Changes to be Reported

6. The company shall notify the District Manager in writing of any of the following changes within 30 days of the change occurring:
 - a. change of address of the company;
 - b. change of the name of the corporation where the company or operator is or at any time becomes a corporation, and a copy of the most current "Initial Notice or Notice of Change" (Form 1, 2, or 3 of O. Reg. 189, R.R.O. 1989, as amended from time to time), filed under The Corporations Information Act shall be included in the notification to the District Manager;
 - c. change in directors or officers of the corporation where the company or operator is or at any time becomes a corporation, and a copy of the most current "Initial Notice or Notice of Change" as referred to in clause (b);

Information

7. In the event the company provides to the Ministry information, records, documentation or notification in accordance with this certificate (for the purposes of this condition, "information"),



- a. the receipt of said information by the Ministry;
- b. the acceptance by the Ministry of the information's completeness accuracy; or,
- c. the failure of the Ministry to prosecute the Company, or to require the company to take any action, under this certificate or a statute or regulation in relation to said information;

shall not be construed as the approving, excusing or justifying by the Ministry of any act or omission of the company relating to said information, amounting to non-compliance with this certificate or a statute or regulation.

Adverse Impact

8. The company shall take all reasonable steps to minimize any adverse effect resulting from non-compliance with the requirements specified in this certificate including, but not limited to, such accelerated or additional monitoring as may be necessary to determine the nature and impact of the discharge in respect of which there is non-compliance.

Conditions for Ministry Order of Immediate Shutdown

9. The Regional Director may order an immediate shutdown of the facility and the company shall comply with such an order where, in the opinion of the Regional Director upon probable grounds, a violation of an condition has resulted or may result in an adverse effect as that is described in the Environmental Protection Act.

SECTION 2: OPERATION AND MAINTENANCE

Operation and Maintenance

10. a. The company shall ensure that at all times, the site and facility and related fixtures, appurtenances, equipment and services which are installed or used to achieve compliance with this certificate are properly operated and maintained.
- b. In furtherance of, but without limiting the generality of, the obligation imposed by subcondition a the company shall ensure that:



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A.I
NUMBER 8-1030-94-00

Page 6 of 1

- i. funding, staffing, training of staff, laboratory and process controls, quality assurance and quality control procedures, or in relation to the site and facility is adequate to achieve compliance with this certificate; and,
- ii. equipment and material are kept on hand and in good repair for immediate use in the event of:
 - (1) any change in process parameters which results or potentially could result in an excursion from the operational ranges set out in condition 16 of this certificate;
 - (2) any fire or explosion;
 - (3) any discharge of a contaminant into the natural environment or interior of any building; or,
 - (4) any spill within the meaning of Part IX of the Environmental Protection Act,

and staff are trained in the use of said equipment and material and in the methods and procedures to be employed upon the occurrence of such an event.

Operating Manual

11. In furtherance of, but without limiting the generality of the obligation imposed by condition 10, the company shall operate the facility in accordance with the Operating Manual which should be made available to the District Manager for inspection upon request. The company shall keep the operating manual up to date through revisions undertaken from time to time so as to reflect any changes in the described operation and maintenance procedures made necessary by good engineering practice, this certificate or the requirements of the Ministry.

Due Diligence

12. The obligations imposed by the terms and conditions of this certificate of approval are obligations of due diligence.

Stack Emission Criteria

13. The Company shall operate the incinerator such that it meets all point of impingement standards in Regulation 346 and guidelines listed in Schedule A and the following emission constraints;



Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

AIR

NUMBER 8-1030-94-006

Page 7 of 16

- a. Maximum opacity of the stack gas as measured by a properly maintained opacity monitor shall not exceed 10% for more than four minutes in the aggregate in any thirty minute period.
 - b. Maximum concentration of residual organic matter as measured by a total hydrocarbon monitor shall not exceed 100 ppm by volume on undiluted basis, expressed as equivalent methane, being an average of ten measurements taken at approximately one minute intervals.
 - c. The maximum concentration of carbon monoxide (CO) in the stack gas shall not exceed 250 ppm by volume on undiluted basis, being an average of ten measurements taken at approximately one minute intervals.
 - d. Maximum concentration of particulate matter in the stack shall not exceed 50 mg/m³ normalized to 11% of oxygen in dry stack gas at 25°C and 101.3 kPa.
14. Within six month following the issue date of this certificate, the company shall submit to the Regional Director a report outlining a timetable and steps it will undertake to decrease the concentrations of carbon monoxide in the stack gas to less than 100 parts per million.

Limitation on Wastes

15. The Company shall comply with limitations regarding the feeding rates of various wastes and the heat contents of these wastes as follows:
- a. The maximum feeding rate of rich waste to the incinerator shall not exceed 45 lpm with a minimum heating value of 25 MJ/kg.
 - b. The maximum feeding rate of lean waste to the incinerator shall not exceed 170 lpm providing the heating value of waste does not exceed 4 MJ/kg.
 - c. The maximum feeding rate of intermediate heat value waste to the incinerator shall not exceed 20 lpm.
 - d. Wastes fed into the incinerator shall not contain more than 2% of organic chlorine by weight.

Detailed Operating Conditions

16. In addition to the obligations imposed by condition 13, condition 14 and condition 15, the company shall operate the incinerator at all times while wastes are fed into the incinerator as follows;



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A 11

NUMBER 8-1030-94-00

Page 8 of 11

- a. The company shall install and operate mixers or recirculation pumps in the designated feed tanks for lean and rich wastes, as described in Modifications to Existing Sarnia Tank Farm, Conceptual Scope of Work, January 17, 1991, prior to feeding these wastes into the incinerator.
- b. 1300°C flame temperature measured accurately in the primary zone by means of auxiliary fuel control.
- c. 800°C as measured by the temperature recorder TR-241 located at the exit from the incinerator by means of control of the feeding rate of lean waste.
- d. The incinerator shall provide not less residual oxygen in the stack gas than 8% by volume as measured by the continuous emission monitor for oxygen.
- e. Spray dryer outlet temperature shall not exceed 225°C
- f. Incinerator pressure, as measured at the exit of the incinerator by a pressure indicator PI-242 shall not exceed 25 millimetres of water column for more than 5 seconds.
- g. The company shall operate the incinerator to immediately cut off waste feed when any of the following occurs:
 - i. the temperature in the primary chamber falls below 1300°C.
 - ii. the exit temperature as measured in subcondition c. falls below 800°C.
 - iii. Concentration of oxygen in the stack gas as measured in subcondition "d" falls below 8%.
 - iv. Level of opacity in the stack gas exceeds 10% for more than four minutes in any half hour as described in subcondition "13a".
 - v. Concentration of organic matter in the incinerator exhaust gas exceeds 100 ppm on the average in a ten measurements taken at approximately one minute intervals.
 - vi. Concentration of carbon monoxide (CO) in the stack gas exceeds 250 ppm, being an average of ten measurements taken at approximately one minute intervals.
 - vii. Spray dryer outlet temperature exceeds 225°C.



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

NUMBER 8-1030-940

Page 9 of

- h. The company shall shut down the incinerator in the event of;
- i. Incinerator pressure, as measured in subcondition "f", exceed 25 millimetres of water.
 - ii. Loss of flame in the incinerator.
- i. During start-up and shut-down of the incinerator, waste must not be introduced into the incinerator unless the incinerator is operating within the conditions specified in subconditions "a" through "f" inclusive;
17. Within six months following the issue date of this certificate, the company shall submit to the Regional Director a report outlining a timetable and steps which it will undertake to decrease the spray dryer outlet temperature to less than 200°C.

SECTION 3: CONTINUOUS MONITORING AND STACK TESTING

Continuous Emission and Process Monitoring

18. All CEMs presently installed on site shall be maintained and operated in accordance with the procedures described in the attached copies of CEM procedures. The monitored parameters include the following:
- a. opacity;
 - b. stack concentrations of: sulphur dioxide, total hydrocarbons (THC), carbon monoxide and oxygen;
 - c. feed rates to the incinerator, temperature in the incinerator primary zone, incinerator exit temperature, incinerator exit pressure, exit spray dryer temperature, stack gas temperature and stack gas flow;
 - d. Continuous emission monitoring equipment and process monitoring equipment for parameters listed in subcondition a and subcondition b and subcondition c shall be equipped with continuous recording devices and with appropriate alarms for indication of exceedances of set points where applicable;
 - e. Audible and/or visible alarms indicating exceedances of set points will be activated at the values specified in subcondition 13 a., subcondition 13b and subcondition 13c of this certificate;
 - f. Continuous stack monitors shall be properly maintained and calibrated as described in the attached copies of the U.S. opacity guideline, GCM-THC and CEM-CSA and confirmed by the Manager.



Stack Testing

19. The company shall carry out stack testing annually to determine the emissions of the following;
 - a. Total particulates and trace metals specified in Table 6 of Schedule B to this certificate;
 - b. Volatile organic contaminants specified in Table 3 of Schedule B to this certificate;
 - c. Semivolatile trace organic species specified in Tables 1, 2, 4, and 5 of Schedule B to this certificate;
 - d. Oxides of nitrogen;
 - e. Sulphur dioxide;
 - f. Hydrogen chloride.
20. The company shall use sampling and analytical procedures which are in agreement with the Source Testing Code and approved by the Manager;
 - a. Each pollutant category listed in condition 19 shall be sampled a minimum of three times to obtain three valid test samples as part of one sampling campaign;
 - b. Each sampling test shall be considered a compliance test as defined in the Source Testing Code.
21. In preparation for stack testing, the company shall, within the limitations imposed by the availability of waste, tank farm capacity and time constraints, attempt to accumulate sufficient quantities of waste which are representative of waste causing highest stack emissions in normal operation;
 - a. Prior to stack testing the company shall analyze the composite samples of all wastes fed to the facility for the following: total PCBs, total dioxins and furans, hexachlorobenzene, pentachlorophenol, hexachloroethane, carbon tetrachloride and solids content in addition to all parameters listed in the company report on analyses of daily process samples titled "Incineration of Intermediate Heat Value Wastes at Tricil (Sarnia) Limited." dated 1987;
 - b. A record of THC and opacity monitor readings shall be kept while incinerating wastes of known composition as per subcondition a;



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A.1

NUMBER 8-1030-94-0

Page II of 1

- c. Company shall make every effort to secure sufficient quantity of representative waste for feeding the facility during stack testing. The representative waste shall be similar in composition to the waste which caused the highest THC and opacity readings in pre-tests work described in subcondition a and subcondition b;
- d. Upon consulting the District Manager, the company may exceed the maximum feeding rates shown in condition 15 in the period of one month prior to and during stack tests providing the increased feeding rates do not violate other terms of this certificate.

Incinerator Operation During Stack Testing

22. For the purpose and duration of stack tests only, or after obtaining the approval from the Director, the company may change the minimum temperatures in the incinerator imposed by subcondition 16b and subcondition 16c providing none of the limits imposed by condition 13 has been exceeded.
23. The Company shall call a meeting between the stack sampling consultant, the Manager and the District Manager, at least two weeks prior to tests, to discuss:
 - a. sampling protocol, process conditions and individual responsibilities during testing;
 - b. timing of tests so that witnessing can be arranged at Manager's discretion;
 - c. procedure for execution of a new tests in place of any compliance test which, in the opinion of the Manager or its designate, deviated significantly from the Source Testing Code.

Sampling of Process Effluents

24. The Company shall prepare three composite samples of rich waste, lean waste and baghouse ash during each stack test. The composite samples shall be analyzed for contaminants to be specified by the company and approved by the Regional Director prior to stack testing. Sampling procedure and frequency shall be determined at the meeting referred to in condition 23.



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

NUMBER 8-1030-94-00

Page 12 of 16

Reporting of Stack Testing Results

25. The company shall provide to the District Manager;
- A report summarizing test results not later than 30 days after the receipt of the results from the laboratory.
 - A stack test report conforming with the requirements of the Source Testing Code and containing stack testing results, continuous monitoring data obtained during each stack sampling test, results of analyses on process samples, process data and feed rates, assessment of operation and interpretation of results not later than 90 days after the receipt of the results from the laboratory.
 - Any test including sampling and laboratory analyses which in the opinion of the Director has not been performed in accordance with the Source Testing Code or sampling methods as agreed to by the Manager, shall be repeated by the company in the shortest time practicable.

Reporting of Continuous Emission Monitoring Data

26. The company shall provide to the District Manager monthly summaries of continuous emission monitoring data; the summaries shall include average monthly values of all parameters listed subcondition 18a and subcondition 18b and the concomitant standard deviations; the number and duration of exceedances of the operational ranges listed in subcondition 13a, subcondition 13b and subcondition 13c; and reasons for exceedances and corrective actions.

The reasons for the imposition of these terms and conditions are as follows:

SECTION 1: GENERAL CONDITIONS

Definitions

1. Condition 1 is included to define special terms used throughout this certificate.

Applicability of the Certificate

2. Condition 2 is imposed to emphasize that in addition to conditions in this certificate the company shall comply with conditions contained in the Provisional Certificate of Approval A 031813 issued for a Waste Disposal Site.



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A1

NUMBER 8-1030-94-0

Page 13 of

Requirements

3. Condition 3 is included to emphasize that the issuance of the certificate does not diminish any other statutory and regulator obligations to which the company is subject in the construction, maintenance and operation of the facility, and in particular the requirements of Regulation 346.

Interpretation (Severability and Conflict)

4. Condition 4 is included to clarify how the certificate is to be judicially interpreted and specifically, to clarify that the requirements of the certificate are severable and that they prevail over supporting documentation.

Compliance

5. Condition 5 is included to emphasize that the company is under a statutory obligation to ensure compliance with the certificate.

Changes to be Reported

6. Condition 6 is included to ensure that the Ministry records are kept accurate and current with respect to approved facility and to ensure that subsequent owners of the facility are made aware of the certificate and continue to operate the facility in compliance with it.

Information

7. Condition 7 is included to ensure that Ministry personnel, when acting in the course of their duties, will be given information and records related to the facility which are the subject of this certificate, to enable the Ministry to be assured of the company's compliance with the terms and conditions of this certificate. Subsection c is included to make the company aware that the mere provision of information in accordance with this certificate shall not exonerate it from enforcement in relation to any non-compliance disclosed by that information simply because the Ministry fails to note the non-compliance, require corrective action or prosecute.

Adverse Impact

8. Condition 8 is included to emphasize that the company has an ongoing duty to mitigate any adverse impacts resulting from non-compliance with the certificate.

Conditions for Ministry Order of Immediate Shutdown

9. Condition 9 is included to emphasize that the company will not be permitted to operate the facility in case of non-compliance with the conditions in this certificate.



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

A.
NUMBER 8-1030-94-

Page 14 of

SECTION 2: OPERATION AND MAINTENANCE

Operation and Maintenance

10. Condition 10 is included to ensure that the facility will be operated maintained, funded, staffed and equipped in a manner enabling compliance with the terms and conditions of this certificate, such that the environment is protected and deterioration, loss, injury or damage to any person or property is prevented.

Operating Manual

11. Condition 11 is included to ensure that the company shall follow approved operating procedures as required by this certificate and that the operating manual shall be kept up to date.

Due Diligence

12. Condition 12 is included to clarify that the terms and conditions of this certificate of approval impose a standard of due diligence and not absolute liability.

Stack Emission Criteria

13. Condition 13 is included to ensure that the facility, including air pollution control equipment, will not emit into the ambient air pollutants at rates which are higher than achievable by the facility as demonstrated by stack tests and the company's monthly reports. In the case of carbon monoxide, the two minutes interval was added to recognize that some time will be required to purge the incinerator and the air pollution control equipment after the waste feed has been cut off as required by condition 16 of the certificate.

14. Condition 14 is included to ensure that further improvements to the incineration process are made to ensure a minimum combustion efficiency of 99.9%.

Limitation on Wastes

15. Condition 15 is included to ensure that feeding rates to the incinerator shall not exceed the values which were recorded during stack testing which in conjunction with continuous emission monitoring indicated compliance with emission limits imposed by this certificate.

Detailed Operating Conditions

16. Condition 16 is included to specify safe limits of operating parameters in normal operation and actions to be taken when these limits are not met. These limits have been achieved in operation and are considered adequate for the destruction of toxic trace organics.



Ontario

Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL

AI
NUMBER 8-1030-94-01

Page 15 of 1

17. Condition 17 is included to ensure that the company decreases the temperature of the scrubber outlet so as to minimize the emissions of dioxins and volatile metals such as mercury.

SECTION 3: CONTINUOUS MONITORING AND STACK TESTING

Continuous Emission and Process Monitoring

18. Condition 18 is included to ensure compliance with the requirements of continuous emission and process monitoring, as applicable, imposed by condition 13, condition 15 and condition 16. This condition emphasizes that the Manager is authorized to determine whether the monitors are operated in an acceptable manner.

Stack Testing

19. Condition 19 is included to specify stack sampling which must be carried out on annual basis in order to assess air emissions from the facility. The selection of pollutants for sampling was based on waste composition, consideration of process and the results of previous stack testing at this facility.
20. Condition 20 is included to emphasize the authority of the Manager to approve sampling and analytical procedures, the required number of stack tests and the fact that every test will be considered as compliance test as described in the Source Testing Code.
21. Condition 21 is included to establish a relationship between the waste composition and stack emissions and to ensure that the emissions measured during stack testing will be representative of those process conditions which may induce highest stack emissions, as is stipulated by the definition of compliance test in the Source Testing Code.
22. Condition 22 allows the company to change the temperatures in the incinerator for testing purposes and in normal operation only after obtaining the Director's approval.
23. Condition 23 is included to enable all parties involved in testing to determine responsibilities and agree on procedures during stack testing in order to ensure a satisfactory sampling program and accurate results.
24. Condition 24 is included to ensure that the collection of waste samples required for interpretation of stack sampling results is carried out.

Reporting

25. Condition 25 is included to ensure that the results of sampling and measurements are communicated to the Ministry so that the operation can be assessed and corrective actions initiated as soon as possible if required.



Ministry of
Environment
and Energy

Ministère de
l'Environnement
et de l'Énergie

CERTIFICATE OF APPROVAL
NUMBER 8-1030-94
Page 16 of 1

26. Condition 26 is included to ensure that the results of continuous emission measurements are communicated to the Ministry so that the operation can be assessed and corrective actions initiated as soon as possible if required. The reporting shall be more comprehensive after the installation of a new data logger has been completed.

In accordance with Section 139 of the Environmental Protection Act, R.S.O. 1990 c. E-19, you may by written notice served upon me and the Environmental Appeal Board within 15 days after receipt of this Notice, require a hearing by the Board. Section 142 of the Environmental Protection Act, as amended provides that the Notice requiring the hearing shall state:

1. The portions of the approval or each term or condition in the approval in respect of which the hearing is required; and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

The Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Certificate of Approval number;
6. The date of the Certificate of Approval;
7. The name of the Director;
8. The municipality within which the works are located;

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:

The Secretary,
Environmental Appeal Board,
112 St. Clair Avenue West,
Suite 502,
Toronto, Ontario,
M4V 1N3.

AND

The Director,
Section 9, Environmental Protection Act,
Ministry of the Environment and Energy,
250 Davisville Avenue, 3rd Floor,
Toronto, Ontario,
M4S 1H2.

The above noted works are approved under Section 9 of the Environmental Protection Act.

DATED AT TORONTO this 19th day of April 1994

P. DeAngelis, P. Eng.,
Director,
Section 9,
Environmental Protection Act.

VO/pm
cc MOEE Sarnia District Manager
J. Zend, Science & Technology Branch

SCHEDULE A - POINT OF IMPINGEMENT CONCENTRATIONS

Column 1

Column 2

NAME OF CONTAMINANT

HALF HOUR AVERAGE CONCENTRATION
AT POINT OF IMPINGEMENT

* Concentration is in micrograms per cubic metre of air unless noted otherwise.

** ng/cubic metre = nanograms per cubic metre

Aluminum Oxide	
Arsenic	100
Barium-total water soluble	1
Chromium (Di, Tri and Hexavalent forms)	30
Manganese	5
Molybdenum	7.5
Nickel	100
Phosphorous Pentachloride	5
Potassium Hydroxide	30
Selenium	28
Sodium Hydroxide	20
Silica-respirable (d<10 micron)	20
Strontium	15
Vinyl Chloride	100
Trichlorofluoromethane	3
Trifluorotrichloroethane	18000
Methylene Chloride	240000
Chloroform	5300
1,1,1-Trichloroethane	1500
1,2-Dichloroethane	350000
Perchloroethylene	1200
Isopropyl Benzene (Cumene)	10000
1,2,4-Trimethyl Benzene (Mesitylene)	100
Carbon Tetrachloride	500
1,2,4-Trichlorobenzene	2800
Naphthalene	100
Benzo(a)pyrene	36
Pentachlorophenol	3.3 ng/cubic metre*
Polychlorinated Biphenyls (PCBs)	60
	0.45

Polychlorinated Dibenzodioxins (PCDD's) in pg/cubic metre - see formula
 Polychlorinated Dibenzofurans (PCDF's) in pg/cubic metre - see formula

formula: $(PCDD's/450) + (PCDF's/22500) \leq 1$

SCHEDULE B - MONITORING PARAMETERS

TABLE 1: PCBs and Chlorobenzenes in Stack Samples

Octachlorostyrene
 Hexachlorobenzene
 1,3,5-Trichlorobenzene
 1,2,3-Trichlorobenzene
 1,2,4-Trichlorobenzene
 Hexachlorobutadiene
 2,4,5-Trichlorobenzene
 2,3,6-Trichlorobenzene
 1,2,4,5-Tetrachlorobenzene
 Hexachloroethane
 1,2,3,5-Tetrachlorobenzene
 α ,2,6-Trichlorotoluene
 1,2,3,4-tetrachlorobenzene
 Pentachlorobenzene
 Dichlorobiphenyls
 Trichlorobiphenyls
 Tetrachlorobiphenyls
 Pentachlorobiphenyls
 Hexachlorobiphenyls
 Heptachlorobiphenyls
 Octachlorobiphenyls
 Nonachlorobiphenyls
 Decachlorobiphenyl
 Total PCB congeners

TABLE 2: Polychlorinated Dibenzodioxins and Polychlorinated Furans

T ₁ CDD	T ₁ CDF
P ₃ CDD	P ₃ CDF
H ₆ CDD	H ₆ CDF
H ₇ CDD	H ₇ CDF
O ₁ CDD	O ₁ CDF
2,3,7,8-T ₁ CDD	2,3,7,8-T ₁ CDF
1,2,3,7,8-P ₃ CDD	1,2,3,7,8-P ₃ CDF
1,2,3,4,7,8-H ₆ CDD	2,3,4,7,8-P ₃ CDF
1,2,3,6,7,8-H ₆ CDD	1,2,3,4,7,8-H ₆ CDF
1,2,3,7,8,9-H ₆ CDD	1,2,3,6,7,8-H ₆ CDF
1,2,3,4,6,7,8-H ₇ CDD	1,2,3,7,8,9-H ₆ CDF
	2,3,4,6,7,8-H ₆ CDF
	1,2,3,4,6,7,8-H ₇ CDF
	1,2,3,4,7,8,9-H ₇ CDF

SCHEDULE B - MONITORING PARAMETERS

TABLE 3: Volatile Organics in Stack Samples

Dichlorodifluoromethane
Vinyl Chloride
Bromomethane
Trichlorofluoromethane
1,1-Dichloroethene
Trichlorotrifluoroethane
Methylene chloride
trans-1,2-Dichloroethane
Chloroform
1,1,1-Trichloroethane
1,2-Dichloroethane
Benzene
1,2-Dichloropropane
Trichloroethene
Bromodichloromethane
Toluene
Dibromochloromethane
Ethylene dibromide
Tetrachloroethene
Ethylbenzene
m & p-Xylene
Bromoform
o-Xylene
Cumene
Mesitylene
Acetone
2-Butanone
Carbontetrachloride
Styrene

SCHEDULE B - MONITORING PARAMETERS

TABLE A: PAH's in Stack Samples

Tetralin
Naphthalene
2-Methylnaphthalene
1-Methylnaphthalene
2-Chloronaphthalene
Biphenyl
Acenaphthylene
Acenaphthene
Fluorene
Phenanthrene
Anthracene
2-Methylantracene
o-Terphenyl
1-Methylphenanthrene
9-Methylphenanthrene
Fluoranthrene
Pyrene
9,10-Dimethylantracene
m-Terphenyl
p-Terphenyl
Benzo (a) Fluorene
Benzo (b) Fluorene
Benzo (a) Anthracene
Triphenylene + Chrysene
Perylene
Benzo (b) Fluoranthene
Benzo (k) Fluoranthene
Benzo (e) Pyrene
Benzo (a) Pyrene
3-Methylchloranthrene
Indeno (1,2,3,c,d) Pyrene
Dibenzo (a,c) Anthracene and Dibenzo (a,h) Anthracene
Picene
Benzo (g,h,i) Perylene
Coronene
Benzo (b) Anthracene
Quinoline
Dibenzo (a,e) Pyrene

SCHEDULE B - MONITORING PARAMETERS

TABLE 5: Chlorophenols in Stack Samples

2,3-dichlorophenol
2,4-dichlorophenol
2,6-dichlorophenol
2,3,4-trichlorophenol
2,4,5-trichlorophenol
2,4,6-trichlorophenol
3,4,5-trichlorophenol
2,3,4,6-tetrachlorophenol
2,3,5,6-tetrachlorophenol
Pentachlorophenol

TABLE 6: Inorganics in Stack Samples

Boron
Barium
Calcium
Cadmium
Copper
Iron
Potassium
Magnesium
Manganese
Sodium
Nickel
Phosphorus
Lead
Strontium
Zinc
Chromium
Aluminum
Silicon
Tin
Titanium
Molybdenum
Vanadium
Sulphur
Mercury
Arsenic
Selenium
Antimony
Silver
Beryllium
Cobalt
Fluorides
Lithium

APPENDIX A

1. Application for Certificate of Approval for Plant Modifications at Tricil (Sarnia) Limited, Corunna, Ontario, submitted to the Ontario Ministry of the Environment by Tricil Limited on July 15, 1981.
2. Application for Certificate of Approval for Plant Modifications at Tricil (Sarnia) Limited, Corunna, Ontario, Supplementary Information, submitted to the Ontario Ministry of the Environment by Tricil Limited on July 15, 1981.
3. "Incineration of Intermediate Heat Value Wastes at Tricil (Sarnia) Ltd.", 1987.
4. Air Emission Testing at the Tricil, Sarnia Incinerator, A Draft Report to: Tricil Limited, 189 The Queensway West, Mississauga, Ontario, E.90-43-225 CI, January 30, 1990, Ortech International, 2395 Spearman Drive, Mississauga, Ontario.
5. Application for Certificate of Approval (Air) for the modifications to the incineration feed system received at the Approvals Branch on September 28 1990.
6. A Proposal to Provide Secondary Combustion Air for the L.E.S.L. Lambton Incinerator.
7. Drawing by the M/G Engineering Ltd. of Sarnia, Ontario No. 8881, 3745, 1562.
8. L.E.S.L. - Lambton Facility, S.I.P.S. Process Vent Control System (a three page description of a system).
9. Drawing no. M-21, Site Plan.
10. Drawing no. 20L-PPF-808, Fume Incineration, Piping and Instrumentation Diagram.
11. Drawing by the M/G Engineering Ltd. of Sarnia, Ontario No. 8562.
12. Modifications to Existing Sarnia Tank Farm, Conceptual Scope of Work, January 17, 1991.
13. A proposal to Provide Secondary Combustion Air for the L.E.S.L. Lambton Incinerator.

APPENDIX A 2.

14. Drawing No. DX-03-0-192 dated January 23, 1991, and Drawing No. D-32-2-043 dated February 20, 1991 by Four Nines, Inc.
15. Application letter to Mr. H.O. Wigle dated November 16, 1992 and signed by Mr. Dean C. Edwardson.
16. Application for Certificate of Approval (Air) for the installation of a vent control system (fume incineration) to control emissions from S.I.P.S. plant storage tanks and processing equipment received at the Approvals Branch on December 2, 1991.
17. "Laidlaw Environmental Services Ltd., Lambton Facility, 1993 Stack Test Plan".
18. Application for a Certificate of Approval No. 8-1039-91, dated December 17, 1993, to increase feed rates to the existing unit and to burn wastes with an intermediate heat value (emulsion).
19. Performance Evaluation, Lambton Facility Incineration System, Volume 1, December 1993.



Ontario

Ministry of the Environment
Ministère de l'Environnement

CERTIFICATE OF APPROVAL
WASTE/AIR
NUMBER 6547-5G5MSP

Under the Environmental Protection Act and the regulations and subject to the limitations thereof, this Notice of Amendment (Notice) amends Provisional Certificate of Approval (Waste Disposal Site) No. A031813, dated January 27, 1986 and Notice, dated April 8, 1987 as well as Certificate of Approval (Air) No. 8-1030-94-006, dated April 19, 1994.

Clean Harbors Canada Inc.
4090 Telfer Road
Coruna, ON
N0N 1G0

Located: Lot 9, Concession 10
Township of Moore, County of Lambton

to permit the modification of the facility to incinerate hauled liquid industrial waste in the following manner:

- (a) to add additional auxiliary waste injection ports;
- (b) to provide for the addition of powdered activated carbon in the air pollution control system;
- (c) to add a fume collection and incineration system to the tank farm;
- (d) to increase the amount of secondary air supplied to the furnace; and
- (e) to alter the feed rate limitations for the system.

all in accordance with the applications and supporting information as listed in Schedule "A" which is attached to this Notice of Amendment and forms part of this Notice of Amendment, which includes the use of the Site only for the Transfer/Processing/ Incineration of the following categories of waste:

a facility to incinerate hauled liquid industrial waste class numbers:

111 - 114 inclusive; 121, 122, 123, 131 - 135 inclusive;
141 - 150 inclusive; 211 - 213 inclusive; 221, 222,
231 - 233 inclusive; 241, 242, 251 - 254 inclusive;
261 - 270 inclusive; 281, 282, 311, and 321

This amendment also allows the removal of the baghouse bypass duct work which is no longer required.

You are hereby notified that this amendment is issued subject to the terms and conditions of the original Certificate with the following changes:

1. The company shall ensure that the combined feed of all waste streams does not exceed 245 litres per minute.
2. The Company shall optimize the operation of the Incinerator and the Air Pollution Control System by establishing appropriate waste feed mix scenarios to accommodate the variability of heating values encountered with the types of wastes that may be incinerated. The Company shall also establish an Operating Window for the Incinerator and the Air Pollution Control System, including acceptable ranges for the Baseline Parameters and all set points for the continuously monitored parameters. Such an Operating Window shall be based upon operating experience and shall be refined not later than during the first Source Testing following the issuance of this amendment. The Company shall submit details of the Operating Window to the Director, Manager and the District Manager as part of the Source Testing Report.
3. The Company shall, at all times, operate the Incinerator and the Air Pollution Control Equipment within the Operating Window, unless the Director determines, in consultation with the Manager and the District Manager that the Operating Window will not, based on the source testing results, adequately guarantee compliance with the Act, O. Reg. 346 and the Performance Conditions of this Certificate.

Concentration Limits:

4. The Company shall, at all times, operate the Incinerator and the Air Pollution Control System in such a manner as to ensure that the following Performance Conditions are met:
 - (a) The concentration of organic matter having a carbon content, expressed as equivalent methane, in the Main Stack expressed as a ten minute block average, shall be not more than 100 parts per million by volume on dry basis normalized to 11 percent oxygen.
 - (b) The one hour block average concentration of carbon monoxide in the main stack shall be not more than 100 parts per million by volume on a dry basis normalized to 11 percent oxygen; or 110 milligrams per dry cubic metre normalized to 11 percent oxygen at a reference temperature of 25°C and a reference pressure of 101.3 kilopascals.

- (c) The concentration of suspended particulate matter in the Stack shall be not more than 20 milligrams per dry cubic metre normalized to 11 percent oxygen at a reference temperature of 25°C and a reference pressure of 101.3 kilopascals.
- (d) The opacity at the exit of the Main Stack shall be not more than:
 - (i) 5 percent, calculated on a 2 hour average; and
 - (ii) 10 percent, calculated on a 6 minute average.
- (e)
 - (i) The toxicity equivalent concentration of dioxins and furans in the Gases in the Main Stack shall be not more than 80 picograms per dry cubic metre normalized to 11 percent oxygen at a reference temperature of 25°C and a reference pressure of 101.3 kilopascals.
 - (ii) The toxicity equivalent concentration of dioxins and furans shall be calculated in accordance with the International Scheme set out in Schedule 3 of the Certificate.
- (f) The concentration of mercury in the Gases in the Stack shall be not more than 50 micrograms per dry cubic metre normalized to 11 percent oxygen at a reference temperature of 25°C and a reference pressure of 101.3 kilopascals.

Interpretation:

- 5. (a) The requirements of this Notice are severable. If any requirement of this Notice, or the application of any requirement of this Notice or the application of any requirement of this Notice to any circumstance, is held invalid, the application of such requirement to other circumstances and the remainder of this Notice shall not be affected thereby.
- (b) In all matters requiring the interpretation and implementation of this Notice, the conditions of this Notice shall take precedence, followed in descending order by the chronological approval documents that this Notice amends.

The reasons for the imposition of these conditions are as follows:

- 1. The reason for Condition 1 is to limit the amount of waste that can be fed to the incinerator at any time. This Condition alters the conditions regarding Feed Rate limitations in certificates of approval numbers A031813 and 8-1030-94-006.

2. Conditions 2 and 3 address the need to optimize the operation and develop a plan for continual monitoring of the optimized operation.
3. Conditions 4 set minimum performance requirements considered necessary to prevent an adverse effect resulting from the operation of the Equipment.

In accordance with Section 139 of the Environmental Protection Act, R.S.O. 1990, Chapter E-19, you may by written notice served upon me, the Environmental Appeal Board and the Environmental Commissioner, Environmental Bill of Rights, S.O. 1993, Chapter 28, within 15 days after receipt of this Notice, require a hearing by the Board. Section 142 of the Environmental Protection Act, as amended provides that the Notice requiring a hearing shall state:

1. The portions of the approval or each term or condition in the approval in respect of which the hearing is required, and;
2. The grounds on which you intend to rely at the hearing in relation to each portion appealed.

In addition to these legal requirements, the Notice should also include:

3. The name of the appellant;
4. The address of the appellant;
5. The Certificate of Approval number;
6. The date of the Certificate of Approval;
7. The name of the Director;
8. The municipality within which the waste disposal site is located;

And the Notice should be signed and dated by the appellant.

This Notice must be served upon:


The Secretary,
Environmental Appeal Board,
2300 Yonge St., 12th Fl.,
P.O. Box 2382
Toronto, Ontario
M4P 1E4.

The Environmental Commissioner,
1075 Bay Street,
Suite 608
6th Floor
Toronto, Ontario
M5S 2W5.

The Director,
Sections 9 & 39,
Environmental Protection Act
Ministry of the Environment,
251 Clair Avenue West, Floor 12A
Toronto, Ontario
M4V 1L5

This instrument is subject to Section 38 of the Environmental Bill of Rights, that allows residents of Ontario to seek leave to appeal the decision on this instrument. Residents of Ontario may seek to appeal for 15 days from the date this decision is placed on the Environmental Registry. By accessing the Environmental Registry, you can determine when the leave to appeal period ends.

DATED AT TORONTO this 24th day of January, 2003



Director,
(Section 9 and Section 39.)
Environmental Protection Act

c: District Manager, Samia

SCHEDULE "A"

This Schedule "A" forms part of Certificate (Air and Waste Disposal Site):

1. Application for a Certificate of Approval (Air), for Plant Modifications at Safety Kleen Ltd. Corunna, Ontario submitted to the Ontario Ministry of the Environment by Safety Kleen Ltd. on November 27, 2000 and all supporting documentation.
2. Application for a Certificate of Approval (Air), for Plant Modifications at Safety Kleen Ltd. Corunna, Ontario submitted to the Ontario Ministry of the Environment by Safety Kleen Ltd. on October 31, 2001 and all supporting documentation.
3. Supplemental information on the above Applications for a Certificates of Approval (Air) submitted to the Ontario Ministry of the Environment by Safety Kleen Ltd. on March 1, 2002.
4. "Operating Manual Lambton Incineration System". Chemical Services Division, Clean Harbors Canada Inc. Latest Revision May, 2002
5. "QA/QC Plan for Safety Kleen Lambton Facility" Prepared by CEM Specialties. Draft Revision 1.

APPENDIX 3

**Method 29 Train Field Data Sheets
Incinerator Exhaust Stack
(8 pages)**

ORTECH Consulting Inc.

Plant	Clean Harbors
Plant Location	Corunna, Ontario
Test No.:	1- Mercury
Test Date	August 17 th / 2022
Test Location	Exhaust Stack
Operator Signature	<i>Adam Petrossi</i>

Project No.:	22196
Page	1 of 4
Probe No.:	6 series
Meter Box No.:	Team 1
Impinger Box No.:	9

Pitot Factor	0.845
DGMCF	0.973
Barometric Pressure	29.47 29.4 "Hg
Static Pressure	-0.12 "H2O
Nozzle Size	0.2505 inches
Stack Diameter	4.833 feet
Length	0 feet
Width	0 feet
Port length:	12 inches

Particulate Gain	
Filter	mg
Probe	mg

Moisture Gain	
CWTR	2327.7 g
WCBDA	22.7 g

Combustion Gas Concentration	
Oxygen	9.28 %
Carbon Dioxide	7.72 %
Carbon Monoxide	68.2 ppm

Reading Interval	3
Number of Ports	2
Number of Points/Port	10

Probe Liner Glass Metal/Teflon/Other _____

Nozzle Glass Metal / Other _____

Union None Metal / Teflon / Other _____

Pitot Leak Checked? Yes No

Measuring Device	MI Numbers
Probe / Pitot SA	B03770
Trendicator	COE 20094
Control Box	COE 20094
Incline Manometer	COE 20094
Comb.Gas.Analyzer	
Micromanometer	
Barometer	Env.Can
Calipers	

Nozzle Measurements	
1	0.2510
2	0.2510
3	0.2500
4	0.2500
Average: 0.2505	

Site Diagram

Notes:

Field Data Sheet

Date: Aug. 17th / 22 Plant: Clean Harbors Test No.: 1 - Mercury Page 2 of 4
 Plant Location: Corunna, Ontario Test Location: Exhaust Stack 22196 Exhaust Stack

Point	Clock Time	Dry Gas Meter ft ³	Pitot ΔP "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp		Meter Temp		Meter Pressure ΔH "H ₂ O	Pump Vacuum "Hg Gauge	
								Outlet °F	Inlet/Trap °F	Outlet °F	Inlet °F			
1	0	58.32	1.6	0.69	376	233	249	66	69	77	71	73	41.7	4
	3	60.64	1.2	0.59	377	253	248	51	51	251	73	75	41.7	4
	6	62.89	1.5	0.66	377	253	246	50	50	264	73	75	41.6	4
2	9	64.87	1.5	0.66	378	252	246	51	51	265	72	76	41.6	4
	12	66.90	1.5	0.66	378	252	251	50	50	264	73	74	1.5	4
	15	68.95	1.5	0.66	379	252	248	50	50	262	72	74	1.5	4
3	18	70.99	1.4	0.64	380	252	247	50	50	263	73	75	1.5	4
	21	73.02	1.6	0.68	380	252	248	47	47	258	73	76	1.7	4
	24	75.04	1.5	0.66	380	252	248	44	44	260	73	75	1.6	4
	27	77.10	1.6	0.68	380	252	249	43	43	263	73	75	1.7	4
4	30	79.15	1.6	0.68	379	253	247	43	43	266	72	75	1.7	4
	33	81.25	1.5	0.66	381	253	252	43	43	266	73	77	1.5	4
	36	83.60	1.5	0.66	381	253	252	43	43	269	73	76	1.5	4
	39	85.65	1.5	0.66	382	254	252	44	44	268	73	77	1.3	4
	42	87.64	1.5	0.66	381	253	253	45	45	265	73	76	1.3	4
6	45	89.44	1.5	0.66	382	253	251	45	45	264	73	78	1.5	4
	48	91.49	1.5	0.66	382	252	247	44	44	260	73	75	1.5	4
	51	93.56	1.5	0.66	382	254	247	43	43	263	73	75	1.4	4
7	54	95.57	1.7	0.7	382	253	249	42	42	261	73	75	1.5	4
	57	97.62	1.6	0.66	382	253	246	41	41	260	73	75	1.6	4
	60	99.69	1.5	0.66	381	253	245	41	41	262	73	76	1.4	4

Traverse: 1
 Start Time: 9:25 am Initial Leak Check: 0.002 cfm @ 15 "Hg
 Finish Time: Final Leak Check: cfm @ "Hg
 Traverse: Initial Leak Check: cfm @ "Hg
 Finish Time: Final Leak Check: cfm @ "Hg
 Project No.: 22196
 Operator: Adam Petrofai

Field Data Sheet

Date: Aug. 17th / 22 Plant: Clean Harbors Test No.: 1 - Mercury Page 3 of 4
 Plant Location: Corunna, Ontario Test Location: Exhaust Stack 22196

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp		Meter Temp		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Outlet °F	Inlet/Trap °F	Outlet °F	Inlet °F		
8	63	101.69	1.5	0.66	381	253	248	41	264	73	76	1.4	4
	66	103.69	1.5	0.66	379	253	246	42	265	74	76	1.5	4
	69	105.70	1.6	0.69	379	253	246	42	264	74	76	1.5	4
9	72	107.73	1.5	0.66	379	254	248	41	267	74	76	1.5	4
	75	109.69	1.5	0.66	380	253	249	41	265	74	76	1.5	4
	78	111.82	1.5	0.66	380	253	245	43	266	74	76	1.3	4
10	81	113.79	1.5	0.66	380	254	245	44	266	74	76	1.4	4
	84	115.76	1.5	0.66	381	253	248	44	266	74	76	1.5	4
	87	117.79	1.5	0.66	381	254	245	44	267	74	76	1.4	4
	90	119.87											
1	0	120.0027	1.4	0.64	381	254	252	61	211	75	77	1.6	5
	3	122.49	1.4	0.64	381	253	250	47	212	75	77	1.5	5
	6	124.53	1.5	0.66	382	253	250	45	211	75	77	1.3	4
2	9	126.47	1.6	0.69	382	253	250	45	265	75	77	1.5	4
	12	128.45	1.4	0.64	380	254	250	43	261	75	76	1.6	4
	15	130.55	1.5	0.67	381	254	251	42	211	76	77	1.4	4
3	18	132.55	1.5	0.66	381	254	247	41	211	75	77	1.4	4
	21	134.55	1.6	0.69	379	253	247	42	262	75	77	1.5	4
	24	136.58	1.5	0.67	381	254	251	43	265	75	78	1.6	4
4	27	138.68	1.4	0.64	379	254	252	43	267	75	78	1.4	4

Traverse: Port 4 Initial Leak Check: 0.003 cfm @ 15 "Hg
 Start Time: 10:55 Finish Time: 11:32 a.m.
 Initial Leak Check: 0.003 cfm @ 16 "Hg
 Final Leak Check: 0.003 cfm @ 15 "Hg

Project No.: 22196
 Operator: Adam Petrossi

Field Data Sheet

Date: Aug 17th / 22 Plant: Clean Harbors Test No.: 1-Mercury Page 4 of 4
 Plant Location: Corunna, Ontario Test Location: Exhaust Stack 22196

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp		Meter Temp		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Outlet °F	Inlet/Trap °F	Outlet °F	Inlet °F		
	30	140.70	1.5	0.67	379	254	250	44	266	74	77	1.4	4
	33	142.71	1.5	0.67	379	254	249	44	264	75	78	1.4	4
5	36	144.69	1.5	0.67	379	254	248	43	264	76	79	1.4	4
	39	146.68	1.6	0.69	379	255	251	43	264	75	79	1.45	4
	42	148.71	1.4	0.65	379	254	251	44	264	76	80	1.5	4
6	45	150.78	1.5	0.67	379	254	249	45	264	76	79	1.4	4
	48	152.80	1.8	0.73	379	254	249	46	264	76	80	1.4	4
	51	154.80	1.7	0.71	379	254	250	46	265	76	80	1.7	4
7	54	157.00	1.7	0.71	378	255	251	47	266	76	80	1.6	4
	57	159.18	1.7	0.71	379	254	250	48	266	77	80	1.6	4
	60	161.35	1.7	0.71	379	254	248	51	266	77	81	1.6	4
8	63	163.53	1.7	0.71	377	255	250	49	266	77	81	1.6	4
	66	165.73	1.7	0.71	379	254	250	46	257	77	80	1.6	4
	69	167.80	1.7	0.71	378	254	247	44	259	77	81	1.6	4
9	72	169.97	1.7	0.71	378	254	247	44	261	78	81	1.6	4
	75	172.01	1.7	0.71	379	253	247	43	262	77	81	1.7	4
	78	174.19	1.6	0.69	379	255	248	45	266	77	80	1.6	4
10	81	176.33	1.7	0.71	377	254	247	45	264	78	80	1.5	4
	84	178.43	1.6	0.69	378	255	250	47	260	78	80	1.6	4
	87	180.55	1.6	0.69	377	254	249	43	263	78	81	1.6	4
	90	182.67											

Traverse: 2
 Start Time: 1:03 PM Initial Leak Check: cfm @ 15 "Hg
 Finish Time: 1:03 PM Final Leak Check: cfm @ 15 "Hg

Traverse: Initial Leak Check: cfm @ "Hg
 Start Time: Finish Time: Final Leak Check: cfm @ "Hg

Project No.: 22196
 Operator: Adam Petrossi

ORTECH Consulting Inc.

Plant	Clean Harbors
Plant Location	Corunna, Ontario
Test No.:	2 - Mercury
Test Date	August 17 th / 2022
Test Location	Exhaust Stack
Operator Signature	Adam Petross

Project No.:	22196
Page	1 of 4
Probe No.:	6 Series
Meter Box No.:	Team 1
Impinger Box No.:	9

Pitot Factor	0.845
DGMCf	0.973
Barometric Pressure	29.53 "Hg
Static Pressure	29.44 - 0.12 "H2O
Nozzle Size	0.2505 inches
Stack Diameter	4.833 feet (58")
Length	0 feet
Width	0 feet
Port length:	12 inches

Particulate Gain	
Filter	mg
Probe	mg

Moisture Gain	
CWTR	2310.1 g
WCBDA	25.2 g

Combustion Gas Concentration	
Oxygen	9.30 %
Carbon Dioxide	7.63 %
Carbon Monoxide	61.2 ppm

Reading Interval	3
Number of Ports	2
Number of Points/Port	10

Probe Liner Glass / Metal / Teflon / Other _____

Nozzle Glass / Metal / Other _____

Union None / Metal / Teflon / Other _____

Pitot Leak Checked? Yes No

Measuring Device	MII Numbers
Probe / Pitot	
Trendicator	
Control Box	
Incline Manometer	
Comb.Gas.Analyzer	
Micromanometer	
Barometer	Env.Can
Calipers	

Nozzle Measurements	
1	0.2510
2	0.2510
3	0.2500
4	0.2500
Average: 0.2505	

Site Diagram

Notes: _____

Field Data Sheet

Date: Aug. 17/22 Plant: Clean Harbors Test No.: 2 - Mercury Page 2 of 4
 Plant Location: Corunna, Ontario Test Location: Exhaust Stack 22196

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp		Meter Temp		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Outlet °F	Inlet/Trap °F	Outlet °F	Inlet °F		
1	0	183.20	1.3	0.62	380	254	196	62	78	76	78	1.4	3
	3	185.30	1.4	0.64	385	251	220	54	167	76	77	1.3	3
	6	187.18	1.5	0.66	384	252	244	50	193	75	76	1.4	3
2	9	189.18	1.5	0.66	383	252	245	49	201	75	76	1.4	3
	12	191.18	1.5	0.66	384	253	247	47	207	75	76	1.4	3
	15	193.17	1.5	0.66	383	252	247	46	215	75	76	1.4	3
3	18	195.14	1.5	0.66	383	252	248	44	124	75	76	1.45	3
	21	197.15	1.5	0.66	383	252	245	41	114	75	76	1.4	3
	24	199.13	1.5	0.66	383	252	244	39	132	75	77	1.45	3
4	27	201.15	1.5	0.66	382	252	250	37	46	75	76	1.45	3
	30	203.16	1.5	0.66	383	253	252	37	54	75	77	1.4	3
	33	205.18	1.7	0.71	382	253	248	38	137	75	77	1.4	3
5	36	207.26	1.5	0.66	383	253	252	40	159	75	77	1.5	3
	39	209.14	1.5	0.66	382	253	245	41	128	75	77	1.6	3
	42	211.30	1.5	0.66	380	252	250	39	139	75	77	1.45	3
6	45	213.35	1.5	0.66	383	253	249	38	122	75	78	1.45	3
	48	215.39	1.4	0.64	383	253	246	37	97	75	77	1.4	3
	51	217.41	1.85	0.74	383	252	249	38	135	76	78	1.7	3
	54	219.55	1.75	0.72	384	253	249	39	98	76	79	1.5	3
	57	221.60	2.0	0.77	383	253	247	39	205	75	78	1.8	3
	60	223.81	1.75	0.72	384	252	248	38	215	75	78	1.85	4

Traverse: 1 Initial Leak Check: 0.004 cfm @ 17 "Hg
 Start Time: 1:53 PM Final Leak Check: cfm @ "Hg
 Finish Time: Initial Leak Check: cfm @ "Hg
 Final Leak Check: cfm @ "Hg

Project No.: 22196
 Operator: Adam Plossi

Field Data Sheet

Date: Aug. 17/22 Plant: Clean Harbors Test No.: 2 - Mercury Page 3 of 4
 Plant Location: Corunna, Ontario Test Location: Exhaust Stack 22196

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp		Meter Temp		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Outlet °F	Inlet/Trap °F	Outlet °F	Inlet °F		
8	63	226.06	1.7	0.71	384	252	249	38	215	75	78	1.75	4.0
	66	228.30	1.75	0.72	384	253	248	39	211	75	78	1.6	4.0
	69	230.48	1.85	0.74	382	252	248	38	212	76	78	1.65	4.0
9	72	232.66	1.75	0.72	386	253	254	37	240	76	78	1.7	4.0
	75	234.84	1.8	0.73	384	252	246	37	242	76	78	1.7	4.0
	78	237.05	1.75	0.72	381	252	245	38	240	76	78	1.7	4.0
10	81	239.23	1.75	0.72	381	252	246	40	242	76	78	1.7	4.0
	84	241.42	1.7	0.71	379	252	249	41	243	76	78	1.7	4.0
	87	243.58	1.7	0.71	382	252	250	41	197	76	78	1.65	4.0
	90	245.80											
1	0	246.34	1.65	0.70	365	251	245	66	97	76	78	1.4	3.5
	3	248.44	1.65	0.70	367	250	238	49	213	76	76	1.45	3.5
	6	250.46	1.65	0.70	367	250	253	46	214	76	76	1.55	4.0
2	9	252.54	1.45	0.66	367	250	286	46	214	76	76	1.55	4.0
	12	254.63	1.5	0.67	369	250	246	46	205	76	76	1.4	4.0
	15	256.63	1.4	0.64	371	249	265	47	213	76	76	1.45	4.0
3	18	258.67	1.45	0.65	371	250	261	48	213	76	76	1.4	4.0
	21	260.66	1.45	0.65	375	251	250	47	214	75	76	1.4	4.0
	24	262.64	1.45	0.66	375	251	242	47	214	75	77	1.4	4.0
4	27	264.61	1.45	0.65	377	251	250	50	214	75	77	1.45	4.0

Traverse: 2 Initial Leak Check: 0.002 "Hg cfm @ 18 "Hg
 Start Time: 15:58 Final Leak Check: 0.003 "Hg cfm @ 17 "Hg
 Finish Time: 3:23 PM

Project No.: 22196
 Operator: Adam Petrossi

APPENDIX 4

**Method 29 Train Recovery Data Sheets
(5 pages)**

Method 29 (modified)
Particulate and Mercury Train Recovery Data Sheet

Client: Clean Harbors

Project No.: 22196

Date: Aug 17/22

Test No.: 1

Test Location: STACK

Nozzle, Probe Liner
Cyclone Bypass & F.H.
Filter Housing

CONTAINER TS1
Empty Wt: 280.0
After Act. Rinse: 476.9

MARK FLUID LEVEL

SEAL AND LABEL TS1

CONTAINER TS2
Empty Wt: 280.0
After 0.1N HNO₃ Rinse: 510.1

MARK FLUID LEVEL

SEAL AND LABEL TS2

Quartz Fibre Filter

Filter ID: 028075

Initial Wt:
Final Wt:
Gain:
Colour: LIGHT BEIGE

SEAL CONTAINER TS3

Impingers 1 - 6

Impinger #1 50mL of KMnO₄/H₂SO₄
Empty Wt: 654.2
Initial Wt: 718.1
Final Wt: 878.0
Gain: 159.9
Colour: CLEAR

Impinger #2 Knockout w/ 100mL of KMnO₄/H₂SO₄
Empty Wt: 726.1
Initial Wt: 833.9
Final Wt: 2625.6
Gain: 1791.7
Colour: CLEAR

Impinger #3 50 mL of KMnO₄/H₂SO₄
Empty Wt: 577.5
Initial Wt: 631.3
Final Wt: 971.0
Gain: 285.5
Colour: BLACK

Impinger #4 100ml of KMnO₄/H₂SO₄
Empty Wt: 443.8
Initial Wt: 761.1
Final Wt: 822.3
Gain: 61.2
Colour: PURPLE

Impinger #5 100mL of KMnO₄/H₂SO₄
Empty Wt: 572.8
Initial Wt: 760.9
Final Wt: 768.2
Gain: 7.3
Colour: PURPLE

Impinger #6 Empty
Empty Wt: 594.7
Final Wt: 596.8
Gain: 2.1
Colour: -

Impingers Recovery and Rinse

CONTAINER TS4-A
Empty Wt: 1356.0
With Imp. 1-6 Soln: 4099.9
After KMnO₄ Rinse: 4224.8
After D.I. Water Rinse: 4513.0

MARK FLUID LEVEL

SEAL & LABEL TS4-A

CONTAINER TS4-B
Empty Wt: 455.0
With 150 mL DI Water: 557.0
HCl Rinse of imp. 1-6: 699.8
After D.I. Water Rinse: 831.2

MARK FLUID LEVEL

SEAL & LABEL TS4-B

Impinger 7

Impinger #7 Silica Gel
Initial Wt: 993.1
Final Wt: 1015.8
Gain: 22.7

Sample Identification:
TS1 (Probe Rinse-Acetone)
TS2 (Probe Rinse-0.1N HNO ₃)
TS3 (Filter)
TS4-A (Impinger 1-6 Sol'n-KMnO ₄)
TS4-B (Impinger 1-6 Rinse-HCl)

TS1, TS2- Amber Glass Bottle
TS3- Petri Dish
TS4- Amber Glass Bottle

CWTR = 1+2+3+4+5+6: 2327.7

WCBD A= 7: 22.7

Train Loaded By: [Signature]
Train Recovered By: [Signature]
Recovery Witnessed By: [Signature]

Method 29 (modified)
Particulate and Mercury Train Recovery Data Sheet

Client: Clean Harbors

Project No.: 22196

Date: AUG 17/22

Test No.: 72

Test Location: STACKS

Nozzle, Probe Liner
Cyclone Bypass & F.H.
Filter Housing

Quartz Fibre Filter
Filter ID: Q79803

Impingers 1 - 6

Impingers Recovery and Rinse

Impinger 7

CONTAINER TS1
Empty Wt: 280.0
After Act. Rinse: 445.7
MARK FLUID LEVEL
SEAL AND LABEL TS1

Initial Wt:
Final Wt:
Gain: BEICE
Colour: BEICE
SEAL CONTAINER TS3

Impinger #1 50mL of $KMnO_4/H_2SO_4$
Empty Wt: 527.5
Initial Wt: 606.7
Final Wt: 834.3
Gain: 227.8
Colour: clear

CONTAINER TS4-A
Empty Wt: 1300.5
With Imp. 1-6 Soln: 4087.7
After $KMnO_4$ Rinse: 4220.3
After D.I. Water Rinse: 4620.3

Impinger #7 Silica Gel
Initial Wt: 936.1
Final Wt: 961.3
Gain: 25.2

Impinger #2 Knockout w/ 100mL of $KMnO_4/H_2SO_4$
Empty Wt: 772.1
Initial Wt: 863.1
Final Wt: 2743.1
Gain: 1880.0
Colour:

MARK FLUID LEVEL
SEAL & LABEL TS4-A

CONTAINER TS2
Empty Wt: 280.0
After 0.1N HNO_3 Rinse: 503.6
MARK FLUID LEVEL
SEAL AND LABEL TS2

Impinger #3 50 mL of $KMnO_4/H_2SO_4$
Empty Wt: 645.4
Initial Wt: 696.0
Final Wt: 858.6
Gain: 162.6
Colour:

CONTAINER TS4-B
Empty Wt: 40.9
With 150 mL DI Water: 658.5
HCl Rinse of imp. 1-6: 770.9
After D.I. Water Rinse: 896.2

Impinger #4 100ml of $KMnO_4/H_2SO_4$
Empty Wt: 674.8
Initial Wt: 786.5
Final Wt: 870.8
Gain: 24.3
Colour:

MARK FLUID LEVEL
SEAL & LABEL TS4-B

Sample Identification:
TS1 (Probe Rinse-Acetone)
TS2 (Probe Rinse-0.1N HNO_3)
TS3 (Filter)
TS4-A (Impinger 1-6 Sol'n- $KMnO_4$)
TS4-B (Impinger 1-6 Rinse-HCl)

Impinger #5 100mL of $KMnO_4/H_2SO_4$
Empty Wt: 650.5
Initial Wt: 766.4
Final Wt: 774.5
Gain: 24.1
Colour:

MARK FLUID LEVEL
SEAL & LABEL TS4-B

TS1, TS2- Amber Glass Bottle
TS3- Petri Dish
TS4- Amber Glass Bottle

CWTR = 1+2+3+4+5+6+7 310.1

WCDDA=7: 25.2

Train Loaded By: DK
Train Recovered By: DK
Recovery Witnessed By:

Method 29 (modified)
 Particulate and Mercury Train Recovery Data Sheet

Test No.: 1
 Test Location: INLET

Client: Clean Harbors
 Project No.: 22196
 Date: Aug-17-12

Nozzle, Probe Liner
 Cyclone Bypass & F.H.
 Filter Housing

Quartz Fibre Filter
 Filter ID: Q28807

Impingers 1 - 6

Impingers Recovery and Rinse

Impinger 7

CONTAINER TS1
 Empty Wt: 275.0
 After Act. Rinse: 520.0
 MARK FLUID LEVEL
 SEAL AND LABEL TS1

Initial Wt:
 Final Wt:
 Gain:
 Colour: PURPLE/PAN
 SEAL CONTAINER TS3

Impinger #1 50ml of $KMnO_4/H_2SO_4$
 Empty Wt: 650.6
 Initial Wt: 753.4
 Final Wt: 766.9
 Gain: 13.5
 Colour: PURPLE

CONTAINER TS4-A
 Empty Wt: 404.7
 With Imp. 1-6 Soln: 975.6
 After $KMnO_4$ Rinse: 110.8
 After D.I. Water Rinse: 1210.8
 MARK FLUID LEVEL
 SEAL & LABEL TS4-A

Impinger #7 Silica Gel
 Initial Wt: 1003.8
 Final Wt: 1007.3
 Gain: 3.5

CONTAINER TS2
 Empty Wt: 275.0
 After 0.1N HNO_3 Rinse: 550
 MARK FLUID LEVEL
 SEAL AND LABEL TS2

Impinger #2 Knockout w/ 100ml of $KMnO_4/H_2SO_4$
 Empty Wt: 767.9
 Initial Wt: 800.9
 Final Wt: 1161.2
 Gain: 270.3
 Colour: PURPLE

CONTAINER TS4-B
 Empty Wt: 480.0
 With 150 ml DI Water: 980.0
 HCl Rinse of imp. 1-6: 725.0
 After D.I. Water Rinse: 851
 MARK FLUID LEVEL
 SEAL & LABEL TS4-B

Impinger #3 50 ml of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

MARK FLUID LEVEL
 SEAL & LABEL TS4-B

Sample Identification:
 TS1 (Probe Rinse-Acetone) 11
 TS2 (Probe Rinse-0.1N HNO_3) 12
 TS3 (Filter) 13
 TS4-A (Impinger 1-6 Sol'n- $KMnO_4$) 14
 TS4-B (Impinger 1-6 Rinse-HCl) 15

Impinger #4 100ml of $KMnO_4/H_2SO_4$
 Empty Wt: 650.3
 Initial Wt: 753.9
 Final Wt: 783.0
 Gain: 49.9
 Colour: PURPLE

MARK FLUID LEVEL
 SEAL & LABEL TS4-B

Impinger #5 100ml of $KMnO_4/H_2SO_4$
 Empty Wt: 669.8
 Initial Wt: 790.5
 Final Wt: 777.2
 Gain: -82.3
 Colour: PURPLE

MARK FLUID LEVEL
 SEAL & LABEL TS4-B

Impinger #6 Empty
 Empty Wt:
 Final Wt:
 Gain:
 Colour:

TS1, TS2- Amber Glass Bottle
 TS3- Petri Dish
 TS4- Amber Glass Bottle

CWTR = 1+2+3+4+5+6: 151.6
 WCBDA = 7: 3.5

16

Train Loaded By: [Signature]
 Train Recovered By: [Signature]
 Recovery Witnessed By:

Method 29 (modified)
Particulate and Mercury Train Recovery Data Sheet

Client: Clean Harbors

Project No.: 22196

Date: AUG 17/22

Test No.: 2

Test Location: INLET

Nozzle, Probe Liner
Cyclone Bypass & F.H.
Filter Housing

Quartz Fibre Filter
Filter ID: 028801

Impingers 1 - 6

Impingers Recovery and Rinse

Impinger 7

CONTAINER TS1
Empty Wt: 285.0
After Act. Rinse:
MARK FLUID LEVEL
SEAL AND LABEL TS1

Initial Wt:
Final Wt:
Gain:
Colour: BEIGE
SEAL CONTAINER TS3

Impinger #1 50ml of $KMnO_4/H_2SO_4$
Empty Wt: 652.9
Initial Wt: 777.7
Final Wt: 848.4
Gain: 75.7
Colour: PURPLE

CONTAINER TS4-A
Empty Wt: 410.0
With Imp. 1-6 Sol'n: 1061.5
After $KMnO_4$ Rinse: 1197.5
After D.I. Water Rinse: 1430.9
MARK FLUID LEVEL
SEAL & LABEL TS4-A

Impinger #7 Silica Gel
Initial Wt: 1006.5
Final Wt: 1011.0
Gain: 4.5

CONTAINER TS2
Empty Wt: 285.0
After 0.1N HNO_3 Rinse:
MARK FLUID LEVEL
SEAL AND LABEL TS2

Impinger #2 Knockout w/ 100ml of $KMnO_4/H_2SO_4$
Empty Wt: 784.4
Initial Wt: 910.4
Final Wt: 932.8
Gain: 22.4
Colour: PURPLE

CONTAINER TS4-B
Empty Wt: 410.0
With 150 ml DI Water: 560.0
HCl Rinse of imp. 1-6: 652.4
After D.I. Water Rinse: 856.0
MARK FLUID LEVEL
SEAL & LABEL TS4-B

Impinger #3 50 ml of $KMnO_4/H_2SO_4$
Empty Wt:
Initial Wt:
Final Wt:
Gain:
Colour:

MARK FLUID LEVEL
SEAL & LABEL TS4-B

Sample Identification:	
TS1 (Probe Rinse-Acetone)	<u>16</u>
TS2 (Probe Rinse-0.1N HNO_3)	<u>17</u>
TS3 (Filter)	<u>18</u>
TS4-A (Impinger 1-6 Sol'n- $KMnO_4$)	<u>19</u>
TS4-B (Impinger 1-6 Rinse-HCl)	<u>20</u>

Impinger #4 100ml of $KMnO_4/H_2SO_4$
Empty Wt: 653.0
Initial Wt: 761.4
Final Wt: 839.5
Gain: 39.5
Colour: PURPLE

MARK FLUID LEVEL
SEAL & LABEL TS4-B

Impinger #5 100ml of $KMnO_4/H_2SO_4$
Empty Wt: 672.1
Initial Wt: 791.7
Final Wt: 913.5
Gain: 121.8
Colour: PURPLE

MARK FLUID LEVEL
SEAL & LABEL TS4-B

Impinger #6 Empty
Empty Wt:
Final Wt:
Gain:
Colour:

MARK FLUID LEVEL
SEAL & LABEL TS4-B

16

TS1, TS2- Amber Glass Bottle
TS3- Petri Dish
TS4- Amber Glass Bottle

CWTR = 1+2+3+4+5+6: 180.7

WCBD=7: 4.5

Train Loaded By: RAM
Train Recovered By: RAM
Recovery Witnessed By:

**Method 29 (modified)
Particulate and Mercury Train Recovery Data Sheet**

Client: Clean Harbors
 Project No.: 22196
 Date: AUG 17/22

Test No.: BLANK
 Test Location: _____

Nozzle, Probe Liner
 Cyclone Bypass & F.H.
 Filter Housing

Quartz Fibre Filter
 Filter ID: Q28799

Impingers 1 - 6

Impingers Recovery and Rinse

Impinger 7

CONTAINER TS1
 Empty Wt: 2850
 After Act. Rinse: 559.4
 MARK FLUID LEVEL
 SEAL AND LABEL TS1

Initial Wt:
 Final Wt:
 Gain:
 Colour:
 SEAL CONTAINER TS3

Impinger #1 50mL of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

CONTAINER TS4-A
 Empty Wt: 405.0
 With Imp. 1-6 Sol'n: 617.0
 After $KMnO_4$ Rinse: 577.0
 After D.I. Water Rinse: 981.8
 MARK FLUID LEVEL
 SEAL & LABEL TS4-A

Impinger #7 Silica Gel
 Initial Wt:
 Final Wt:
 Gain:
 7

CONTAINER TS2
 Empty Wt: 2850
 After 0.1N HNO_3 Rinse: 571.6
 MARK FLUID LEVEL
 SEAL AND LABEL TS2

Initial Wt:
 Final Wt:
 Gain:
 Colour:

Impinger #2 Knockout w/ 100mL of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

CONTAINER TS4-B
 Empty Wt: 405.0
 With 150 mL DI Water: 625.0
 HCl Rinse of imp. 1-6: 828.7
 After D.I. Water Rinse:
 MARK FLUID LEVEL
 SEAL & LABEL TS4-B

MARK FLUID LEVEL
 SEAL AND LABEL TS2

Initial Wt:
 Final Wt:
 Gain:
 Colour:

Impinger #3 50 mL of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

Sample Identification:
 TS1 (Probe Rinse-Acetone) 21
 TS2 (Probe Rinse-0.1N HNO_3) 22
 TS3 (Filter) 23
 TS4-A (Impinger 1-6 Sol'n- $KMnO_4$) 24
 TS4-B (Impinger 1-6 Rinse-HCl) 25

Impinger #4 100mL of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

Impinger #5 100mL of $KMnO_4/H_2SO_4$
 Empty Wt:
 Initial Wt:
 Final Wt:
 Gain:
 Colour:

Impinger #6 Empty
 Empty Wt:
 Final Wt:
 Gain:
 Colour:

TS1, TS2- Amber Glass Bottle
 TS3- Petri Dish
 TS4- Amber Glass Bottle

CWTR = 1+2+3+4+5+6: _____

WCBD A = 7: _____

Train Loaded By: _____
 Train Recovered By: _____
 Recovery Witnessed By: _____

APPENDIX 5

**Method 29 Analytical Reports
(7 pages)**



1435 Norjohn Court, Unit 1, Burlington ON, L7L 0E6
Phone: 905-331-3111, FAX: 905-331-4567

Certificate of Analysis

ALS Project Contact: Lynne Wrona
ALS Project ID: ORT100
ALS WO#: L2729215
Date of Report: 31-Aug-22
Date of Sample Receipt: 18-Aug-22

Client Name: ORTECH Environmental
Client Address: 804 Southdown Road
Mississauga, ON L5J 2Y4
Canada
Client Contact: Chris Belore
Client Project ID: 22196 Clean Harbors

COMMENTS:

Sample Particulate Analysis via Gravimetric USEPA Method 5 (LL5 30-AUG-2022)

REPORT FLAGS:

J - The value is uncertain and below what can be reliably identified as positive with a ≥99% confidence limit (i.e. below the laboratory determined MDL).

LCB = Laboratory Control Blank
CVS = Continuing Verification Standard Sample (limits: ±2 in the last decimal)
LOR = Limit of Reporting

Certified by: *L. Wrona*
Lynne Wrona
Project Manager

Results in this certificate relate only to the samples as submitted to the laboratory.
This report shall not be reproduced, except in full, without the written permission of ALS Canada Ltd.

ALS Environmental

Sample Analysis Summary Report

Sample Name	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(6 THRU 10) TEST#2	22-22196-PM-(11 THRU 15) TEST#1	22-22196-PM-(16 THRU 20) TEST#2	22-22196-PM-(21 THRU 25) BLANK	
ALS Sample ID	L2729215-1	L2729215-2	L2729215-3	L2729215-4	L2729215-5	
Matrix	Stack	Stack	Stack	Stack	Stack	
Analysis type	Sample	Sample	Sample	Sample	Sample	
Sampling Date/Time	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	
Date of Receipt	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	
PM via Gravimetric Analysis						
Method 5	LOR	mg	mg	mg	mg	mg
Filter Particulate Matter	0.8	1.5	5.1	1220	1400	0.8
Acetone Particulate Matter	0.4	14.0	10.3	896	1110	0.1 J
Acetone Mass	g	g	g	g	g	g
	0.02	189	160	241	274	312

ALS Environmental

Sample Analysis Summary Report

Sample Name	MB		
ALS Sample ID	L2729215-MB		
Matrix	n/a		
Analysis type	Sample		
Sampling Date/Time	n/a		
Date of Receipt	n/a		
PM via Gravimetric Analysis			
	LOR		
Method 5	mg	mg	
Filter Particulate Matter	0.8	<0.1	
Acetone Particulate Matter	0.4	0.1	J
	g	g	
Acetone Mass	0.02	31.4	



1435 Norjohn Court, Unit 1, Burlington ON, L7L 0E6
Phone: 905-331-3111, FAX: 905-331-4567

Certificate of Analysis

ALS Project Contact: Lynne Wrona
ALS Project ID: ORT100
ALS WO#: L2729215
Date of Report: 6-Sep-22
Date of Sample Receipt: 18-Aug-22

Client Name: Ortech Environmental
Client Address: 804 Southdown Road
Mississauga, ON L5J 2Y4
Canada
Client Contact: Chris Belore
Client Project ID: 22196 Clean Harbors

COMMENTS:

Sample Preparation via USEPA Method 29 (LL5 01-Sep-2022)
Mercury Analysis via CVAA using Method USEPA 7470A (KC11 24-Aug-2022, 06-Sep-2022)

LOR = Limit of Reporting
LCB = Laboratory Control Blank (limits: <LOR)
LCS = Laboratory Control Sample (limits: hivol, solids: 85-115%, stack: 90-110%)
MS = Matrix Spike Sample (limits: 75-125%)
RPD = Relative Percent Difference (limits: <20%)
CCV/CVS = Calibration Verification Standard (limits: 85-115%)

Certified by: *L. Wrona*
Lynne Wrona
Project Manager

Results in this certificate relate only to the samples as submitted to the laboratory.
This report shall not be reproduced, except in full, without the written permission of ALS Canada Ltd.

ALS Environmental

Sample Analysis Summary Report

Sample Name	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(6 THRU 10) TEST#2	22-22196-PM-(11 THRU 15) TEST#1	22-22196-PM-(16 THRU 20) TEST#2	22-22196-PM-(21 THRU 25) BLANK
ALS Sample ID	L2729215-1	L2729215-2	L2729215-3	L2729215-4	L2729215-5
Matrix	Stack	Stack	Stack	Stack	Stack
Analysis type	Sample	Sample	Sample	Sample	Sample
Sampling Date/Time	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22
Date of Receipt	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22
Mercury via CVAA	LOR				
	Method 29	ug	ug	ug	ug
Analytical Fraction 1B	0.015	0.150	0.200	7.92	7.80
Analytical Fraction 3B	0.025	7.84	6.39	0.283	10.7
Analytical Fraction 3C	0.25	<0.3	<0.3	26.3	31.3
					<0.15
					<0.05
					<0.3

ALS Environmental

Sample QC Summary Report

Sample Name	LCB	LCS	LCS	LCSD	LCSD
ALS Sample ID	LCB	LCS	LCS	LCSD	LCSD
Analysis type	Method Blank	Blank Spike	Blank Spike	Blank Spike Dup	Blank Spike Dup
Sampling Date/Time	N/A	N/A	N/A	N/A	N/A
Date of Receipt	N/A	N/A	N/A	N/A	N/A

Mercury via CVAA	Method 29	LOR ug	ug	ug	% Rec	ug	% Rec
Analytical Fraction 1B	0.015	<0.015		0.290	97%	0.291	97%
Analytical Fraction 3B	0.025	<0.025		0.471	94%	0.475	95%
Analytical Fraction 3C	0.25	<0.25		4.89	97%	4.83	96%

ALS Environmental

Sample QC Summary Report

Sample Name	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(1 THRU 5) TEST#1	22-22196-PM-(1 THRU 5) TEST#1
ALS Sample ID	L2729215-1	L2729215-1DUP	L2729215-1MS	L2729215-1MS	L2729215-1MSD	L2729215-1MSD
Matrix	Stack	Stack	Stack	Stack	Stack	Stack
Analysis type	Sample	Duplicate	Matrix Spike	Matrix Spike	Matrix Spike Dup	Matrix Spike Dup
Sampling Date/Time	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22
Date of Receipt	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22
Mercury via CVAA						
	Method 29	LOR				
		ug	ug	ug	% Rec	ug
						% Rec
Analytical Fraction 1B	0.015	0.150	0.151	0.447	99%	0.441
Analytical Fraction 3B	0.025	7.84	7.75	10.9	97%	10.8
Analytical Fraction 3C	0.250	<0.3	<0.3	5.86	96%	5.88

APPENDIX 6

**Method 30B Train Field Data Sheets
Incinerator Exhaust Stack
(7 pages)**

**Clean Harbors, Sarnia
Mercury Tube Sampling Train
Sample Volume Corrections**

Incinerator Exhaust Stack

Test # - Tube (tube pair field ID)	DGMCF	Initial DGM Reading (L)	Final DGM Reading (L)	Actual Vol. Sampled (L)	Barometric Pressure (in Hg)	Average DGM Pressure del H (in H ₂ O)	Average DGM Temperature (°C)	Corrected Volume (L)*	Corrected Volume (Rm ³)*
T1A OL663187	0.988	48.30	108.50	60.20	29.48	0.5	33.6	57.03	0.0570
T1B OL618359 (Spiked)	1.018	28.40	91.70	63.30	29.48	2.5	29.4	62.96	0.0630
T2A OL528943 (Spiked)	0.988	12.00	73.90	61.90	29.48	0.5	38.3	57.76	0.0578
T2B OL663163	1.018	92.20	158.30	66.10	29.48	2.5	31.2	65.35	0.0654
T3A OL663165	0.988	74.50	135.50	61.00	29.47	0.5	39.2	56.73	0.0567
T3B OL568842 (Spiked)	1.018	59.00	115.00	56.00	29.47	2.3	31.1	55.34	0.0553
T4A OL610673 (Spiked)	0.988	37.70	98.00	60.30	29.44	0.5	38.8	56.10	0.0561
T4B OL663238	0.992	15.50	80.00	64.50	29.44	1.8	35.3	61.13	0.0611
T5A OL624083	0.988	98.70	162.30	63.60	29.43	0.5	39.1	59.09	0.0591
T5B OL620071 (Spiked)	0.992	81.00	146.60	65.60	29.43	1.8	34.8	62.25	0.0623
T6A OL610641 (Spiked)	0.988	73.20	133.80	60.60	29.42	0.5	35.5	56.94	0.0569
T6B OL624086	0.992	49.00	113.80	64.80	29.42	1.8	32.9	61.85	0.0619

* dry at 25°C and 1 atmosphere

ORTECH
Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	1

Test location:	STACK
Date:	AUG 17 / 22
Project No.:	22196

Train A

Tube Identification:	06663187	Spiked	Yes (No)
Spike Concentration		ng	

Measuring Device	MII
Control Module	10173 A12010
Barometer	ENV. CAN.

Barometric Pressure	29.78
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	49.3	32	.5	6.7
5	53.5	34	.5	7
10	59.4	34	.5	
15	63.4	33	.5	
20	68.4	32	.5	
25	73.4	32	.5	
30	78.4	33	.5	
35	83.2	33	.5	
40	87.8	34	.5	
45	92.8	34	.5	
50	97.9	36	.5	
55	103.1	36	.5	
60	108.5	34	.5	

Start Time:	09:27	Initial Leak Check	0.05 LPM@ 17 "Hg	DGMCF:	.988
Finish Time:	10:27	Final Leak Check	LPM@ "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Train B

Tube Identification:	06618359	Spiked	Yes (No)
Spike Concentration	150	ng	

Measuring Device	10172	MII
Control Module	A1017	

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	28.4	27	2.5	5
5	33.7	29	2.5	5
10	38.9	29	2.5	6
15	44.1	29	2.5	6
20	49.5	28	2.5	6
25	54.7	29	2.5	6
30	60.0	29	2.5	6
35	65.3	30	2.5	6
40	70.6	30	2.5	6
45	75.8	30	2.5	6
50	81.2	31	2.5	6
55	86.4	30	2.5	6
60	91.7	30	2.5	6

Start Time:	08:27	Initial Leak Check	0.05 LPM@ 11 "Hg	DGMCF:	1.018
Finish Time:	10:27	Final Leak Check	LPM@ "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	
Operator: D. TURTON					

ORTECH Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	2

Test location:	STACK
Date:	4/6/17/22
Project No.:	22196

Train A

Tube Identification:	02528943	Spiked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Spike Concentration	290	ng	

Measuring Device	MII
Control Module	V3 A12010
Barometer	ENV. CAN.

Barometric Pressure	29.48
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	12.0	33	.5	7
5	17.8	37	.5	7
10	23.6	37	.5	7
15	28.6	38	.5	7
20	33.4	37	.5	7.5
25	39.8	38	.5	7.5
30	47.7	40	.5	8
35	48.7	40.38	.5	8
40	53.7	38	.5	8
45	58.6	40	.5	8
50	63.8	40	.5	8
55	68.8	41	.5	8
60	73.9	41	.5	8

Start Time:	10:47	Initial Leak Check	.05 LPM@ 15 "Hg	DGMCF:	.988
Finish Time:	11:47	Final Leak Check	.05 LPM@ 15 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	.5

Train B

Tube Identification:	0663163	Spiked	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Spike Concentration		ng	

Measuring Device	MII
Control Module	V2 A10117

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	92.2	29	2.5	5
5	98.0	31	2.5	5
10	103.7	31	2.5	5
15	108.7	31	2.5	5
20	113.6	31	2.5	5
25	118.4	31	2.5	5
30	123.1	32	2.5	5
35	129.4	31	2.5	5
40	135.3	31	2.5	5
45	141.4	31	2.5	5
50	147.1	33	2.5	5
55	152.7	32	2.5	5
60	158.3	31	2.5	5

Start Time:	10:47	Initial Leak Check	.05 LPM@ 15 "Hg	DGMCF:	1.018
Finish Time:	11:47	Final Leak Check	.05 LPM@ 15 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	2.5

Operator:	BT
-----------	----

ORTECH
Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	3

Test location:	STACK
Date:	AUG 17/22
Project No.:	22/69

Train A

Tube Identification:	663165	Spiked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Spike Concentration	—	ng	

Measuring Device	MII
Control Module	V3 A12010
Barometer	ENV. CAN.

Barometric Pressure	29.47
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	77.5	38	.5	6
5	80.4	41	.5	6
10	85.8	41	.5	6
15	90.7	40	.5	6
20	95.5	39	.5	6.7
25	100.6	39	.5	7
30	105.7	39	.5	7
35	110.7	39	.5	7
40	115.6	39	.5	7
45	120.6	39	.5	7
50	125.5	39	.5	7
55	130.5	39	.5	7
60	135.5	37	.5	7

Start Time:	12:11	Initial Leak Check	.05 LPM@ 15 "Hg	DGMCF:	0.988
Finish Time:	13:11	Final Leak Check	LPM@ "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Train B

Tube Identification:	568842	Spiked	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Spike Concentration	40	ng	

Measuring Device	MII
Control Module	V2 A10117

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	59.0	31	2.5	2
5	64.5	34	2.5	6
10	69.8	32	2.5	6
15	74.8	32	2.5	6
20	79.5	32	2.3	6.5
25	83.9	31	2.3	6.5
30	88.4	30	2.3	6.5
35	92.7	31	2.2	6.5
40	97.0	30	2.2	6.5
45	101.0	30	2.1	6.5
50	105.8	30	2.0	6.5
55	110.3	30	2.0	6.5
60	115.0	31	2	6.5

* MAKE OUT

Start Time:	12:11	Initial Leak Check	.05 LPM@ 15 "Hg	DGMCF:	1.018
Finish Time:	13:11	Final Leak Check	LPM@ "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Operator:	DT
-----------	----

ORTECH Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	4

Test location:	STACK
Date:	AUG 17 1996
Project No.:	22/96

Train A

Tube Identification:	010673	Spiked	(Yes) No
Spike Concentration	600	ng	

Measuring Device	MII
Control Module	A12010
Barometer	ENV. CAN.

Barometric Pressure	29.44
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	37.7	36	-5	4
5	42.0	39	-5	6
10	47.9	39	-5	7
15	53.2	39	-5	7
20	58.3	39	-5	7
25	63.2	39	-5	7
30	68.2	40	-5	7
35	73.2	39	-5	7
40	78.2	39	-5	7
45	83.2	39	-5	7
50	88.1	39	-5	7
55	92.9	40	-5	7
60	98.0	38	-5	7

Start Time:	14:01	Initial Leak Check:	0.5 LPM@ 16 "Hg	DGMCF:	.988
Finish Time:	15:01	Final Leak Check:	0.7 LPM@ 16 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Train B

Tube Identification:	6672348	Spiked	(Yes) No
Spike Concentration		ng	

Measuring Device	MII
Control Module	M05498

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	15.5	33	1.8	6
5	21.0	35	1.8	6
10	26.2	35	1.8	7
15	31.0	35	1.8	7
20	35.5	35	1.8	7
25	41.3	36	1.8	7
30	46.2 47.0	36 36	1.8	7
35	52.5	36	1.8	7
40	58.0	36	1.8	7
45	63.3	36	1.8	7
50	69.0	36	1.8	7
55	74.6	36	1.8	7
60	80.0	38	1.8	7

Start Time:	14:01	Initial Leak Check:	0.5 LPM@ 22 "Hg	DGMCF:	.992
Finish Time:	15:01	Final Leak Check:	0.5 LPM@ 18 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Operator:	DT
-----------	----

ORTECH
Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	5

Test location:	STACK
Date:	AUG 17/22
Project No.:	22/98

Train A

Tube Identification:	024083	Spiked	Yes (No)
Spike Concentration		ng	

Measuring Device	MII
Control Module	A12010
Barometer	ENV. CAN.

Barometric Pressure	29.43
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	98.7	37	.5	6
5	104.3	39	.5	6
10	109.8	39	.5	6
15	115.3	39	.5	6
* 20 DOWN	121.7	39	.5	6
25	126.1	39	.5	7
30	131.3	39	.5	7
35	136.5	39	.5	7
40	141.6	39	.5	7
45	146.8	41	.5	7
50	152.1	39	.5	7
55	157.1	39	.5	7
60	162.3	40	.5	7

Start Time:	15:24	Initial Leak Check	.05 LPM@ 18 "Hg	DGMCF:	.988
Finish Time:	16:29	Final Leak Check	.05 LPM@ 18 "Hg	Sample Volume:	
* PROCESS ISSUE BACK ON 15:49				Average DGM Temp:	
				Average DGM Δ H:	

Train B

Tube Identification:	020071	Spiked	Yes (No)
Spike Concentration	1000	ng	

Measuring Device	MII
Control Module	M05498

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	88.9 81.0	34	1.8	9
5	86.5	34	1.8	9
10	92.0	34	1.8	9
15	97.8	34	1.8	9
* 20 DOWN	103.5	34	1.8	9
25	107.5	36	1.8	13
30	113.2	35	1.8	13
35	118.9	36	1.8	13
40	124.5	35	1.8	13
45	130.0	36	1.8	13
50	135.7	34	1.8	13
55	141.2	35	1.8	13
60	146.6	35	1.8	13

Start Time:	15:24	Initial Leak Check	.05 LPM@ 12 "Hg	DGMCF:	.992
Finish Time:	16:29	Final Leak Check	.05 LPM@ 12 "Hg	Sample Volume:	
Operator:				Average DGM Temp:	
				Average DGM Δ H:	

ORTECH
Mercury Tube Data Sheet

Plant:	Clean Harbors
Plant Location:	Corunna
Test No.:	6

Test location:	STACK
Date:	AUG 17/20
Project No.:	22196

Train A

Tube Identification:	61064	Spiked	<input checked="" type="radio"/> Yes <input type="radio"/> No
Spike Concentration	2250	ng	

Measuring Device	MII
Control Module	A1201
Barometer	ENV. CAN.

Barometric Pressure	29.42
---------------------	-------

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	73.2	36	.5	6
5	78.5	37	.5	6
10	83.5	37	.5	6
15	88.5	37	.5	6
20	92.9	36	.5	6
25	97.6	36	.5	6
30	102.5	35	.5	9
35	107.7	35	.5	9
40	112.8	35	.5	9
45	118.0	35	.5	9
50	123.2	34	.5	9
55	128.5	34	.5	9
60	133.8	34	.5	9

Start Time:	16:46	Initial Leak Check:	0.07 LPM @ 15 "Hg	DGMCF:	.788
Finish Time:	17:48	Final Leak Check:	0.05 LPM @ 15 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Train B

Tube Identification:	624086	Spiked	<input checked="" type="radio"/> Yes <input type="radio"/> No
Spike Concentration		ng	

Measuring Device	MII
Control Module	M05498

Clock Time	Dry Gas Meter L	Average Meter Temperature °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	49.0	32	1.8	6
5	54.1	33	1.8	6
10	59.1	33	1.8	6
15	64.1	33	1.8	6
20	69.0	33	1.8	6
25	72.7	33	1.8	11
30	78.4	33	1.8	11
35	84.5	33	1.8	11
40	90.6	33	1.8	10.5
45	95.7	33	1.8	10.5
50	101.5	33	1.8	10.5
55	106.0	33	1.8	10.5
60	113.8	33	1.8	10.5

Start Time:	16:46	Initial Leak Check:	0.05 LPM @ 15 "Hg	DGMCF:	0.992
Finish Time:	17:46	Final Leak Check:	0.05 LPM @ 15 "Hg	Sample Volume:	
				Average DGM Temp:	
				Average DGM Δ H:	

Operator:	DT
-----------	----

APPENDIX 7

**Method 30B Analytical Report
(18 pages)**

Sorbent Trap Analysis Report

Date | 8/29/22

Analyst[s] | Lindsey Buzaki

Project | 2029794

Turnaround | Standard

Company | ORTECH

Contact | Chris Belore

Phone | 905-822-4120 ext. 324

Email | cbelore@ortech.ca

Method | EPA 7473

Method Uncertainty | ± 10%

MDL | 0.39 ng

LOQ | 5 ng

Trap ID	Pre-Filter Mass [ng]	AGS Mass [ng]	Section 1 Mass [ng]	Section 2 Mass [ng]	Section 3 Mass [ng]	Spike Level [ng]	Breakthrough [%] ²	Spike Recovery [%] ³	Source	Notes	Affected Section
OL663187			148.8	0.0			0.0%		Test 1 - Stack		
OL618359			306.1	1.0		150	0.3%		Test 1 - Stack		
OL528943			391.9	2.0		250	0.5%		Test 2 - Stack		
OL663163			151.6	0.9			0.6%		Test 2 - Stack		
OL663165			115.8	1.5			1.3%		Test 3 - Stack		
OL568842			499.6	1.3		400	0.3%		Test 3 - Stack		
OL610673			734.4	0.0		600	0.0%		Test 4 - Stack		
OL663238			150.8	0.3			0.2%		Test 4 - Stack		
OL624083			84.0	0.1			0.1%		Test 5 - Stack		
OL620071			1060	0.0		1000	0.0%		Test 5 - Stack		
OL610641			2226	1.1		2200	0.1%		Test 6 - Stack		
OL624086			127.7	0.8			0.6%		Test 6 - Stack		

¹ Total Mass = PF+AGS+S1+S2

² Breakthrough = S2 / [PF+AGS+S1]

³ For PS12B only Spike Recovery = S3 / Spike Level

⁴ Data invalidation qualifier - refer to notes

ATTENTION: A response factor was used to calculate certain values on this report. Italicized masses appear on the report as rounded to the nearest tenth nanogram.



Analyst Lindsey Buzaki
 File Name 220829_LHB_ORTECH_2029794
 Analyzer 444
 Cell type Short

Temperature [°C] 680
 Flow Rate [L/min] 1.5
 MDL [ng] 0.39
 SD 1

Trap ID	Pf Mass [ng]	AGS Mass [ng]	Section 1 Mass [ng]	Section 2 Mass [ng]	Section 3 Mass [ng]	Section 4 Mass [ng]	Spike Level [ng]	Source	Notes	Affected Section
1	OL663187		148.8	0.0				Test 1 - Stack		
2	OL618359		306.1	1.0				Test 1 - Stack		
3	OL528943		391.9	2.0				Test 2 - Stack		
4	OL663163		151.6	0.9				Test 2 - Stack		
5	OL663165		115.8	1.5				Test 3 - Stack		
6	OL568842		499.6	1.3				Test 3 - Stack		
7	OL610673		734.4	0.0				Test 4 - Stack		
8	OL663238		150.8	0.3				Test 4 - Stack		
9	OL624083		84.0	0.1				Test 5 - Stack		
10	OL620071		1060	0.0				Test 5 - Stack		
11	OL610641		2226	1.1				Test 6 - Stack		
12	OL624086		127.7	0.8				Test 6 - Stack		
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										


Additional Notes

Daily Calibration ¹			Continuing Calibration Verifications ⁴			Active Hg Standard Bank ⁵		
Lot Std. ID	Std. [ng]	Calculated [ng]	Lot Std. ID	Std. [ng]	Calculated [ng]	Kit Used	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B
S2-MEB708106 A	5.0	see cal. report	OL5019277	1500.0	1445	Concentration [µg/ml]		
S2-MEB708106 A	10.0	see cal. report	S2-HG709270 A	1000.0	981.3	0.1		T2-MEB716662 B
S2-MEB712974 A	100.0	see cal. report	S2-HG709270 A	1000.0	1007	1		S2-MEB712974 B
S2-HG709270 A	1000.0	see cal. report	S2-HG709270 A	1000.0	1014	10		R2-HG700202 B
S2-MEB708107 A	5000.0	see cal. report				100		S2-MEB708107 B
S2-MEB708107 A	10000.0	see cal. report				1000		R2-HG677010
						0.1		S2-MEB708106 A
						1		S2-MEB712974 A
						10		S2-HG709270 A
						100		S2-MEB708107 A
						1 (Independent)		R2-HG691902
						10 (Independent)		R2-MEB691339
						100 (Independent)		P2-MEB681004

¹ Performed daily prior to analysis of sorbent traps. Refer to SOP for Instrument Calibration for acceptance criteria
² Performed immediately after calibration curve is verified, must come within 10% of expected value
³ Performed between every 10 samples for method 30B and after every analytical batch
⁴ Response factor value must fall between the LOD and MDL
⁵ Subject to change, for analyst convenience only
⁶ Method blank must be measured at a value less than LOD
⁷ Data invalidation qualifier - refer to notes

Immediately report any QA/QC failures or anything suspicious to the QA/QC Manager

Other Reagents	
Sodium Carbonate	22110-11
Iodinated Activated Carbon	4C33


Analyst Signature 
 By signing this report I confirm that the above data are true to the best of my knowledge.

Date 8/29/22



REPORT

Report created 29.08.2022 11:45:33
 Instrument RA915+ Serial 444
 number
 Calibration created 29.08.2022 11:45:30
 Calibration name 220829_LHB_5-10000_p2



Results

N	Mercury mass, ng	S-Blank	Ref.data, ppb	Calculated, ppb	d, %
1	10.00	510000	10000.0	9261.3	-7.4
2	5.00	266900	5000.0	4846.1	-3.1
3	1.00	56230	1000.0	1021.1	2.1
4	0.10	5860	100.0	106.4	6.4
5	0.01	574	10.0	10.4	4.3
6	0.01	269	5.0	4.9	-2.3

Calibration S - Sblank = a·m
 Algorithm WLSM
 Correlation coefficient 0.999769
 Residual standard deviation 238.698046
 Coefficient a = 55070.0000



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form

Trap ID
 OL663187

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly):

Wally C

Production Lot: U-1139

Spike Date:

Carbon Lot: 4C

Spike Time:

High Flow Fluffy Pre-filter 185 mm 240 mm
 Static Pre-filter AGS 300 mm 450 mm

QA/QC Signature (Spike):

Type of Trap: **30B**

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: / /

Sampling Location:

Run End Date/Time: / /

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Signature]</i>	8-22-22	10:50	Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Signature]</i>	8/29/22	15:00	Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%, Traceable to NIST

Best Before: July 2025

1 440 264 2500 office
1 888 876 2611 toll free

www.ohiolumex.com
mail@ohiolumex.com

30350 Bruce Industrial Pkwy.
Cleveland, OH 44139 USA



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



OL618359

Unspiked Spiked At: 150ng
Spiking Method Cold Vapor Adsorption Via Impinger Sparging
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly) [Signature]

QA/QC Signature (Spike) [Signature]

Production Lot: S-4CEA Carbon Lot: 4C

- High Flow Fluffy Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- 185 mm 450 mm

Spike Date: 3/17/2022 Spike Time: 1455 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____
Date _____ Time _____

Sampling Location: _____
(stack, FGD inlet, etc.)

Run Number (optional): _____ Run END: _____
Date _____ Time _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CEMENT KILNS Only**

No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____
Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.

	Signature	Date	Time	Security Seal
Trap inserted by				If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by				
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap received by lab	<u>[Signature]</u>	<u>3-22-22</u>	<u>10:50</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<u>[Signature]</u>	<u>3/29/22</u>	<u>15:12</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs. Deactivated glass and glass wool Impregnated Activated Carbon – Refer to SDS

Best Before: March 2025



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



Trap ID
OL528943

Unspiked Spiked At: 250ng
Spiking Method Cold Vapor Adsorption Via Impinger Sparging
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Maker) [Signature]

Production Lot: S-39E4 Carbon Lot: 4C

QA/QC Signature (Spiker) [Signature]

- High Flow Coil Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- Fluffy Pre-filter 185 mm 450 mm

Spike Date: 1/15/2020 Spike Time: 1055 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____
Date _____ Time _____

Sampling Location: _____
(stack, FGD inlet, etc.)

Run Number (optional): _____ Run END: _____
Date _____ Time _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CEMENT KILNS Only**
No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____
Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by				If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by				
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap received by lab	<u>[Signature]</u>	<u>8-22-22</u>	<u>10:50</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<u>[Signature]</u>	<u>8/29/22</u>	<u>15:18</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs. Deactivated glass and glass wool Impregnated Activated Carbon – Refer to SDS

Best Before: January 2023



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



Trap ID
OL663163

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly):

Walla C

Production Lot: U-1139

Spike Date:

Carbon Lot: 4C

Spike Time:

- High Flow Fluffy Pre-filter 185 mm 240 mm
- Static Pre-filter AGS 300 mm 450 mm

QA/QC Signature (Spike):

Type of Trap: **30B**

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: /

Sampling Location:

Run End Date/Time: /

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received. Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Signature]</i>	8-22-22	10:50	Seal intact as received. Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Signature]</i>	8/29/22	15:24	Seal intact as received. Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation on the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%, Traceable to NIST

Best Before: July 2025



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



Trap ID
OL663165

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly)

[Handwritten Signature]

Production Lot: U-1139

Spike Date:

Carbon Lot: 4C

Spike Time:

- High Flow
- Fluffy Pre-filter
- 185 mm
- 240 mm
- Static Pre-filter
- AGS
- 300 mm
- 450 mm

QA/QC Signature (Spike):

Type of Trap: **30B**

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: /

Sampling Location:

Run End Date/Time: /

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here. (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Handwritten Signature]</i>	8-22-22	10:50	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Handwritten Signature]</i>	8/29/22	15:32	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%, Traceable to NIST

Best Before: July 2025

1 440 264 2500 office
1 888 876 2611 toll free

www.ohiolumex.com
mail@ohiolumex.com

30350 Bruce Industrial Pkwy.
Cleveland, OH 44139 USA



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



Unspiked Spiked At: 400ng
Spiking Method Cold Vapor Adsorption Via Impinger Sparging
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly) _____

QA/QC Signature (Spike) _____

Production Lot: S-4B51 Carbon Lot: 4C

- High Flow Fluffy Pre-filter 240 mm
- Static Pre-filter AGS 300 mm
- 185 mm 450 mm

Spike Date: 1/19/2022 Spike Time: 1312 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____	PRE-Run Leak Check (circle one):	PASS	FAIL
Boiler ID: _____	Run START: _____	Date	Time
Sampling Location: _____ <small>(stack, FGD inlet, etc.)</small>	-----		
Run Number (optional): _____	Run END: _____	Date	Time
Sampling Train (circle one): A B	POST-Run Leak Check (circle one):	PASS	FAIL
Notes: _____			

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____	Estimated Ave Hg Concentration (µg/dscm): _____
Ave Trap Temp (F°): _____	Circle Event if Occurred During Sampling:
Ave Flow Rate (cc/min): _____	STARTUP SHUTDOWN
Total Volume (L) _____ or (dscm): _____	----- <small>For CEMENT KILNS Only</small>
	No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____
Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.				
	Signature	Date	Time	Security Seal
Trap inserted by				If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by				
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap received by lab		8-22-22	10:50	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		8/29/22	15:39	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs. Deactivated glass and glass wool Impregnated Activated Carbon – Refer to SDS

Best Before: January 2025



Ohio Lumex Co., Inc.
 Sorbent Trap Chain of Custody Form



Trap ID
 OL610673

Unspiked Spiked At: 600ng
 Spiking Method Cold Vapor Adsorption Via Impinger Sparging
 Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly) _____

QA/QC Signature (Spike) _____

Production Lot: S-4DF9 Carbon Lot: 4C

- High Flow
- Fluffy Pre-filter
- 240 mm
- Static Pre-filter
- AGS
- 300 mm
- 185 mm
- 450 mm

Spike Date: 05/02/2022 Spike Time: 1218 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____
Date Time

Sampling Location: _____
(stack, FGD inlet, etc.)

Run Number (optional): _____ Run END: _____
Date Time

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CEMENT KILNS Only**
 No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____
 Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.

	Signature	Date	Time	Security Seal
Trap inserted by				If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by				
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap received by lab		8.22.22	10:50	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by		8/29/22	15:40	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs. Deactivated glass and glass wool Impregnated Activated Carbon - Refer to SDS

Best Before: May 2025



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



Trap ID
OL663238

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly):

[Handwritten Signature]

Production Lot: U-1139

Spike Date:

Carbon Lot: 4C

Spike Time:

- High Flow
- Fluffy Pre-filter
- 185 mm
- 240 mm
- Static Pre-filter
- AGS
- 300 mm
- 450 mm

QA/QC Signature (Spike):

Type of Trap: **30B**

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: /

Sampling Location:

Run End Date/Time: /

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Signature]</i>	8/22/22	10:50	Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Signature]</i>	8/29/22	15:51	Seal intact as received: Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%. Traceable to NIST.

Best Before: July 2025



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



Trap ID
OL624083

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly): *[Signature]*

Production Lot: U-1115

Spike Date:

Carbon Lot: 4C

Spike Time:

High Flow Fluffy Pre-filter 185 mm 240 mm
 Static Pre-filter AGS 300 mm 450 mm

QA/QC Signature (Spike):

Type of Trap: 30B

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: /

Sampling Location:

Run End Date/Time: /

Run Number (Optional):

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here. (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Signature]</i>	8-22-22	10:50	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Signature]</i>	8/29/22	15:51:00	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%, Traceable to NIST

Best Before: June 2025



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



Trap ID
OL620071

Unspiked Spiked At: 1,000ng
Spiking Method Cold Vapor Adsorption Via Impinger Sparging
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly) [Signature]

QA/QC Signature (Spike) [Signature]

Production Lot: S-4DF8 Carbon Lot: 4C

- High Flow
- Fluffy Pre-filter
- 240 mm
- Static Pre-filter
- AGS
- 300 mm
- 185 mm
- 450 mm

Spike Date: 05/02/2022 Spike Time: 1122 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____
Date Time

Sampling Location: _____
(stack, FGD inlet, etc.)

Run Number (optional): _____ Run END: _____
Date Time

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CEMENT KILNS Only**

No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.

	Signature	Date	Time	Security Seal
Trap inserted by				If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet)
Trap removed and sealed by				
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Courier/Other (If Applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap received by lab	<u>[Signature]</u>	<u>8-22-22</u>	<u>10:50</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Trap analyzed by	<u>[Signature]</u>	<u>8/29/22</u>	<u>10:00</u>	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs. Deactivated glass and glass wool Impregnated Activated Carbon – Refer to SDS

Best Before: May 2025



Ohio Lumex Co., Inc. Sorbent Trap Chain of Custody Form



Trap ID

OL610641

Unspiked Spiked At: 2,200ng Spiking Method Cold Vapor Adsorption Via Impinger Sparging Certified Accuracy ± 10%. Traceable to NIST

QA/QC Signature (Trap Assembly)

QA/QC Signature (Spike)

Production Lot: S-DF7 Carbon Lot: 4C

- High Flow, Static Pre-filter, Fluffy Pre-filter, AGS, 185 mm, 240 mm, 300 mm, 450 mm

Spike Date: 05/02/2022 Spike Time: 1050 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source, PRE-Run Leak Check, Boiler ID, Run START, Sampling Location, Run Number, Run END, Sampling Train, POST-Run Leak Check, Notes

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp, Ave Trap Temp, Ave Flow Rate, Total Volume, Estimated Ave Hg Concentration, Circle Event if Occurred During Sampling, No. of RAW MILL OFF Events During Sampling

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng), Note: Analyzer calibration range will be set based on this value.

Chain Of Custody

Table with columns: Signature, Date, Time, Security Seal. Rows include Trap inserted, removed, received, and analyzed by.

Make sure all of your sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps and should be prevented at all costs.

Best Before: May 2025



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form

Trap ID
 OL624086

UNSPIKED

SPIKED AT:

QA/QC Signature (Trap Assembly):

Wally C

Production Lot: U-1115

Spike Date:

Carbon Lot: 4C

Spike Time:

High Flow Fluffy Pre-filter 185 mm 240 mm
 Static Pre-filter AGS 300 mm 450 mm

QA/QC Signature (Spike):

Type of Trap: 30B

SAMPLING INFORMATION

Facility / Source:

PRE-Run Leak Check: PASS FAIL

Boiler ID:

Run Start Date/Time: /

Sampling Location:

Run End Date/Time: /

Run Number (Optional):

Run Number (Optional):

Sampling Train: A B

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°):

Estimated Avg. Hg Concentration (µg/dscm):

Avg. Trap Temp (F°):

Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min):

CEMENT ONLY:

Total Volume (L): or (dscm)

of RAW MILL OFF events during sampling:

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng):

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

	Signature	Date	Time	Security Seal
Sample(s) taken by				If applicable place chain of custody seal here (see security seal instruction sheet)
Sample(s) prepared for shipment by				
Courier/Other (if applicable)				Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) received by lab	<i>[Signature]</i>	8-22-22	10:50	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>
Sample(s) analyzed by	<i>[Signature]</i>	8/29/22	10:19	Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/>

Ensure sampling conditions prevent moisture condensation in the trap media. Moisture condensation is a major cause of measurement failure in sorbent traps and should be prevented. Spiking Method Cold Vapor Adsorption Via Impinger. Sparging Certified Accuracy ± 10%. Traceable to NIST.

Best Before: June 2025

1 440 264 2500 office
1 888 876 2611 toll free


www.ohiolumex.com
mail@ohiolumex.com

30350 Bruce Industrial Pkwy.
Cleveland, OH 44139 USA

ORTECH Consulting Inc. Sample Log
Mercury Tube Samples
Incinerator Exhaust Stack

Job/Report Number: 22196
Received By: David Utley
Job Assigned To: Ohio Lumex
PO #: 20000-J2858

Tube ID	Spiked?	Sample Date	Sample Description	Approx. Sample Volume m ³	Sample Analysis
OL663187	No	August 17, 2022	Test 1 - Stack	0.06	Hg
OL618359	Yes	August 17, 2022	Test 1 - Stack	0.06	Hg
OL528943	Yes	August 17, 2022	Test 2 - Stack	0.06	Hg
OL663163	No	August 17, 2022	Test 2 - Stack	0.06	Hg
OL663165	No	August 17, 2022	Test 3 - Stack	0.06	Hg
OL568842	Yes	August 17, 2022	Test 3 - Stack	0.06	Hg
OL610673	Yes	August 17, 2022	Test 4 - Stack	0.06	Hg
OL663238	No	August 17, 2022	Test 4 - Stack	0.06	Hg
OL624083	No	August 17, 2022	Test 5 - Stack	0.06	Hg
OL620071	Yes	August 17, 2022	Test 5 - Stack	0.06	Hg
OL610641	Yes	August 17, 2022	Test 6 - Stack	0.06	Hg
OL624086	No	August 17, 2022	Test 6 - Stack	0.06	Hg

Relinquished To: _____ Date: _____
 Relinquished By:  Date: Aug 18/22

This report has been reviewed and approved by:

Jonathan Cross
QA/QC Manager and Research Scientist

A handwritten signature in black ink, appearing to be 'Jonathan Cross', written over a horizontal line.

APPENDIX 8

**Method 29 Train Field Data Sheets
Pre-PAC Injection
(5 pages)**

Clean Harbors, Sarnia
 Particulate and Mercury Sampling Train
 Pre-PAC Injection

Test No.	Dry Gas Meter Correction Factor	Initial Dry Gas Meter Reading ft ³	Final Dry Gas Meter Reading ft ³	Actual Volume Sampled ft ³	Barometric Pressure in. mercury	Average Dry Gas Meter		Corrected Gas Volume Sampled Rm ³ *	Total Gain (g)	Moisture (%)
						Pressure in. water	Temperature °F			
1	1.003	40.10	46.85	6.75	29.48	0.4	82.5	0.1872	155.1	52.99
2	1.003	47.30	56.50	9.20	29.44	0.3	88.7	0.2518	184.9	49.96

* Dry at 25°C and 1 atmosphere

ORTECH Consulting Inc.

Plant	Clean Harbors
Plant Location	Corunna, Ontario
Test No.:	1 M29
Test Date	AUG 17/22
Test Location	Incinerator-Exhaust-Stack INLET
Operator Signature	<i>D. D. [Signature]</i>

Project No.:	2219E
Page	1 of 2
Probe No.:	3/4
Meter Box No.:	1/2
Impinger Box No.:	1/4

Pitot Factor	-
DGMCF	1.005
Barometric Pressure	29.48 "Hg
Static Pressure	"H2O
Nozzle Size	2304 inches
Stack Diameter	5 inches
Length	0 feet
Width	0 feet
Port length:	8 inches

Particulate Gain	
Filter	mg
Probe	mg

Moisture Gain	
CWTR	151.6 g
WCBDA	3.5 g

Combustion Gas Concentration	
Oxygen	%
Carbon Dioxide	%
Carbon Monoxide	ppm

Reading Interval	5
Number of Ports	1
Number of Points/Port	10

Probe Liner Glass Metal/Teflon/Other _____

Nozzle Glass Metal/Other _____

Union None Metal/Teflon/Other _____

Pitot Leak Checked? Yes No

Measuring Device	Mill Numbers
Probe / Pitot	-
Trendicator	AOLKAS
Control Box	-
Incline Manometer	-
Comb.Gas.Analyzer	-
Micromanometer	-
Barometer	Env.Can
Calipers	BO3506

Nozzle Measurements	
1	12505
2	2305
3	12305
4	12800
Average:	

Site Diagram

Notes: _____

Field Data Sheet

Date: Aug-17-77 Plant: Clean Harbors Inlet: VNLEBT Page 2 of 2
 Plant Location: Corunna, Ontario Test Location: Inlet-Exhaust Stack

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp °F		Meter Temp °F		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Inlet/Trap	Outlet	Inlet	Outlet		
1	0	40.10			400	251	250	69	82	82	5	3	
	25	47.16			406	252	245	57	82	82	5	3	
	40	43.95			405	252	245	56	82	84	3	13	
	515	45.50			408	252	245	56	82	84	2	15	
	1220	46.85											
	1525												
	1830												
	21												
	24												
	27												
	30												
	33												
	36												
	39												
	42												
	45												
	48												
	51												
	54												
	57												
	60												

Traverse: _____ Initial Leak Check: _____ "Hg
 Start Time: 9:40 Initial Leak Check: 1003 cfm@ 15 "Hg
 Finish Time: 10:00 Final Leak Check: 203 cfm@ 16 "Hg
 Project No.: 22195
 Operator: [Signature]

ORTECH Consulting Inc.

Plant	Clean Harbors
Plant Location	Corunna, Ontario
Test No.:	2 - M29
Test Date	AUG 17/22
Test Location	Incinerator Exhaust Stack
Operator Signature	<i>D. D. U.S.</i>

Project No.:	22196
Page	1 of 2
Probe No.:	3
Meter Box No.:	1
Impinger Box No.:	16

Pitot Factor	1
DGMCF	1003
Barometric Pressure	29.44 "Hg
Static Pressure	"H2O
Nozzle Size	230 4 inches
Stack Diameter	5 inches
Length	0 feet
Width	0 feet
Port length:	8 inches

Particulate Gain	
Filter	mg
Probe	mg

Moisture Gain	
CWTR	180.4 g
WCBDA	4.5 g

Combustion Gas Concentration	
Oxygen	%
Carbon Dioxide	%
Carbon Monoxide	ppm

Measuring Device	MII Numbers
Probe / Pitot	SEE
Trendicator	
Control Box	TEST
Incline Manometer	
Comb. Gas. Analyzer	1
Micromanometer	
Barometer	Env. Can
Calipers	

Reading Interval	5
Number of Ports	1
Number of Points/Port	10

Probe Liner Glass / Metal / Teflon / Other

Nozzle Glass / Metal / Other

Union None / Metal / Teflon / Other

Pitot Leak Checked? Yes No

Site Diagram

Nozzle Measurements
1 _____
2 _____
3 _____
4 _____
Average: _____

Notes: _____

Field Data Sheet

Date: AUG 17 2004 Plant: Clean Harbors Test No.: 2 M29 Page 2 of 2
 Plant Location: Corunna, Ontario Test Location: Incinerator-Exhaust Stack INC 7

Point	Clock Time	Dry Gas Meter ft ³	Pitot Δ P "H ₂ O	Desired cfm	Stack Temp °F	Probe Temp °F	Oven Temp °F	Impinger Temp °F		Meter Temp °F		Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
								Outlet	Inlet/Trap	Outlet	Inlet		
1	0	47.30			400	253	262	82		86	86	.3	2
	45	49.49			416	253	241	62		86	87	.3	5
	810	51.61			391	268	255	56		87	89	.3	8
	15	53.52			412	265	258	53		87	91	.3	11
2	1620	55.10			402	266	260	51		88	93	.2	15
	2025	56.50			400	270	265	50		89	95	.2	15
	2430												
3	28												
	32												
	36												
	40												
	44												
4	48												
	52												
	56												
	60												
5	64												
	68												
	72												
	76												
6	80												

Traverse: _____ Initial Leak Check: _____ "Hg Final Leak Check: _____ "Hg
 Start Time: 1421 Initial Leak Check: 1002 cfm@ 16 "Hg
 Finish Time: 1446 Final Leak Check: 2002 cfm@ 17 "Hg
 Project No.: 22196
 Operator: _____

APPENDIX 9

**Acid Gas Field Data Sheets
(5 pages)**

Clean Harbors, Sarnia
 Acid Gas Sampling Train
 Sample Volume Corrections

Incinerator Exhaust Stack

Test #	DGMCF	Initial DGM Reading (L)	Final DGM Reading (L)	Actual Vol. Sampled (L)	Barometric Pressure (in Hg)	Average DGM Pressure del H (in H ₂ O)	Average DGM Temperature (°C)	Corrected Volume (L)*	Corrected Volume (Rm ³)*
1	1.009	58.00	178.40	120.40	29.48	2.0	31.3	117.80	0.1178
2	1.009	79.30	200.90	121.60	29.47	2.0	32.6	118.43	0.1184
3	1.009	5.10	126.80	121.70	29.44	2.0	32.3	118.53	0.1185
4	1.009	32.40	152.40	120.00	29.43	2.0	31.2	117.27	0.1173

* dry at 25°C and 1 atmosphere

ORTECH Method 26 Data Sheet

Plant:	CLEAN HARBORS
Plant Location:	CORUNNA ON
Test No.:	1
Test location:	STAIRS
Date:	AUG 17/22
Project No.:	22196

Measuring Device	Mill Number
Control Module	A1541
Barometer	V0774

P _{Bar}	29.48
------------------	-------

Clock Time	Dry Gas Meter L	Probe Temp °C	Stack Temp °C	Oven Temp °C	Impinger Outlet °C	Meter Temp °C	Meter Pressure Δ H "H ₂ O	Pump Vacuum "Hg Gauge
0	58.0	200	194	—	24	28	2	1
5	68.2	200	195	—	28	31	2	1
10	78.7	200	195	—	28	31	2	1
15	87.8	200	195	—	28	32	2	1.5
20	98.2	200	195	—	28	32	2	1.5
25	108.6	200	195	—	28	32	2	1.5
30	118.6	200	195	—	28	32	2	1.5
35	128.7	200	194	—	28	32	2	1.5
40	138.8	200	193	—	28	32	2	1.5
45	148.2	200	193	—	28	32	2	1.5
50	158.0	200	192	—	28	31	2	2
55	168.2	200	193	—	28	31	2	2
60	178.4	200	193	—	28	31	2	2

Start Time:	12:10
Finish Time:	11:10
Initial Leak Check:	.205 lpm @ 15" Hg
Final Leak Check:	.205 lpm @ 15" Hg

DGMCF:	
Sample Volume:	1.09
Average DGM Temp:	
Average DGM Δ H:	

Comments:

Probe Purge On: @

Off: @

sample @ ~2 lpm for 60 minutes.

Operator: *[Signature]*

**ORTECH
Method 26 Data Sheet**

Plant:	CLEAN HARBORS
Plant Location:	CORONA/GN
Test No.:	2
Test location:	9 PAKS
Date:	AUG 17 / 22
Project No.:	22106

Measuring Device	Mill Number
Control Module	A11542
Barometer	

P _{Bar}	29.47
------------------	-------

Clock Time	Dry Gas Meter L	Probe Temp °C	Stack Temp °C	Oven Temp °C	Impinger Outlet °C	Meter Temp °C	Meter Pressure ΔH "H ₂ O	Pump Vacuum "Hg Gauge
0	79.3	200	194	—	18	29	2	1
5	89.4	200	194	—	18	30	2	1
10	99.5	200	194	—	18	32	2	1.5
15	109.5	200	194	—	18	32	2	1.5
20	119.3	200	194	—	18	32	2	1.5
25	129.1	200	194	—	18	33	2	1.5
30	139.0	200	194	—	18	33	2	1.5
35	148.7	200	195	—	18	34	2	2
40	158.9	200	195	—	18	34	2	2
45	168.7	200	192	—	18	33	2	2
50	179.4	200	192	—	18	34	2	2
55	189.9	200	192	—	18	34	2	2
60	200.9	200	192	—	18	34	2	2

Start Time:	11:39
Finish Time:	12:39
Initial Leak Check:	.05 lpm @ 15" HG
Final Leak Check:	.05 lpm @ 15" HG

DGMCF:	1.009
Sample Volume:	
Average DGM Temp:	
Average DGM ΔH:	

Comments:

Probe Purge On: @ @

Off: @ @

sample @ ~2 lpm for 60 minutes.

Operator: DT

ORTECH
Method 26 Data Sheet

Plant:	CLEAN HARBORS
Plant Location:	CORRUNA
Test No.:	3
Test location:	STACKS
Date:	AUG 17/22
Project No.:	22196

Measuring Device	Mill Number
Control Module	A1542
Barometer	ENV CAN

P _{Bar}	29.44
------------------	-------

Clock Time	Dry Gas Meter L	Probe Temp °C	Stack Temp °C	Oven Temp °C	Impinger Outlet °C	Meter Temp °C	Meter Pressure ΔH "H ₂ O	Pump Vacuum "Hg Gauge
0	5.1	200	195	—	18	31	2	1
5	14.3	200	194	—	18	33	2	1
10	25.3	200	192	—	18	33	2	1
15	35.3	200	193	—	18	33	2	1
20	45.0	200	193	—	18	33	2	1
25	54.3	200	192	—	18	33	2	1.5
30	64.2	200	191	—	18	32	2	1.5
35	74.1	200	191	—	18	32	2	1.5
40	84.9	200	192	—	18	32	2	1.5
45	95.5	200	192	—	18	32	2	1.5
50	106.0	200	192	—	18	32	2	1.5
55	116.6	200	193	—	18	32	2	1.5
60	126.8	200	193	✓	18	32	2	1.5

Start Time:	14:18
Finish Time:	15:18
Initial Leak Check:	.205 lpm @ 15" Hg
Final Leak Check:	lpm @ " Hg

DGMCF:	1.009
Sample Volume:	
Average DGM Temp:	
Average DGM Δ H:	

Comments:

Probe Purge On: @

Off: @

sample @ ~2 lpm for 60 minutes.

Operator: AT

**ORTECH
Method 26 Data Sheet**

Plant: CLEAN HARBORS
 Plant Location: CORRUINA
 Test No.: 4
 Test location: STACKS
 Date: AUG 17/22
 Project No.: 22196

Measuring Device: _____ Mill Number _____
 Control Module: A11542
 Barometer: SPAN CAN

P_{Bar}: 29.43

Clock Time	Dry Gas Meter L	Probe Temp °C	Stack Temp °C	Oven Temp °C	Impinger Outlet °C	Meter Temp °C	Meter Pressure ΔH "H ₂ O	Pump Vacuum "Hg Gauge
0	32.4	200	186	17	17	30	2	1
5	42.4	200	188	17	17	30	2	1
10	52.5	200	188	17	17	33	2	1
15	62.3	200	189	17	17	32	2	1
20	72.0	200	191	17	17	33	2	1.5
25	82.0	200	191	17	17	33	2	1.5
30	92.3	200	190	17	17	34	2	1.5
35	102.5	200	190	17	17	34	2	1.5
40	112.4	200	190	17	17	30	2	1.5
45	122.2	200	191	17	17	30	2	1.5
50	132.0	200	192	17	17	29	2	1.5
55	142.2	200	192	17	17	29	2	1.5
60	152.4	200	192	17	17	28	2	1.5

Start Time: 15:36
 Finish Time: 16:56
 Initial Leak Check: .005 Lpm @ 15 " Hg
 Final Leak Check: .005 Lpm @ 15 " Hg


DGMCF: 1.009
 Sample Volume: _____
 Average DGM Temp: _____
 Average DGM Δ H: _____

Comments: _____
 Probe Purge On: @ _____
 Off: @ _____
 sample @ ~2 lpm for 60 minutes. Operator: BT

APPENDIX 10

**Acid Gas Recovery Data Sheet
(1 page)**


ORTECH Consulting Inc. Recovery & Sample Log
 Method 26
 Incinerator Stack



Client: Clean Harbors, Corunna
 Job/Report Number: 22196
 Received By: Dan Turton
 How Received: Train Recovery
 Job Assigned To: ALS
 PO #: 22196-J2864

Test Number	ORTECH Sample ID	Date Sampled	Contents of Impingers	Initial Volume (ml)	Final Volume (ml)	Gain (ml)	H ₂ O Rinse (ml)	Total Sample Volume (ml)	Analysis
1	22-22196-M26-1	AUG 17/22	0.1N H2SO4	30.0	110	80	20	130	Halides
2		AUG 17/22	0.1N H2SO4	30.0	110	80	20	130	Halides
3		AUG 17/22	0.1N H2SO4	30.0	108	78	22	130	Halides
4		AUG 17/22	0.1N H2SO4	30.0	107	77	23	130	Halides
Blank		AUG 17/22	0.1N H2SO4	30.0	30	0	100	130	Halides

Impinger 1 empty, Imp 2+3 30ml split 0.1N H2SO4, Imp 4 & Imp 5 empty, Imp 6 Silica Gel

Relinquished by: 
 Date: Aug 18/22
 Relinquished to: AARON BURTON
 Date: 18-Aug-2022 15:46
22.0°C

APPENDIX 11

**Acid Gas Analytical Report
(4 pages)**



1435 Norjohn Court, Unit 1, Burlington ON, L7L 0E6
Phone: 905-331-3111, FAX: 905-331-4567

Certificate of Analysis

ALS Project Contact: Lynne Wrona
ALS Project ID: ORT100
ALS WO#: L2729208
Date of Report: 2-Sep-22
Date of Sample Receipt: 18-Aug-22

Client Name: ORTECH Environmental
Client Address: 804 Southdown Road
Mississauga, ON L5J 2Y4
Canada
Client Contact: Chris Belore
Client Project ID: 22196 Clean Harbors

COMMENTS:

Cl as HCl Anion Analyzed via Ion Chromatography USEPA Method 26/26A (SA 23, 29-Aug-22)
Br as HBr Anion Analyzed via Ion Chromatography USEPA Method 26/26A (SA 23-Aug-22)
F as HF Anion Analyzed via Ion Chromatography USEPA Method 26/26A (SA 23-Aug-22)
I as HI Anion Analyzed via Ion Chromatography USEPA Method 26/26A (SA 30 Aug-22)

ANALYST COMMENTS:

Fluoride observed in the method blank above its LOR. Sample data is well above this threshold, indicating any impact to data quality is negligible.
PE 2-Sep-22

LOR = Limit of Reporting

MB = Laboratory Control Blank (limits: <LOR)

LCS = Laboratory Control Sample (limits: 90-110%)

MS = Matrix Spike Sample (limits: 90-110%, NH₃: 85-115%)

RPD = Relative Percent Difference (limits: <20% for sample duplicate, <10% for duplicate injection)

Certified by: 

Lynne Wrona
Project Manager

Results in this certificate relate only to the samples as submitted to the laboratory.

This report shall not be reproduced, except in full, without the written permission of ALS Canada Ltd.

ALS Environmental

Sample Analysis Summary Report

Sample Name	22-22196-M26-1 TEST#1	22-22196-M26-2 TEST#2	22-22196-M26-3 TEST#3	22-22196-M26-4 TEST#4	22-22196-M26-5 BLANK
ALS Sample ID	L2729208-1	L2729208-2	L2729208-3	L2729208-4	L2729208-5
Matrix	Stack	Stack	Stack	Stack	Stack
Analysis type	Sample	Sample	Sample	Sample	Sample
Sampling Date/Time	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22
Date of Receipt	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22
Ion Chromatography Analysis					
USEPA Method 26/26A	mg	mg	mg	mg	mg
Total F ⁻ as HF (ave)	5.39	5.13	5.37	5.18	0.0527
Analysis 1	5.40	5.14	5.39	5.20	0.0516
Analysis 2	5.38	5.11	5.35	5.16	0.0538
Total Cl ⁻ as HCl (ave)	7.74	8.68	10.7	9.13	0.0723
Analysis 1	7.76	8.67	10.8	9.09	0.0735
Analysis 2	7.73	8.68	10.7	9.16	0.0711
Total Br ⁻ as HBr (ave)	0.615	0.884	1.26	2.35	<0.225
Analysis 1	0.616	0.897	1.26	2.38	<0.225
Analysis 2	0.613	0.872	1.26	2.32	<0.225
Total I ⁻ as HI (ave)	<0.0643	<0.0680	<0.0671	<0.0680	<0.0671
Analysis 1	<0.0643	<0.0680	<0.0671	<0.0680	<0.0671
Analysis 2	<0.0643	<0.0680	<0.0671	<0.0680	<0.0671

ALS Environmental

Sample QC Summary Report

Sample Name	MB	LCS	LCS
ALS Sample ID	MB	LCS	LCS
Matrix	Stack	Stack	Stack
Analysis type	Method Blank	Blank Spike	Blank Spike
Sampling Date/Time	n/a	n/a	n/a
Date of Receipt	n/a	n/a	n/a
Ion Chromatography Analysis			
USEPA Method 26/26A	mg	mg	% Rec
Total F ⁻ as HF (ave)	0.00281	0.0536	96%
Analysis 1	0.00280	0.0542	
Analysis 2	0.00281	0.0530	
Total Cl ⁻ as HCl (ave)	<0.00241	0.0746	94%
Analysis 1	<0.00241	0.0748	
Analysis 2	<0.00241	0.0744	
Total Br ⁻ as HBr (ave)	<0.00791	0.241	93%
Analysis 1	<0.00791	0.242	
Analysis 2	<0.00791	0.240	
Total I ⁻ as HI (ave)	<0.00236	0.0723	96%
Analysis 1	<0.00236	0.0723	
Analysis 2	<0.00236	0.0723	

ALS Environmental

Sample QC Summary Report

Sample Name	22-22196-M26-1 TEST#1	22-22196-M26-1 TEST#1	22-22196-M26-1 TEST#1	22-22196-M26-1 TEST#1
ALS Sample ID	L2729208-1	L2729208-1DUP	L2729208-1MS	L2729208-1MS
Matrix	Stack	Stack	Stack	Stack
Analysis type	Sample	Duplicate	Matrix Spike	Matrix Spike
Sampling Date/Time	17-Aug-22	17-Aug-22	17-Aug-22	17-Aug-22
Date of Receipt	18-Aug-22	18-Aug-22	18-Aug-22	18-Aug-22
Ion Chromatography Analysis				
USEPA Method 26/26A	mg	mg	mg	% Rec
Total F ⁻ as HF (ave)	5.39	5.43	6.90	106%
Analysis 1	5.40	5.44	6.93	
Analysis 2	5.38	5.41	6.87	
Total Cl ⁻ as HCl (ave)	7.74	7.52	11.9	98%
Analysis 1	7.76	7.53	11.9	
Analysis 2	7.73	7.51	11.9	
Total Br ⁻ as HBr (ave)	0.615	0.599	6.09	80%
Analysis 1	0.616	0.586	6.14	
Analysis 2	0.613	0.612	6.05	
Total I ⁻ as HI (ave)	<0.0643	<0.0643	1.84	89%
Analysis 1	<0.0643	<0.0643	1.84	
Analysis 2	<0.0643	<0.0643	1.84	

APPENDIX 12

**Feed Sample Analytical Report
(2 pages)**



LAMBTON SCIENTIFIC

a division of TECHNICAL CHEMICAL SERVICES Inc.

391 Vidal Street South, Sarnia, ON, N7T 2V3

Phone: (519) 344-4747 Fax: (519) 344-2350 E-Mail: info@lambtonscientific.com

Certificate of Analysis

Customer: Clean Harbors Ltd.

Address: R. R. #1

4090 Telfer Road

Corunna, Ontario N0N 1G0

Attention: Rob Girard

Authorized By: Rob Girard

Phone Number: (519) 864-1021

Fax Number: (519) 864-3816

E-Mail: girard.rob@cleanharbors.com

Project Number:

L.S. Submission No.: 2208-271

Invoice Number.: 37523

Purchase Order No.: RG

Date Received: Aug-22-2022

Time Received: 9:00

Date Re-Submitted: ---

Requested Turn-Around: Standard (4 - 7 Days)

Report Due Date: Aug-30-2022 by 16:30

Project Description: Hg

Notes, Abbreviations, Acronyms and Explanations:

PDF Copy to be E-MAILED to Client (no Hardcopy)

The following work performed and recorded herein has been carried out in accordance with acceptable professional standards employing acceptable/recognized analytical methodologies and quality assurance procedures. Methodologies used by LS are based upon recognized Provincial, Federal or US method compendia such as CCME, EPA, ASTM, APHA. Method blanks are reported; unless indicated otherwise, associated sample data are not blank corrected. Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.

Although every care and due diligence is taken in the performance of our services, TCS/LS and its staff shall not be held responsible for any losses or damages resulting directly or indirectly from any errors or omissions. The extent of TCS/LS's liability is limited to a refund of the analytical cost(s) for the parameter(s) in question. No other warranty is expressed or implied. Customer samples will be retained at LS for a minimum of one month from the date of receipt (provided sufficient sample size originally received).

<p>ATG ... Analytical Test Group [MISA] BTEXS ... Benzene, Toluene, Ethylbenzene, Xylenes (m, o, p-), Styrene CAS# ... Chemical Abstracts Service Registry Number CF ... Concentration Factor (numerical value: original volume / reduced volume) COC ... Chain Of Custody (record of client analytical request) [Sample Submission Form] COMP ... Composite (sample formed from multiple samples) CRM ... Certified Reference Material CVAAS ... Cold Vapour Atomic Absorption Spectroscopy DF ... Dilution Factor (numerical value: final diluted volume / original volume) DUP ... Duplicate (customer Field QA/QC or lab chosen entire sample process re-analysis) EF ... Extraction Factor (numerical value: extract volume / sample quantity) FF ... Final Factor (numerical value; product of EF and either DF or CF) FIELD QA/QC ... Quality control samples at time of sampling [TB, TSB, DUP] GC-FID ... Gas Chromatography - Flame Ionization Detector GC-MSD ... Gas Chromatography - Mass Spectroscopy Detector GRAB ... Grab (sample at a single point in time) IC ... Ion Chromatography ICP-AES ... Inductively Coupled Plasma - Atomic/Optical Emission Spectroscopy INTERIM ... Interim report (non-finalized report, ie: partial, draft, incomplete, etc) ISE ... Ion-Selective Electrode LCS ... Laboratory Control Sample (lab QA/QC for analyte recovery [MISA = Spiked Blank]) LOQ ... Limit Of Quantification (lowest concentration result with meaningful U) MB ... Method Blank (lab QA/QC sample for contamination of analytical process) MDL ... Method Detection Limit (MISA)</p>	<p>MISA ... Municipal and Industrial Strategy for Abatement (Ont Reg) MRL ... Method Reporting Limit (MRL >= MDL) MS ... Matrix Spike (lab QA/QC sample for analyte interference [MISA = Spiked Sample]) P&T ... Purge and Trap PAH ... Polynuclear Aromatic Hydrocarbon QA/QC ... Quality Assurance and Quality Control RC ... Remark Code (MISA: <W, <DL, <LMDL, <T, etc) REP ... Replicate (lab chosen QA/QC sample re-analysis for difference comparison) RI ... Re-Issued (replacement report due to amendment) RS ... Re-Submitted (client requested submission change after original submission) RT ... Report TAT (client requested change to turn-around time) RPD ... Relative Percent Difference (QA/QC comparative statistic between matched results) SRI ... Smallest Reporting Increment (MISA) SRL ... Sample Reporting Limit (product of MRL and any quantification factors) SURROGATE ... known added compounds that mimic analytes for QA/QC recovery TB ... Travelling Blank (sample for collection contamination) [MISA FIELD QA/QC] TCLP ... Toxicity Characteristic Leaching Procedure (EPA 1311) TSB ... Travelling Spiked Blank (sample for collection analyte recovery) [MISA FIELD QA/QC] U ... Uncertainty; measure of total variability associated with result VOCs ... Volatile Organic Compounds % REC ... Percent Recovery (QA/QC statistic between actual versus predicted result)</p> <p>--- ... sample not analyzed, not requested or data not available < ... result less than MRL or less than MRL multiplied by any quantification factors</p>
---	--

The information in this report/facsimile/electronic transmission is intended for the named recipient(s) only. It may contain privileged and confidential information. If you have received this report in error, any perusal, use, copying or dissemination of its contents is prohibited. Please notify Lambton Scientific immediately if received by error. This Certificate shall not be reproduced without approval of the laboratory.

The results reported relate only to the samples as received by the laboratory.

This report has been reviewed and approved by:

August 24, 2022

Dated

Andy Schmidtmeier, M.Sc.

Interim Report 1:

Interim Report 2:

Final Report:

E-MAILED

August 24, 2022

Hg

Lambton Scientific ID	Customer ID	Sample Date	Sample Time	Info	MRL	Units	Results	Qualifier	Comments	Extraction Date	Analysis Date	Initials: MS/TO
2208-09933	Alkaline Composite	Aug-17-2022	---	Grab / Other	0.05	mg/kg	< 0.05					
2208-09934	Rich Composite	Aug-17-2022	---	Grab / Other	0.20	mg/kg	0.48					
2208-09935	Lean Composite	Aug-17-2022	---	Grab / Other	0.20	mg/kg	0.44					
2208-09936	Emulsion Composite	Aug-17-2022	---	Grab / Other	0.20	mg/kg	< 0.22			Aug-22-2022	Aug-24-2022	
2208-09937	Leachate Composite	Aug-17-2022	---	Grab / Other	0.20	mg/kg	< 0.23					
2208-09938	TDU Raw Composite	Aug-17-2022	---	Grab / Other	0.50	mg/kg	9.2					
2208-09939	TDU Post Composite	Aug-17-2022	---	Grab / Other	0.50	mg/kg	< 0.53					

Mercury									
LABORATORY QA/QC DATA									
MB	LCS	RM	MS	REP					
Method Blank	Lab Control Sample	Reference Material	Sample Matrix Spike	Replicate	Qualifier				
					Blank	Material	% Rec	% Rec	% RPD
< 0.005	Actual: 100 Limits: 80-120	% Rec: 84	% Rec: ---	---	100	80-120	84	---	---
BATCH MRL: 0.005 mg/L Units: mg/L % RPD: ---									



Report Notes/Comments:

APPENDIX 13

**Equipment Calibration Data
(12 pages)**

**ORTECH Consulting Inc.
Pitot Tube Calibration**

Date	February 8, 2022
Probe/Pitot ID	S9
MI Number	B03770
Calibrated Against	B02911
Cp standard	0.99777
Calibration Procedure	93-T62-SP-012

Calibration Facility	ORTECH Consulting Inc.
Calibrated By	Dan Turton
Signature	
Reviewed/Accepted By	

$C_p = C_{pstd} \cdot \sqrt{\frac{P_{std}}{P_s}}$

Configuration	Wind Tunnel Velocity m/s	Velocity Head Standard Pitot in. H ₂ O P _{std}	Velocity Head S-Type Pitot in. H ₂ O P _s	S-Type Pitot Coefficient C _{p_s}	Deviation From The Mean
With Nozzle (0.25")	7.32	0.130	0.180	0.848	0.0031
	9.30	0.210	0.290	0.849	0.0042
	11.75	0.335	0.470	0.842	0.0025
	13.47	0.440	0.620	0.841	0.0043
	16.11	0.630	0.880	0.844	0.0006
			Mean	0.845	0.0029

Without Nozzle	7.32	0.130	0.185	0.836	0.0065
	9.08	0.200	0.280	0.843	0.0004
	11.66	0.330	0.460	0.845	0.0022
	13.62	0.450	0.630	0.843	0.0004
	15.59	0.590	0.820	0.846	0.0035
			Mean	0.843	0.0026

Note: Pitots must always be used in the orientation that they are calibrated in (marked F for front and B for back).

Acceptance Criteria:


The Cp of Standard Pitots must be in the range of 0.99 ±0.01.

For Stausscheibe (S-Type) Pitots refer to the measurement criteria as specified in Method 2 of the Ontario Source Testing Code. If the pitot meets these measurement requirements it is assigned a Cp of 0.84. Otherwise, calculate the absolute differences between the average pitot tube coefficient and the coefficient obtained for each of the wind tunnel settings. The average of these differences must not exceed 0.01. Otherwise, the calibration must be repeated. (Environment Canada Reference Method EPS 1/RM/8, Section 6).

ORTECH

Dry Gas Meter Calibration Using Calibrated Critical Orifice

Meter Console Information	
Meter Number	1
Meter Mill Number	A04015
Orifice Set ID	COE20999
Barometer ID	COE 20028

Calibration Conditions	
Barometric Pressure	29.68 in Hg
Theoretical Critical Vacuum	14.0 in Hg
System Leak Check	NDL @ 23" Hg
Calibration Date	July 6, 2022
Calibration Technician	Blair McIntyre
Reviewed and Accepted By	

Factors/Conversions	
Std Temp	528 °R
Std Press	29.92 in Hg
K ₁	17.647 or/in Hg


Run Time	Metering Console				Critical Orifice					
	DGM Orifice	Volume	Volume	Avg. DGM Temp	Avg. DGM Temp	Serial Number	Coefficient	Amb Temp	Amb Temp	Actual
Elapsed	DH	Initial	Final	Initial	Final		K'	Initial	Final	Vacuum
(Q)	(P _m)	(V _{mi})	(V _{mf})	(t _{mi})	(t _{mf})			(t _{smb})	(t _{smb})	
min	in H ₂ O	cubic feet	cubic feet	°F	°F			°F	°F	in Hg
10.0	0.15	77.320	80.393	75.0	78.0	UR-40	0.2352	75.2	75.2	19.0
10.0	0.30	80.393	84.756	78.0	81.0	UR-48	0.3308	75.2	75.2	18.0
10.0	0.50	84.756	90.784	81.0	85.0	UR-55	0.4520	75.2	75.2	16.0
10.0	0.90	90.784	98.646	85.0	88.0	UR-63	0.5874	75.2	75.2	11.0
10.0	1.60	29.250	39.720	74.0	78.0	UR-73	0.8107	75.2	75.2	11.0

Standardized Data				Dry Gas Meter				
Dry Gas Meter		Critical Orifice		Calibration Factor		Flowrate		
(V _{mstd})	(Q _{mstd})	(V _{crlstd})	(Q _{crlstd})	Value	Variation	Std & Corr	DH @	
cubic feet	cfm	cubic feet	cfm	(Y)	(DY)	(Q _{mstd(corr)})	0.75 SCFM	
							(DH@)	
							(DDH@)	
3.001	0.300	3.017	0.302	1.005	0.003	0.302	0.927	0.029
4.239	0.424	4.244	0.424	1.001	-0.001	0.424	0.937	0.039
5.822	0.582	5.799	0.580	0.996	-0.007	0.580	0.836	-0.061
7.552	0.755	7.536	0.754	0.998	-0.005	0.754	0.891	-0.006
10.272	1.027	10.401	1.040	1.013	0.010	1.040	0.832	-0.066
			DGMCF	1.003			0.898	DH@ Average

Individual values of DGM calibration factor (Y) must be within ± 1.5% of the average value.
 If not the calibration must be repeated. Also, the DGMCF average value (Y) must be 1.00 ± 0.05,
 otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use.
 (Environment Canada Reference Method EPS 1/RM/8, Section 6)

ORTECH

Trendicator Calibration

03 - 1005	Calibration Procedure
Omega DP116	Trendicator Type
A04015	Mill
July 5, 2022	Date
Bair McIntyre	Calibrated By
	Reviewed and Accepted By

Fluke Calibrator Output (°F)	Trendicator Display Value		Percent Difference
	Before Adjustment (°F)	After Adjustment (°F)	
32	32		0.0
70	70		0.0
100	100		0.0
200	201		-0.5
250	252		-0.8
300	302		-0.7
400	400		0.0
500	500		0.0
600	601		-0.2
700	703		-0.4
800	802		-0.3
900	903		-0.3
1000	1003		-0.3
1100	1104		-0.4
1200	1204		-0.3
1250	1254		-0.3

$$\% \text{ Difference} = \frac{\text{calibrator - after adjustment reading}}{\text{reading}} \times 100$$

calibrator

Acceptance Criteria:

Trendicator display must read within ± 1.5%, and ± 3 degrees F of the standard value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary,

and recalibrated prior to use.


(Ontario Source Testing Code, June 2010, Part C: Method ON-2, 7.5 Appendix 2E)

ORTECH

Dry Gas Meter Calibration Data

Calibration Procedure	03-J004
Meter Number	Vost 3
Date	July 18, 2022
Barometric Pressure	29.23
System Leak Check	<0.01LPM @ 19.5" Hg

MII NUMBERS	
DGM	A12010
Gasometer	A01463
Barometer	COE 20028

Calibrated By	Adam Petrossi
Signature	
Reviewed and Accepted By	

$$ft^3 = cm^3 \times 1.352 \text{ litres per cm}^3 / 28.3168 \text{ litres per ft}^3$$


$$DGMCF = \frac{Vstd \text{ ft}^3}{Vdgm \text{ ft}^3} \times \frac{Tdgm \text{ } ^\circ F + 460}{Tstd \text{ } ^\circ F + 460} \times \frac{Pbar \text{ (in. Hg)}}{(Pbar \text{ in. Hg} + DGM \text{ Pressure}/13.6)}$$

Initial	Gasometer Reading cm		Gasometer Volume ft ³	Gasometer Temperature °C	DGM Reading L		DGM Volume ft ³	DGM Average Temperature °C	DGM Pressure in. H ₂ O	DGM Outlet °C	DGM Calibration Factor	Time min.	Flow Rate lpm
	Final	Initial			Final								
55.60	40.00	15.60	0.734	23.5	68.45	89.78	0.753	31.0	1.00	31.0	0.996	15	1.4
48.50	36.40	12.10	0.569	24.0	103.11	120.36	0.609	38.0	1.00	39.0	0.976	15	1.2
49.90	36.10	13.80	0.649	24.0	137.00	156.65	0.694	43.0	1.00	43.0	0.993	15	1.3

DGMCF AVERAGE
1Lpm 0.988

Acceptance Criteria:
 Individual values of DGM calibration factor must be within ± 1.5% of the average value.
 If not the calibration must be repeated. Also, the DGMCF average value must be 1.00 ± 0.05,
 otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use.
 (Environment Canada Reference Method EPS 1/RM/8, Section 6)

ORTECH Trendicator Calibration

Calibration Procedure	03-J005
Trendicator Type	Nutech
MII	A12010
Date	July 18, 2022
Calibrated By	Adam Petrossi
Signature	
Reviewed and Accepted By	

Fluke Calibrator Output (COE 20024) (°C)	Tredicator Display Value		Percent Difference (%)
	Before Adjustment (°C)	After Adjustment (°C)	
0	0		0.0
20	20		0.0
50	50		0.0
100	101		-1.0
150	151		-0.7
200	200		0.0
300	300		0.0
400	399		0.3
500	499		0.2
600	599		0.2

$$\% \text{ Difference} = \frac{(\text{micromite} - \text{after adjustment reading}) \times 100}{\text{micromite}}$$

Acceptance Criteria:

Trendicator display must read within $\pm 1.5\%$ of the micromite value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use. (MOE Source Testing Code, Version #2, Method 5)

ORTECH

Dry Gas Meter Calibration Data

Calibration Procedure	03-J004	03-J004
Meter Number	Vost 2	
Date	August 11, 2022	
Barometric Pressure	29.53	
System Leak Check	<0.01 Lpm @ "Hg	

MII NUMBERS	
DGM	A10117
Gasometer	A01463
Barometer	COE20028

Calibrated By	Blair McIntyre
Signature	
Reviewed and Accepted By	

$ft^3 = cm^3 \times 1.352$ litres per cm³ / 28.3168 litres per ft³

$$DGMCf = \frac{V_{std} \text{ ft}^3}{V_{dgm} \text{ ft}^3} \times \frac{T_{dgm} \text{ } ^\circ\text{F} + 460}{T_{std} \text{ } ^\circ\text{F} + 460} \times \frac{P_{bar} \text{ (in. Hg)}}{(P_{bar} \text{ in. Hg} + DGMPressure/13.6)}$$

Gasometer Reading		Gasometer Volume	Gasometer Temperature	DGM Reading		DGM Volume	DGM Average Temperature	DGM Pressure	DGM Outlet	DGM Calibration	Time	Flow Rate
cm	cm			L	Initial							
Initial	Final	cm	°C	Initial	Final	ft ³	°C	in. H ₂ O	°C	Factor	min.	lpm
66.80	51.80	15.00	23.0	14.360	34.440	0.709	32.0	6.0	32.0	1.010	10	2.0
51.80	36.80	15.00	23.0	34.440	54.240	0.699	33.0	6.0	33.0	1.028	10	2.0
36.80	21.70	15.10	23.0	54.240	74.100	0.701	33.0	6.0	33.0	1.032	10	2.0
35.90	28.40	7.50	23.0	117.400	127.340	0.351	32.0	2.5	32.0	1.029	10	1.0
51.20	43.50	7.70	23.0	96.800	107.150	0.366	32.0	2.5	32.0	1.015	10	1.0
43.50	35.90	7.60	23.0	107.150	117.400	0.362	32.0	2.5	32.0	1.011	10	1.0


Acceptance Criteria:

Individual values of DGM calibration factor must be within ± 1.5% of the average value. If not the calibration must be repeated. Also, the DGMCf average value must be 1.00 ± 0.05, otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use. (Environment Canada Reference Method EPS 1/RM/8, Section 6)

DGMCf AVERAGE

2 Lpm	1.023
1 Lpm	1.018

ORTECH Trendicator Calibration

Calibration Procedure	03-J005
Trendicator Type	Nutech
MII	A10117
Date	August 11, 2022
Calibrated By	Blair McIntyre
Signature	
Reviewed and Accepted By	

Fluke Calibrator Output (COE 20024) (°C)	Tredicator Display Value		Percent Difference (%)
	Before Adjustment (°C)	After Adjustment (°C)	
0	0		0.0
20	20		0.0
50	50		0.0
100	102		-2.0
150	151		-0.7
200	200		0.0
300	300		0.0
400	399		0.3
500	499		0.2
600	599		0.2

$$\% \text{ Difference} = \frac{(\text{micromite} - \text{after adjustment reading}) \times 100}{\text{micromite}}$$

Acceptance Criteria:



Trendicator display must read within $\pm 1.5\%$ of the micromite value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use. (MOE Source Testing Code, Version #2, Method 5)

ORTECH

Dry Gas Meter Calibration Data

Calibration Procedure	03-J004
Meter Number	Vost 4
Date	August 15, 2022
Barometric Pressure	29.56
System Leak Check	NDL @ 17.5 "Hg

MII NUMBERS	
DGM	A11542
Gasometer	A01463
Barometer	COE 20028

Calibrated By	Blair McIntyre
Signature	
Reviewed and Accepted By	

$\text{ft}^3 = \text{cm}^3 \times 1.332 \text{ litres per cm}^3 / 28.3168 \text{ litres per ft}^3$

$$\text{DGMCF} = \frac{V_{\text{std}} \text{ ft}^3}{V_{\text{dgm}} \text{ ft}^3} \times \frac{T_{\text{dgm}} \text{ } ^\circ\text{F} + 460}{T_{\text{std}} \text{ } ^\circ\text{F} + 460} \times \frac{\text{Pbar (in. Hg)}}{\text{(Pbar in. Hg} + \text{DGM Pressure/13.6)}}$$

Initial	Final	Gasometer Reading		Gasometer Volume	Gasometer Temperature	DGM Reading		DGM Volume	DGM Average Temperature	DGM Pressure	DGM Outlet	DGM Calibration	Time	Flow Rate
		cm	cm			L	Final							
48.40	33.60	14.80	16.24	0.696	23.0	36.05	36.05	0.700	28.0	2.0	27.0	1.007	10	2.0
33.60	18.60	15.00	36.05	0.706	23.0	56.21	56.21	0.712	30.0	2.0	30.0	1.009	10	2.0
64.50	49.60	14.90	56.21	0.701	23.0	76.34	76.34	0.711	32.0	2.0	32.0	1.011	10	2.0
56.20	49.00	7.20	13.08	0.339	23.0	23.18	23.18	0.357	33.0	0.8	33.0	0.980	10	1.0
34.40	27.10	7.30	43.31	0.343	23.0	53.45	53.45	0.358	33.0	0.8	33.0	0.989	10	1.0
41.60	34.40	7.20	33.17	0.339	23.0	43.31	43.31	0.358	33.0	0.8	33.0	0.976	10	1.0

Acceptance Criteria:



Individual values of DGM calibration factor must be within $\pm 1.5\%$ of the average value. If not the calibration must be repeated. Also, the DGMCF average value must be 1.00 ± 0.05 , otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use. (Environment Canada Reference Method EPS 1/RM/8, Section 6)

DGMCF AVERAGE

2Lpm	1.009
1Lpm	0.982

ORTECH

Trendicator Calibration

Calibration Procedure	03-J005
Trendicator Type	Nutech
MII	A11542
Date	August 15, 2022
Calibrated By	Blair McIntyre
Signature	
Reviewed and Accepted By	

Fluke Calibrator Output (COE 20024) (°C)	Tredicator Display Value		Percent Difference (%)
	Before Adjustment (°C)	After Adjustment (°C)	
0	0		0.0
20	20		0.0
50	50		0.0
100	101		-1.0
150	150		0.0
200	199		0.5
300	299		0.3
400	399		0.3
500	498		0.4
600	599		0.2

$$\% \text{ Difference} = \frac{(\text{micromite} - \text{after adjustment reading}) \times 100}{\text{micromite}}$$


Acceptance Criteria:

Trendicator display must read within $\pm 1.5\%$ of the micromite value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use. (MOE Source Testing Code, Version #2, Method 5)

ORTECH

Dry Gas Meter Calibration Using Calibrated Critical Orifice

Meter Console Information	
Meter Number	Team 1
Meter MII Number	COE 20094
Orifice Set ID	COE20999
Barometer ID	COE 20028

Calibration Conditions	
Barometric Pressure	29.53 in Hg
Theoretical Critical Vacuum	13.9 in Hg
System Leak Check	NDL @ 16.5" Hg
Calibration Date	June 7, 2022
Calibration Technician	Bhair McInyre
Reviewed and Accepted By	

Factors/Conversions	
Std Temp	528 °R
Std Press	29.92 in Hg
K ₁	17.647 or/in Hg

Run Time	Metering Console				Calibration Data				Critical Orifice		
	DGM Orifice DH (P _m) in H ₂ O	Volume Initial (V _{mi}) cubic feet	Volume Final (V _{mf}) cubic feet	Avg. DGM Temp Initial (t _{mi}) °F	Avg. DGM Temp Final (t _{mf}) °F	Seral Number	Coefficient K'	Amb Temp Initial (t _{amb}) °F	Amb Temp Final (t _{amb}) °F	Actual Vacuum in Hg	
10.0	0.29	0.735	3.900	71.5	71.5	UR-40	0.2352	72.5	72.5	22.0	
10.0	0.58	3.900	8.320	71.5	72.5	UR-48	0.3308	72.5	72.5	20.5	
10.0	1.20	8.320	14.390	72.5	72.5	UR-55	0.4520	72.5	72.5	19.0	
10.0	2.00	14.390	22.255	72.5	72.5	UR-63	0.5874	72.5	72.5	17.0	
10.0	3.70	22.280	33.040	72.5	73.5	UR-73	0.8107	72.5	72.5	14.0	

Standardized Data		Dry Gas Meter			
Dry Gas Meter (V _{m(Std)}) cubic feet	Q _{m(Std)} cfm	Critical Orifice (V _{cr(Std)}) cubic feet		Calibration Factor	
		(V _{cr(Std)}) cfm	(Q _{cr(Std)}) cfm	Value (Y)	Variation (DY)
3.105	0.311	3.010	0.301	0.969	-0.004
4.336	0.434	4.233	0.423	0.976	0.003
5.958	0.596	5.784	0.578	0.971	-0.002
7.735	0.774	7.517	0.752	0.972	-0.001
10.617	1.062	10.374	1.037	0.977	0.004
			DGMCF	0.973	
				Flowrate Std & Corr (Q _{m(Std)/corr}) cfm	DH @ 0.75 SCFM (DH@) in H ₂ O
				0.301	1.801
				0.423	1.821
				0.578	2.018
				0.752	1.991
				1.037	1.934
				1.907	DH@ Average
					0.026
					0.107
					-0.087
					0.110
					0.084

Individual values of DGM calibration factor (Y) must be within ± 1.5% of the average value. If not the calibration must be repeated. Also, the DGMCF average value (Y) must be 1.00 ± 0.05, otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use. (Environment Canada Reference Method EPS 1/RM/8, Section 6)

ORTECH
Trendicator Calibration

Calibration Procedure	03 - J005
Trendicator Type	Omega DP118
MII	COE 20094
Date	June 7, 2022
Calibrated By	Blair McIntyre
Reviewed and Accepted By	

Fluke Calibrator Output (COE 20024) (°F)	Tredicator Display Value		Percent Difference (%)
	Before Adjustment (°F)	After Adjustment (°F)	
32	32		0.0
70	69		1.4
100	99		1.0
200	201		-0.5
250	252		-0.8
300	302		-0.7
400	401		-0.3
500	500		0.0
600	601		-0.2
700	700		0.0
800	800		0.0
900	900		0.0
1000	1001		-0.1
1100	1102		-0.2
1200	1202		-0.2
1250	1251		-0.1



$$\% \text{ Difference} = \frac{(\text{calibrator} - \text{after adjustment reading}) \times 100}{\text{calibrator}}$$

Acceptance Criteria:

Trendicator display must read within $\pm 1.5\%$, and ± 3 degrees F of the standard value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use.

(Ontario Source Testing Code, June 2010, Part C: Method ON-2, 7.5 Appendix 2E)

ORTECH
Manometer Calibration Data

Date	June 7, 2022	Calibrated By	Blair McIntyre
Manometer Number	Team 1	Signature	
Manometer MII Number	COE 20094	Reviewed/Accepted By	
Calibrated Against	Dual 3		
MII Number	COE 20008		
Calibration Procedure	03 - J010		

Front Leg

Manometer Scale	Manometer Reading "H ₂ O		Reference Manometer Reading "H ₂ O	Percent Difference %
	Before Adjustment	After Adjustment		
"H ₂ O				
	0.300		0.310	3.2
0-1.0	0.600		0.600	0.0
	0.900		0.910	1.1
	3.00		3.00	0.0
1.0-10.0	6.00		6.02	0.3
	9.00		9.01	0.1

$$\text{Percent Difference} = \frac{(\text{Ref. Manometer} - \text{Instrument Reading})}{\text{Ref. Manometer}} \times 100$$

Acceptance Criteria:

The manometer being calibrated must be within $\pm 5.0\%$ of the Standard value at each reading. Otherwise, the manometer must be repaired and/or adjusted as necessary and recalibrated prior to use. Manometers must be capable of measuring velocity pressure to within 0.005 "H₂O on the 0 to 1 inch scale, and 0.05 "H₂O on the 1 to 10 inch scales.
(Environment Canada Reference Method 1/RM/8, Section 2)

APPENDIX 14

**Pre-Test Plan Acceptance Letter
(3 pages)**

Ministry of the Environment,
Conservation and Parks
Technical Assessment and
Standards Development Branch
40 St. Clair Avenue West
7th Floor
Toronto ON M4V 1M2
Phone: 416.327.5519
Fax: 416.327.2936

Ministère de l'Environnement, de
la Protection de la nature et des Parcs
Direction des évaluations techniques et de
l'élaboration des normes
40, avenue St. Clair Ouest
7^e étage
Toronto, ON M4V 1M2
Tél: 416 .327.5519
Télé: 416. 327.2936



Via email: cbelore@oretech.ca

TSS File No.: SWR:SA: 110093:22

2022/08/02

Chris Belore
ORTECH

Dear Mr. Belore:

Subject: Pre-test plan review for source testing to be conducted at Clean Harbors

We received your pre-test plan (Project #22196), dated July 22, 2022, prepared on behalf of Clean Harbors and referring to source testing to be conducted at their facility in Corunna, Ontario.

Testing is being repeated due to elevated mercury concentrations at the Incinerator Exhaust Stack.

Sources to be tested:

- Pre PAC-Injection
- Post Pac-Injection (2 locations)

Target contaminants:

- Mercury (Hg)

Reference methods to be used:

Stack gas parameters	Ontario Source Testing Code (OSTC) Methods ON-1-ON-4
Hg	US EPA Method 29
Hg	US EPA Method 30B

Testing strategy

Clean Harbors committed to repeat the mercury testing as soon as practical after the July 2022 maintenance shutdown. During the shutdown the facility is replacing the Incinerator Exhaust Stack and performing maintenance on the powdered activated carbon (PAC) injection system and the baghouse.

Mercury testing will be conducted at the following locations:

- Pre PAC-Injection, after the Spray Dryer, and just before PAC injection point
- Post PAC-Injection after the ID fan on the breaching to the exhaust stack
- Post PAC-Injection at the sample ports located on the stack platform

US EPA Method 29 will be used at the incinerator exhaust stack. Two tests will be conducted concurrently with three of the US EPA Method 30B tests at the breaching location.

US EPA Method 30B will be used at the breaching to the incinerator exhaust stack. Six pairs of sampling tubes will be collected.

Mercury testing will also be conducted prior to the PAC injection to determine the mercury removal efficiency. A single sample port, at a non-ideal location will be tested with either a modified US EPA Method 30B or modified US EPA Method 29 sampling train.

Liquid waste (rich, lean, alkaline and emulsion) samples will be collected and composited by Clean Harbors personnel based on US EPA Method S004 (Tap) in SW-846, 3rd Edition. A sample will be collected every thirty minutes during the stack testing periods and placed in a large, chilled container for compositing. Clean Harbors personnel will also collect a sample of baghouse dust every thirty minutes during the stack testing periods. These samples will be analyzed in-house by the Clean Harbors laboratory for mercury.

Operating conditions:

Recorded data will include, but not be limited to:

- waste feed stream analysis for mercury (rich, lean, emulsion, alkaline and leachate streams)
- incinerator feed rates (rich, lean, emulsion, alkaline and leachate streams)
- volumetric flowrates (TDU, secondary air and stack gases)
- PAC feed rate
- temperatures (primary zone, secondary zone, spray dryer inlet and outlet)
- pressures (spray dryer outlet, baghouse differential)
- combustion gas stack concentrations (CO, HCl, CO₂, H₂O, THC, O₂, SO₂)
- stack gas opacity

The pre-test plan is approved as the proposed reference methodologies/sampling strategies are acceptable.

As per our conversation over the phone, the testing program is anticipated to begin the week of August 15, 2022. If any changes occur please notify both the Sarnia Area Office and the Source Testing Group week of the 15th.

Just a reminder that the source testing report is required to be submitted in electronic format to the source testing group at sourcetesting@ontario.ca.

If you have any questions with regards to this assessment, I can be reached by phone at 437-995-2835 or by email at sourcetesting@ontario.ca

Sincerely,



Caitlyn Ruddy
Source Assessment Specialist
Technology Standards Section

cc: F. Wagner- Clean Harbors (frank.wagner@safety-kleen.com)
N. Does- Sarnia District Office (nicole.does@ontario.ca)
S. Mercer- EAPD (steve.mercer@ontario.ca)
J. McKerrall –TSS (jeffrey.mckerrall@ontario.ca)
B. Fullerton- TSS (bill.fullerton@ontario.ca)

File AQ-02 (Clean Harbors- Incinerator)

Doc.Mgmt # 5AF070070

APPENDIX 15

**ORTECH CEM Calibration Data
(15 pages)**

Total Hydrocarbon Reference Method 25A Calibration Data Sheet

Method 25A:SOP Number 95-T62-SP001

Project Number:	22196	Date:	August 17, 2022
Company:	Clean Harbors	Operator:	J. Grollman
Location:	Sarnia	Analyzer ID	VIG 20
Test Location:	Incinerator	Test	1

THC Full Scale Setting	100
Zero Gas (ppm)	<0.1 ppm
Low Gas Value (ppm)	20-35 % full scale setting
Mid Gas Value (ppm)	45-55 % full scale setting
High Gas Value (ppm)	80-90 % full scale setting

Perform analyzer calibration as per manufacturers instructions.

Calculate the linearity factor "C" based on the zero and high gas values. Based on the calculated linearity, predict the analyzer response for low and mid values (D3 and D4). Calculate calibration error with the low and mid (B3 and B4) gasses.

	Cal.Gas Value (A)	Initial Analyzer Response (B)	Linearity $(B2-B1)/(A2-A1)$	Predicted Response (A X C)	Calibration Error % $((B)-(D))/AX100$
Zero	0 <small>A1</small>	0.05 <small>B1</small>	1.006 <small>c</small>		
High	89.4 <small>A2</small>	90.03 <small>B2</small>			
Mid	44.7 <small>A4</small>	44.5 <small>B4</small>		45.0 <small>D4</small>	-1.1 <small>E4</small>
Low	22.35 <small>A3</small>	22.42 <small>B3</small>		22.5 <small>D3</small>	-0.3 <small>E3</small>

Criteria +/-5%

Note: If the calibration Error (E3 and E4) are greater than 5%, repeat the procedure until values are acceptable.

Perform test. At the completion of the test or hourly; Calculate the calibration drift as a percent of full scale value.

Introduce the zero and mid level gases at the probe and record data as the system final response.

	System Initial Response (F)	System Final Response (G)	Calibration Drift $(G-F)/span*100$
Zero	0.05	0	0.05
Mid	44.5	44.4	0.1

Criteria 3%

Calculate system response time by introducing zero gas to the probe, record time to reach 95% of calibration gas value.

Repeat with upscale gas. Perform three runs and calculate average of the runs.

	Zero Response Time (seconds)		Upscale Response Time (seconds)
Run 1	40		45
Run 2	40		45
Run 3	40		45
Average	40		45

Total Hydrocarbon Reference Method 25A Calibration Data Sheet

Method 25A:SOP Number 95-T62-SP001

Project Number:	22196	Date:	August 17, 2022
Company:	Clean Harbors	Operator:	J. Grollman
Location:	Sarnia	Analyzer ID	VIG 20
Test Location:	Incinerator	Test	2

THC Full Scale Setting	100
Zero Gas (ppm)	<0.1 ppm
Low Gas Value (ppm)	20-35 % full scale setting
Mid Gas Value (ppm)	45-55 % full scale setting
High Gas Value (ppm)	80-90 % full scale setting

Perform analyzer calibration as per manufacturers instructions.

Calculate the linearity factor "C" based on the zero and high gas values. Based on the calculated linearity, predict the analyzer response for low and mid values (D3 and D4). Calculate calibration error with the low and mid (B3 and B4) gasses.

	Cal.Gas Value (A)	Initial Analyzer Response (B)	Linearity $(B2-B1)/(A2-A1)$	Predicted Response (A X C)	Calibration Error % $((B)-(D))/AX100$
Zero	0 <small>A1</small>	0.05 <small>B1</small>	1.006 <small>C</small>		
High	89.4 <small>A2</small>	90.03 <small>B2</small>			
Mid	44.7 <small>A4</small>	44.5 <small>B4</small>		45.0 <small>D4</small>	-1.1 <small>E4</small>
Low	22.35 <small>A3</small>	22.42 <small>B3</small>		22.5 <small>D3</small>	-0.3 <small>E3</small>

Criteria +/-5%

Note: If the calibration Error (E3 and E4) are greater than 5%, repeat the procedure until values are acceptable.

Perform test. At the completion of the test or hourly; Calculate the calibration drift as a percent of full scale value.

Introduce the zero and mid level gases at the probe and record data as the system final response.

	System Initial Response (F)	System Final Response (G)	Calibration Drift $(G-F)/span*100$
Zero	0	0	0
Mid	44.38	43.7	0.7

Criteria 3%

Calculate system response time by introducing zero gas to the probe, record time to reach 95% of calibration gas value.

Repeat with upscale gas. Perform three runs and calculate average of the runs.

	Zero Response Time (seconds)		Upscale Response Time (seconds)
Run 1	40		45
Run 2	40		45
Run 3	40		45
Average	40		45

Total Hydrocarbon Reference Method 25A Calibration Data Sheet

Method 25A:SOP Number 95-T62-SP001

Project Number:	22196	Date:	August 17, 2022
Company:	Clean Harbors	Operator:	J. Grollman
Location:	Sarnia	Analyzer ID	VIG 20
Test Location:	Incinerator	Test	3

THC Full Scale Setting	100
Zero Gas (ppm)	<0.1 ppm
Low Gas Value (ppm)	20-35 % full scale setting
Mid Gas Value (ppm)	45-55 % full scale setting
High Gas Value (ppm)	80-90 % full scale setting

Perform analyzer calibration as per manufacturers instructions.

Calculate the linearity factor "C" based on the zero and high gas values. Based on the calculated linearity, predict the analyzer response for low and mid values (D3 and D4). Calculate calibration error with the low and mid (B3 and B4) gasses.

	Cal. Gas Value (A)	Initial Analyzer Response (B)	Linearity $(B2-B1)/(A2-A1)$	Predicted Response (A X C)	Calibration Error % $((B)-(D))/AX100$
Zero	0 <small>A1</small>	0.05 <small>B1</small>	1.006 <small>c</small>		
High	89.4 <small>A2</small>	90.03 <small>B2</small>			
Mid	44.7 <small>A4</small>	44.5 <small>B4</small>		45.0 <small>D4</small>	-1.1 <small>E4</small>
Low	22.35 <small>A3</small>	22.42 <small>B3</small>		22.5 <small>D3</small>	-0.3 <small>E3</small>

Criteria +/-5%

Note: If the calibration Error (E3 and E4) are greater than 5%, repeat the procedure until values are acceptable.

Perform test. At the completion of the test or hourly; Calculate the calibration drift as a percent of full scale value.

Introduce the zero and mid level gases at the probe and record data as the system final response.

	System Initial Response (F)	System Final Response (G)	Calibration Drift $(G-F)/span*100$
Zero	0	0	0
Mid	43.7	43.6	0.1

Criteria 3%

Calculate system response time by introducing zero gas to the probe, record time to reach 95% of calibration gas value.

Repeat with upscale gas. Perform three runs and calculate average of the runs.

	Zero Response Time (seconds)		Upscale Response Time (seconds)
Run 1	40		45
Run 2	40		45
Run 3	40		45
Average	40		45

Total Hydrocarbon Reference Method 25A Calibration Data Sheet

Method 25A:SOP Number 95-T62-SP001

Project Number:	22196	Date:	August 17, 2022
Company:	Clean Harbors	Operator:	J. Grollman
Location:	Sarnia	Analyzer ID	VIG 20
Test Location:	Incinerator	Test	4

THC Full Scale Setting	100
Zero Gas (ppm)	<0.1 ppm
Low Gas Value (ppm)	20-35 % full scale setting
Mid Gas Value (ppm)	45-55 % full scale setting
High Gas Value (ppm)	80-90 % full scale setting

Perform analyzer calibration as per manufacturers instructions.

Calculate the linearity factor "C" based on the zero and high gas values. Based on the calculated linearity, predict the analyzer response for low and mid values (D3 and D4). Calculate calibration error with the low and mid (B3 and B4) gasses.

	Cal. Gas Value (A)	Initial Analyzer Response (B)	Linearity (B2-B1)/(A2-A1)	Predicted Response (A X C)	Calibration Error % ((B)-(D))/AX100
Zero	0 <small>A1</small>	0.05 <small>B1</small>	1.006 <small>C</small>		
High	89.4 <small>A2</small>	90.03 <small>B2</small>			
Mid	44.7 <small>A4</small>	44.5 <small>B4</small>		45.0 <small>D4</small>	-1.1 <small>E4</small>
Low	22.35 <small>A3</small>	22.42 <small>B3</small>		22.5 <small>D3</small>	-0.3 <small>E3</small>

Criteria +/-5%

Note: If the calibration Error (E3 and E4) are greater than 5%, repeat the procedure until values are acceptable.

Perform test. At the completion of the test or hourly; Calculate the calibration drift as a percent of full scale value.

Introduce the zero and mid level gases at the probe and record data as the system final response.

	System Initial Response (F)	System Final Response (G)	Calibration Drift (G-F)/span*100
Zero	0	0	0
Mid	43.6	43.0	0.6

Criteria 3%

Calculate system response time by introducing zero gas to the probe, record time to reach 95% of calibration gas value.

Repeat with upscale gas. Perform three runs and calculate average of the runs.

	Zero Response Time (seconds)		Upscale Response Time (seconds)
Run 1	40		45
Run 2	40		45
Run 3	40		45
Average	40		45

Clean Harbors
 Mobile Source Monitoring Laboratory # 1
 Daily Analyzer Calibration Evaluation
 22196
 August 17, 2022
 Test 1 Final Calculations (Stack)

Analyzer		O2	CO2	SO2	CO	NO	NOx
MII Number/Serial Number		COE 20060	COE 20060	COE 20052	COE 20101		
Model		Siemens Ultramat 23	Siemens Ultramat 23	Ametek 922	Siemens Ultramat 23	CAI CLD 700 NOX	
Range		25	25	250	100	250	250
Actual Cylinder Value	High	23.02	23.29	225.7	91.05	225.6	225.6
	Mid.	11.51	11.65	112.85	45.53	112.8	112.8
	Zero	0.00	0.00	0	0	0	0

Analyzer Initial Calibration	Zero	0.00	0.00	0	0.0	0.0	0.0
	Mid	11.40	11.31	115	45.0	111.6	111.6
	High	22.99	23.30	225.8	91.4	225.6	226.3
System Initial Calibration	Zero	0.00	0.17	0	0.0	0.1	0.1
	Upscale	11.45	11.29	112	44.8	111.3	111.7
System Final Calibration	Zero	0.15	0.20	0.8	0.0	0.4	0.4
	Upscale	11.41	11.33	109.3	46.1	113.4	114.7

Calibration Error Results

Analyzer Calibration Error = (Measured Concentration of Cal Gas in Direct Mode - Manufacturer Certified Cal Gas Concentration)/Analyzer Range)*100

Analyzer		O2	CO2	SO2	CO	NO	NOx
Analyzer Span Range		25.00	25.00	250	100	250	250
Calibration Error	Zero %	0.00	0.00	0.00	0.00	0.00	0.00
	Mid %	0.44	1.36	0.86	0.53	0.48	0.48
	High %	0.12	0.04	0.04	0.35	0.00	0.28
Acceptable Limits of Span		+2%	+2%	+2%	+2%	+2%	+2%

Error Results **PASS** **PASS** **PASS** **PASS** **PASS** **PASS**

System Drift

Drift Calculation = | System Bias_{final} - System Bias_{initial} |

Analyzer		O2	CO2	SO2	CO	NO	NOx
Span		25.00	25.00	250	100	250	250
Initial System Bias	Zero	0.00	0.68	0.00	0.00	0.02	0.03
	Upscale	0.20	-0.08	-1.20	-0.2	-0.1	0.0
Final System Bias	Zero	0.60	0.80	0.80	0.0	0.2	0.2
	Upscale	0.04	0.08	-2.28	1.1	0.7	1.2

System Zero Drift	%	0.60	0.12	0.80	0.00	0.14	0.13
System Cal Drift	%	0.16	0.16	1.08	1.27	0.84	1.20
Acceptable Limits of Span		+ - 3 %	+ - 3 %	+ - 3 %	+ - 3 %	+ - 3 %	+ - 3 %

Drift Result **PASS** **PASS** **PASS** **PASS** **PASS** **PASS**

System Calibration Bias

System Bias Calculation = ((Measured Concentration of Cal Gas in System Calibration Mode - Measured Concentration of Cal Gas in Direct Mode)/Analyzer Range)* 100

Analyzer		O2	CO2	SO2	CO	NO	Nox
Analyzer Full Scale Span		25	25	250	100	250	250
Analyzer Initial	Zero	0.00	0.00	0.00	0.0	0.0	0.0
	Upscale	11.40	11.31	115.00	45.0	111.6	111.6
System Initial	Zero	0.00	0.17	0.00	0.0	0.1	0.1
	Upscale	11.45	11.29	112.00	44.8	111.3	111.7
Analyzer Final	Zero	0.00	0.00	0.00	0.0	0.0	0.0
	Upscale	0.00	0.00	0.00	0.0	0.0	0.0
System Final	Zero	0.15	0.20	0.80	0.0	0.4	0.4
	Upscale	11.41	11.33	109.30	46.1	113.4	114.7

Initial System Bias	Zero %	0.00	0.68	0.00	0.00	0.02	0.03
	Upscale %	0.20	-0.08	-1.20	-0.22	-0.12	0.04
Final System Bias	Zero %	0.60	0.80	0.80	0.00	0.16	0.16
	Upscale %	0.04	0.08	-2.28	1.05	0.72	1.24
Acceptable Limits of Span		+ - 5 %	+ - 5 %	+ - 5 %	+ - 5 %	+ - 5 %	+ - 5 %

Bias Results **PASS** **PASS** **PASS** **PASS** **PASS** **PASS**

Clean Harbors
 Mobile Source Monitoring Laboratory # 1
 Daily Analyzer Calibration Evaluation
 22196
 August 17, 2022
 Test 2 Final Calculations (Stack)

Analyzer		O2	CO2	SO2	CO	NO	NOx
MI Number/Serial Number		COE 20060	COE 20060	COE 20052	COE 20101		
Model		Siemens Ultramat 23	Siemens Ultramat 23	Ametek 922	Siemens Ultramat 23	CAI CLD 700 NOX	
Range		25	25	250	100	250	250
Actual Cylinder Value	High	23.02	23.29	225.7	91.05	225.6	225.6
	Mid.	11.51	11.65	112.85	45.53	112.8	112.8
	Zero	0.00	0.00	0	0	0	0

Analyzer Initial Calibration	Zero	0.00	0.00	0	0.0	0.0	0.0
	Mid	11.40	11.31	115	45.0	111.6	111.6
	High	22.99	23.30	225.8	91.4	225.6	226.3
System Initial Calibration	Zero	0.15	0.20	0.8	0.0	0.4	0.4
	Upscale	11.41	11.33	109.3	46.1	113.4	114.7
System Final Calibration	Zero	0.18	0.10	0.8	0.7	0.5	0.5
	Upscale	11.39	11.40	113.4	45.0	112.2	113.8

Calibration Error Results

Analyzer Calibration Error = (Measured Concentration of Cal Gas in Direct Mode - Manufacturer Certified Cal Gas Concentration)/Analyzer Range)*100

Analyzer		O2	CO2	SO2	CO	NO	NOx
Analyzer Span Range		25.00	25.00	250	100	250	250
Calibration Error	Zero %	0.00	0.00	0.00	0.00	0.00	0.00
	Mid %	0.44	1.36	0.86	0.53	0.48	0.48
	High %	0.12	0.04	0.04	0.35	0.00	0.28
Acceptable Limits of Span		+2%	+2%	+2%	+2%	+2%	+2%

Error Results PASS PASS PASS PASS PASS PASS

System Drift

Drift Calculation = | System Bias_{final} - System Bias_{initial} |

Analyzer		O2	CO2	SO2	CO	NO	NOx
Span		25.00	25.00	250	100	250	250
Initial System Bias	Zero	0.60	0.80	0.32	0.00	0.16	0.16
	Upscale	0.04	0.08	-2.28	1.1	0.7	1.2
Final System Bias	Zero	0.72	0.40	0.80	0.7	0.2	0.2
	Upscale	-0.04	0.36	-0.64	0.0	0.2	0.9
System Zero Drift	%	0.12	0.40	0.48	0.70	0.04	0.04
System Cal Drift	%	0.08	0.28	1.64	1.05	0.48	0.36
Acceptable Limits of Span		+ 3 %	+ 3 %	+ 3 %	+ 3 %	+ 3 %	+ 3 %

Drift Result PASS PASS PASS PASS PASS PASS

System Calibration Bias

System Bias Calculation = ((Measured Concentration of Cal Gas in System Calibration Mode - Measured Concentration of Cal Gas in Direct Mode)/Analyzer Range))* 100

Analyzer		O2	CO2	SO2	CO	NO	Nox
Analyzer Full Scale Span		25	25	250	100	250	250
Analyzer Initial	Zero	0.00	0.00	0.00	0.0	0.0	0.0
	Upscale	11.40	11.31	115.00	45.0	111.6	111.6
System Initial	Zero	0.15	0.20	0.80	0.0	0.4	0.4
	Upscale	11.41	11.33	109.30	46.1	113.4	114.7
Analyzer Final	Zero	0.00	0.00	0.00	0.0	0.0	0.0
	Upscale	0.00	0.00	0.00	0.0	0.0	0.0
System Final	Zero	0.18	0.10	0.80	0.7	0.5	0.5
	Upscale	11.39	11.40	113.40	45.0	112.2	113.8
Initial System Bias	Zero %	0.60	0.80	0.32	0.00	0.16	0.16
	Upscale %	0.04	0.08	-2.28	1.05	0.72	1.24
Final System Bias	Zero %	0.72	0.40	0.80	0.70	0.20	0.20
	Upscale %	-0.04	0.36	-0.64	0.00	0.24	0.88
Acceptable Limits of Span		+ 5 %	+ 5 %	+ 5 %	+ 5 %	+ 5 %	+ 5 %

Bias Results PASS PASS PASS PASS PASS PASS

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Oxygen
Location	Sarnia, ON	Analyzer ID.	Siemens Ultramat 23
Project No.	22196	Analyzer Span Setting	25

Span Gas Concentration	11.65
------------------------	-------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	45	55
2	45	55
3	45	55

System Response Time* 55 Seconds
 Average Time 50 Seconds

* Reported as Greatest Value of all Response Time Checks
 Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	11.29
2	11.33
3	11.4
4	11.35
5	11.29
Mean	11.33
Standard Deviation (SD)	0.05
% RSD Criteria <3%	0.41

% RSD = SD/Mean X 100

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Carbon Dioxide
Location	Sarnia, ON	Analyzer ID.	Siemens Ultramat 23
Project No.	22196	Analyzer Span Setting	25

Span Gas Concentration	11.65
------------------------	-------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	50	55
2	50	55
3	50	55

System Response Time* 55 Seconds
 Average Time 53 Seconds

* Reported as Greatest Value of all Response Time Checks
 Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	11.29
2	11.33
3	11.4
4	11.35
5	11.29
Mean	11.33
Standard Deviation (SD)	0.05
% RSD Criteria <3%	0.41

% RSD = SD/Mean X 100

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Sulphur Dioxide
Location	Sarnia, ON	Analyzer ID.	Ametek 922
Project No.	22196	Analyzer Span Setting	250

Span Gas Concentration	112.85
------------------------	--------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	80	80
2	80	80
3	80	80

System Response Time* 80 Seconds
 Average Time 80 Seconds

* Reported as Greatest Value of all Response Time Checks
 Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	112
2	109.3
3	113.4
4	113.4
5	115.13
Mean	113
Standard Deviation (SD)	2.17
% RSD Criteria <3%	1.93

% RSD = SD/Mean X 100

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Carbon Monoxide
Location	Sarnia, ON	Analyzer ID.	Siemens Ultramat 23
Project No.	22196	Analyzer Span Setting	100

Span Gas Concentration	45.53
------------------------	-------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	40	45
2	40	45
3	40	45

System Response Time* 45 Seconds
 Average Time 43 Seconds

* Reported as Greatest Value of all Response Time Checks

Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	44.78
2	46.05
3	45
4	47
5	47
Mean	46
Standard Deviation (SD)	1.06
% RSD Criteria <3%	2.30

% RSD = SD/Mean X 100

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Nitric Oxide
Location	Sarnia, ON	Analyzer ID.	CAI CLD 700 NOX
Project No.	22196	Analyzer Span Setting	226

Span Gas Concentration	112.8
-------------------------------	-------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	60	60
2	60	60
3	60	60

System Response Time* 60 Seconds
 Average Time 60 Seconds

* Reported as Greatest Value of all Response Time Checks

Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	111.3
2	113.4
3	112.2
4	110.25
5	110.5
Mean	112
Standard Deviation (SD)	1.29
% RSD Criteria <3%	1.16

% RSD = SD/Mean X 100

RESPONSE TIME CHECK

Client	Clean Harbors	Analyzer Type	Nitrogen Oxides
Location	Sarnia, ON	Analyzer ID.	CAI CLD 700 NOX
Project No.	22196	Analyzer Span Setting	250

Span Gas Concentration	112.8
------------------------	-------

Response Time Test No.	Upscale Response Time (seconds)	Downscale Response Time (seconds)
1	60	60
2	60	60
3	60	60

System Response Time* 60 Seconds

Average Time 60 Seconds

* Reported as Greatest Value of all Response Time Checks

Criteria: < 200 seconds for a 95% response to a step change in concentration of gas at the probe exit

REPRODUCIBILITY CHECKS

Run	Analyzer Value
1	111.7
2	114.7
3	113.8
4	111.19
5	112.06
Mean	113
Standard Deviation (SD)	1.49
% RSD Criteria <3%	1.32

% RSD = SD/Mean X 100

**METHOD 7E - Determination of Nitrogen Oxides Emissions
From Stationary Sources**
(Instrumental Analyzer Procedure)
NO₂ to NO Conversion Efficiency Test Procedure

Client:	Clean Harbors	22196
Date:	August 17, 2022	Location: Sarnia

Certified Concentration of NO ₂ Calibration Gas	48.48
--	--------------

Analyzer Reading in Direct Mode	44.76
---------------------------------	--------------

Equation 7E-7 (EPA Method 7E Section 12.7)

$$Eff_{NO_2} = \frac{\text{Measured Concentration in Direct Mode}}{\text{Manufacturer Certified Concentration of Cal. Gas}} \times 100$$

$$Eff_{NO_2} = \frac{44.76}{48.48} \times 100 = \mathbf{92.3 \%}$$

Method 7E criteria is >/= 90%

Efficiency Test Result	Pass
-------------------------------	-------------

APPENDIX 16

**Particulate and Mercury Test Emission Calculations
Incinerator Exhaust
(8 pages)**

ORTECH Environmental

Plant: Clean Harbors
Plant Location: Corunna, ON
Test Location: Incinerator Exhaust Stack
Test No.: 1 - Mercury
Date: August 17, 2022

STACK GAS SAMPLING PARAMETERS

PITOT TUBE COEFFICIENT	0.845
DGM CORRECTION FACTOR	0.973
NOZZLE DIAMETER	6.36 mm
DRY REF GAS VOLUME SAMPLED	3.385 m ³
AVGERGE ISOKINETICITY	102.4 %
STACK DIAMETER	1.47 m
LENGTH	0.00 m
WIDTH	0.00 m
AREA OF STACK or DUCT	1.70 m ³

STACK GAS PHYSICAL PARAMETERS

AVERAGE GAS TEMPERATURE	193.1 °C
AVERAGE GAS MOISTURE BY VOLUME	48.6 %
AVERAGE GAS VELOCITY	29.73 m/s
BAROMETRIC PRESSURE (Station)	99.797 Kpa
STATIC PRESSURE	-0.030 Kpa
ABSOLUTE GAS PRESSURE	99.767 Kpa
OXYGEN CONCENTRATION	9.28 %
CARBON DIOXIDE CONCENTRATION	7.72 %
CARBON MONOXIDE CONCENTRATION	68.2 ppm

FLOWRATE

ACTUAL GAS FLOWRATE	50.68 m ³ /s
DRY REF GAS FLOWRATE	16.41 Rm ³ /s
DRY ADJ GAS FLOWRATE	19.26 Rm ³ /s
WET REF GAS FLOWRATE	31.91 Rm ³ /s

PARTICULATE EMISSION DATA

PARTICULATE COLLECTED	-PROBE	14 mg
	-FILTER	1.5 mg
	-TOTAL	15.5 mg
DRY REF GAS VOLUME SAMPLED		3.385 m ³
PARTICULATE CONC. - ACTUAL		1.482 mg/m ³
PARTICULATE CONC. - DRY REF		4.579 mg/m ³
PARTICULATE CONC. - DRY ADJ		3.901 mg/m ³
PARTICULATE CONC. - WET REF		2.355 mg/m ³
PARTICULATE EMISSION RATE		0.075123 g/s

Note: * Reference conditions refers to 25 deg C (77 deg F) and 101.325 kPa (29.92 in. Hg)

Note: Dry Adj condition refers to 25 deg C (77 deg F) and 1 atmosphere, adjusted to 11% oxygen by volume

ORTECH Environmental

Plant: Clean Harbors
 Test No.: 1 - Mercury
 Date: August 17, 2022

Plant Location: Corunna, ON
 Test Location: Incinerator Exhaust Stack
 Operator: AP

Combustion Gases	
O2%	9.28
CO2%	7.72
COppm	68.2

Measured H2O	
Measured H2O	48.6 %

Filter (mg) 1.5
 Probe (mg) 14
 CWTR (g) 2327.7
 WCBDA (g) 22.7

Leak Check Volume 0.4 ft³
 Reading Interval 3 minutes
 Number of Ports 2
 Number of points / Port 10

Pitot Factor 0.845
 DGM/CF 0.973
 Barometric Pressure 29.47 "Hg
 Static Pressure -0.120 "H₂O
 Nozzle 0.2505 inches
 Stack Diameter 4.833 ft
 Length 0.000 ft
 Width 0.000 ft

Point	Time	DGM Reading	AP "H2O	Temperatures			DGM In °F	ΔH "H2O	Vacuum "Hg	Leak Check Volume	Velocity m/s	Isokinetic %
				Stack °F	Imp. Out °F	DGM Out °F						
1	0	58.32	1.6	376	69	77	73	1.7	4.0		30.21	
	3	60.64	1.2	377	52	73	75	1.7	4.0		26.18	112.9
	6	62.89	1.5	377	50	72	74	1.6	4.0		29.27	126.7
2	9	64.87	1.5	378	51	72	76	1.6	4.0		29.29	99.9
	12	66.90	1.5	378	50	73	74	1.5	4.0		29.29	102.3
	15	68.95	1.5	379	50	72	74	1.5	4.0		29.30	103.4
3	18	70.99	1.4	380	50	73	75	1.5	4.0		28.33	103.0
	21	73.02	1.6	380	47	73	76	1.7	4.0		30.28	106.0
	24	75.04	1.5	380	44	73	75	1.6	4.0		29.32	98.6
4	27	77.10	1.6	380	43	73	75	1.7	4.0		30.28	103.9
	30	79.15	1.6	379	43	72	75	1.7	4.0		30.26	100.2
	33	81.25	1.5	381	43	73	77	1.5	4.0		29.34	102.6
5	36	83.60	1.5	381	43	73	76	1.5	4.0		29.34	118.4
	39	85.65	1.5	382	44	73	77	1.3	4.0		29.36	103.4
	42	87.64	1.5	381	45	73	76	1.3	4.0		29.34	100.2
6	45	89.44	1.5	382	45	73	78	1.5	4.0		29.36	90.7
	48	91.49	1.5	382	44	73	75	1.5	4.0		29.36	103.2
	51	93.56	1.5	382	43	73	75	1.4	4.0		29.36	104.5
7	54	95.57	1.7	382	42	73	75	1.5	4.0		31.25	101.5
	57	97.62	1.5	382	41	73	75	1.6	4.0		29.36	97.2

ORTECH Environmental

Plant: Clean Harbors
 Test No.: 1 - Mercury
 Date: August 17, 2022
 Plant Location: Corunna, ON
 Test Location: Incinerator Exhaust Stack
 Operator: AP

Combustion Gases	
O2%	9.28
CO2%	7.72
COPPM	68.2

Measured H2O	
Measured H2O	48.6 %

Filter (mg) 1.5
 Probe (mg) 14
 CWTR (g) 2327.7
 WCBDA (g) 22.7
 Leak Check Volume 0.4 ft³
 Reading Interval 3 minutes
 Number of Ports 2
 Number of points / Port 10

Pitot Factor 0.845
 DGMCF 0.973
 Barometric Pressure 29.47 "Hg
 Static Pressure -0.120 "H₂O
 Nozzle 0.2505 inches
 Stack Diameter 4.833 ft
 Length 0.000 ft
 Width 0.000 ft

Point	Time	DGM Reading	ΔP "H ₂ O	Temperatures			DGM In °F	ΔH "H ₂ O	Vacuum "Hg	Leak Check Volume	Velocity m/s	Isokinetic %
				Stack °F	Imp. Out °F	DGM Out °F						
8	60	99.69	1.5	381	41	73	76	1.4	4.0		29.34	104.5
	63	101.69	1.5	381	41	73	76	1.4	4.0		29.34	100.8
	66	103.69	1.5	379	42	74	76	1.5	4.0		29.30	100.8
9	69	105.70	1.6	379	42	74	76	1.5	4.0		30.26	101.1
	72	107.73	1.5	379	41	74	76	1.5	4.0		29.30	98.9
	75	109.69	1.5	380	41	74	76	1.5	4.0		29.32	98.6
10	78	111.82	1.5	380	43	74	76	1.3	4.0		29.32	107.2
	81	113.79	1.5	380	44	74	76	1.4	4.0		29.32	99.1
	84	115.76	1.5	381	44	74	76	1.5	4.0		29.34	99.1
1	87	117.79	1.5	381	44	74	76	1.4	4.0	0.4	29.34	102.2
	90	119.87										104.7
	0	120.27	1.4	381	61	75	77	1.6	5.0		28.34	
2	3	122.49	1.4	381	47	75	77	1.5	5.0		28.34	115.6
	6	124.53	1.5	382	45	75	77	1.3	4.0		29.36	106.2
	9	126.47	1.6	382	45	75	77	1.5	4.0		30.32	97.5
3	12	128.45	1.4	380	43	75	76	1.6	4.0		28.33	96.4
	15	130.55	1.5	381	42	76	77	1.4	4.0		29.34	109.3
	18	132.55	1.5	381	41	75	77	1.4	4.0		29.34	100.4
4	21	134.55	1.6	379	42	75	77	1.5	4.0		30.26	100.5
	24	136.58	1.5	381	43	75	78	1.6	4.0		29.34	98.7
	27	138.68	1.4	379	43	75	78	1.4	4.0		28.31	105.5
5	30	140.70	1.5	379	44	74	77	1.4	4.0		29.30	104.9
	33	142.71	1.5	379	44	75	78	1.4	4.0		29.30	101.0
	36	144.69	1.5	379	43	76	79	1.4	4.0		29.30	99.3
6	39	146.68	1.6	379	43	75	79	1.45	4.0		30.26	99.6
	42	148.71	1.4	379	44	76	80	1.5	4.0		28.31	98.5
	45	150.78	1.5	379	45	76	79	1.4	4.0		29.30	107.2
7	48	152.80	1.8	379	46	76	80	1.4	4.0		32.10	101.1
	51	154.80	1.7	379	46	76	80	1.7	4.0		31.20	91.3
	54	157.00	1.7	378	47	76	80	1.6	4.0		31.18	103.4

ORTECH Environmental

Plant: Clean Harbors
Plant Location: Corunna, ON
Test Location: Incinerator Exhaust Stack
Test No.: 2 - Mercury
Date: August 17, 2022

STACK GAS SAMPLING PARAMETERS

PITOT TUBE COEFFICIENT	0.845
DGM CORRECTION FACTOR	0.973
NOZZLE DIAMETER	6.36 mm
DRY REF GAS VOLUME SAMPLED	3.349 m ³
AVGERGE ISOKINETICITY	101.7 %
STACK DIAMETER	1.47 m
LENGTH	0.00 m
WIDTH	0.00 m
AREA OF STACK or DUCT	1.70 m ³

STACK GAS PHYSICAL PARAMETERS

AVERAGE GAS TEMPERATURE	193.3 °C
AVERAGE GAS MOISTURE BY VOLUME	48.7 %
AVERAGE GAS VELOCITY	29.72 m/s
BAROMETRIC PRESSURE (Station)	99.695 Kpa
STATIC PRESSURE	-0.030 Kpa
ABSOLUTE GAS PRESSURE	99.665 Kpa
OXYGEN CONCENTRATION	9.3 %
CARBON DIOXIDE CONCENTRATION	7.63 %
CARBON MONOXIDE CONCENTRATION	61.2 ppm

FLOWRATE

ACTUAL GAS FLOWRATE	50.65 m ³ /s
DRY REF GAS FLOWRATE	16.34 Rm ³ /s
DRY ADJ GAS FLOWRATE	19.15 Rm ³ /s
WET REF GAS FLOWRATE	31.86 Rm ³ /s

PARTICULATE EMISSION DATA

PARTICULATE COLLECTED	-PROBE	10.3 mg
	-FILTER	5.1 mg
	-TOTAL	15.4 mg
DRY REF GAS VOLUME SAMPLED		3.349 m ³
PARTICULATE CONC. - ACTUAL		1.484 mg/m ³
PARTICULATE CONC. - DRY REF		4.599 mg/m ³
PARTICULATE CONC. - DRY ADJ		3.925 mg/m ³
PARTICULATE CONC. - WET REF		2.360 mg/m ³
PARTICULATE EMISSION RATE		0.075158 g/s

Note: * Reference conditions refers to 25 deg C (77 deg F) and 101.325 kPa (29.92 in. Hg)

Note: Dry Adj condition refers to 25 deg C (77 deg F) and 1 atmosphere, adjusted to 11% oxygen by volume

ORTECH Environmental

Plant: Clean Harbors
 Test No.: 2 - Mercury
 Date: August 17, 2022

Plant Location: Corunna, ON
 Test Location: Incinerator Exhaust Stack
 Operator: AP

Pitot Factor	0.845	Filter (mg)	5.1	Combustion Gases	
DGMCF	0.973	Probe (mg)	10.3	O2%	9.3
Barometric Pressure	29.44 "Hg	CWTR (g)	2310.1	CO2%	7.63
Static Pressure	-0.120 "H ₂ O	WCBDA (g)	25.2	COppm	61.2

Nozzle	0.2505 inches	Leak Check Volume	0.54 ft ³
Stack Diameter	4.833 ft	Reading Interval	3 minutes
Length	0.000 ft	Number of Ports	2
Width	0.000 ft	Number of points / Port	10

Measured H2O	48.7 %
--------------	--------

Point	Time	DGM Reading	AP "H ₂ O	Temperatures			DGM In °F	ΔH "H ₂ O	Vacuum "Hg	Leak Check Volume	Velocity m/s	Isokinetic %
				Stack °F	Imp. Out °F	DGM Out °F						
1	0	183.20	1.3	380	62	76	78	1.4	3.0		27.32	113.2
	3	185.30	1.4	385	54	76	77	1.3	3.0		28.44	98.0
	6	187.18	1.5	384	50	75	76	1.4	3.0		29.42	100.9
	9	189.18	1.5	383	49	75	76	1.4	3.0		29.40	100.9
2	12	191.18	1.5	384	47	75	76	1.4	3.0		29.42	100.4
	15	193.17	1.5	383	46	75	76	1.4	3.0		29.40	99.4
	18	195.14	1.5	383	44	75	76	1.45	3.0		29.40	101.4
	21	197.15	1.5	383	41	75	76	1.4	3.0		29.40	99.9
3	24	199.13	1.5	383	39	75	77	1.45	3.0		29.40	101.8
	27	201.15	1.5	382	37	75	76	1.45	3.0		29.38	101.3
	30	203.16	1.5	383	37	75	77	1.4	3.0		29.40	101.8
	33	205.18	1.7	382	38	75	77	1.4	3.0		31.28	97.9
4	36	207.25	1.5	383	40	75	77	1.5	3.0		29.40	97.8
	39	209.19	1.5	382	41	75	77	1.6	3.0		29.38	106.3
	42	211.30	1.5	380	39	75	77	1.45	3.0		29.35	103.1
	45	213.35	1.5	383	38	75	78	1.45	3.0		29.40	102.7
5	48	215.39	1.4	383	37	75	77	1.4	3.0		28.40	105.4
	51	217.41	1.85	383	38	76	78	1.7	3.0		32.65	97.0
	54	219.55	1.75	384	39	76	79	1.5	3.0		31.78	95.4
	57	221.60	2	383	39	75	78	1.8	3.0		33.95	

ORTECH Environmental

Plant: Clean Harbors
 Test No.: 2 - Mercury
 Date: August 17, 2022

Plant Location: Corunna, ON
 Test Location: Incinerator Exhaust Stack
 Operator: AP

Pitot Factor	0.845	Filter (mg)	5.1
DGMCF	0.973	Probe (mg)	10.3
Barometric Pressure	29.44 "Hg	CWTR (g)	2310.1
Static Pressure	-0.120 "H ₂ O	WCBDA (g)	25.2

Combustion Gases	
O ₂ %	9.3
CO ₂ %	7.63
COppm	61.2

Leak Check Volume: 0.54 ft³
 Reading Interval: 3 minutes
 Number of Ports: 2
 Number of points / Port: 10

Point	Time	DGM Reading	ΔP "H ₂ O	Temperatures			ΔH "H ₂ O	Vacuum "Hg	Leak Check Volume	Velocity m/s	Isokinetic %
				Stack °F	Imp. Out °F	DGM Out °F					
8	60	223.81	1.75	384	38	75	1.85	4.0		31.78	96.4
	63	226.06	1.7	384	38	75	1.75	4.0		31.32	105.0
	66	228.30	1.75	384	39	75	1.6	4.0		31.78	106.1
9	69	230.48	1.85	382	38	76	1.65	4.0		32.63	101.7
	72	232.66	1.75	386	37	76	1.7	4.0		31.81	98.7
	75	234.84	1.8	384	37	76	1.7	4.0		32.23	101.8
	78	237.05	1.75	381	38	76	1.7	4.0		31.72	101.6
10	81	239.23	1.75	381	40	76	1.7	4.0		31.72	101.5
	84	241.42	1.7	379	41	76	1.7	4.0		31.23	101.9
1	87	243.58	1.7	382	41	76	1.65	4.0	0.54	31.28	101.9
	90	245.80									104.9
	0	246.34	1.65	365	66	76	1.4	3.5		30.50	99.6
	3	248.44	1.65	367	49	76	1.45	3.5		30.54	96.1
	6	250.46	1.65	367	46	76	1.55	4.0		30.54	99.0
	9	252.54	1.45	367	46	76	1.55	4.0		28.63	106.1
	12	254.63	1.5	369	46	76	1.4	4.0		29.16	99.9
	15	256.63	1.4	371	47	76	1.45	4.0		28.20	105.6
	18	258.67	1.45	371	48	76	1.4	4.0		28.70	101.3
	21	260.66	1.45	375	47	76	1.4	4.0		28.77	101.1
2	24	262.64	1.45	375	47	75	1.4	4.0		28.77	100.5
	27	264.61	1.45	377	50	75	1.45	4.0		28.80	103.2
3	30	266.63	1.45	378	51	75	1.4	4.0		28.82	101.7
	33	268.62	1.5	379	48	75	1.4	4.0		29.33	100.0
4	36	270.61	1.5	380	45	75	1.45	4.0		29.35	100.6
	39	272.61	1.5	382	46	75	1.45	4.0		29.38	100.7
5	42	274.61	1.5	380	45	75	1.45	4.0		29.35	102.1
	45	276.64	1.5	381	45	75	1.45	4.0		29.35	103.2
6	48	278.69	1.5	380	48	75	1.45	4.0		29.35	101.1
	51	280.70	1.5	380	47	75	1.45	4.0		29.35	109.2
7	54	282.87	1.5	384	58	76	1.45	4.0		29.42	

APPENDIX 17

**ORTECH One-Minute Average
Combustion Gas Results
(6 pages)**

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 1 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	THC - 1 min ppm *	THC - 10 min ppm *
10:30	9.90	7.41	68.6		103	103	16.5	
10:31	9.51	7.72	68.5		102	103	18.5	
10:32	9.37	7.84	77.3		102	103	19.3	
10:33	9.20	7.95	68.8		105	106	20.7	
10:34	8.70	8.28	74.6		106	107	23.9	
10:35	9.73	7.54	58.8		105	106	16.9	
10:36	9.18	7.96	70.2		107	108	21.7	
10:37	9.60	7.63	69.0		106	108	17.4	
10:38	9.53	7.68	53.6		111	112	17.3	
10:39	9.68	7.58	60.8		108	109	16.7	18.9
10:40	9.37	7.81	64.4		107	108	19.1	19.1
10:41	9.34	7.83	73.5		107	108	20.1	19.3
10:42	8.99	8.07	65.0		108	109	22.3	19.6
10:43	8.87	8.08	87.4		103	104	27.2	20.3
10:44	9.35	7.72	65.9		107	110	18.5	19.7
10:45	9.19	7.86	66.4		110	111	20.3	20.0
10:46	9.56	7.53	59.0		110	111	16.9	19.6
10:47	9.48	7.57	62.5		109	109	17.8	19.6
10:48	9.60	7.49	60.5		107	107	17.1	19.6
10:49	9.11	7.85	64.0		106	107	20.8	20.0
10:50	9.27	7.68	66.7		108	110	18.6	20.0
10:51	8.63	8.20	66.2		106	107	23.7	20.3
10:52	9.19	7.73	62.6		104	107	19.1	20.0
10:53	9.15	7.80	56.5		111	112	19.1	19.2
10:54	9.30	7.67	63.9		107	108	18.8	19.2
10:55	9.55	7.47	61.0		111	111	16.9	18.9
10:56	9.53	7.50	61.5		109	110	17.4	18.9
10:57	9.56	7.47	62.1		105	106	18.3	19.0
10:58	9.14	7.81	69.9		105	106	19.8	19.2
10:59	9.22	7.71	61.3		107	107	19.9	19.2
11:00	10.78	6.48	68.2		103	104	20.8	19.4
Min	8.63	6.48	53.6		102	103	16.5	18.9
Max	10.78	8.28	87.4		111	112	27.2	20.3
Avg	9.37	7.71	65.8		107	108	19.4	19.5
St Dev	0.39	0.31	6.6		2.6	2.6	2.4	0.4

* Wet Basis as equivalent methane

Note: No SO₂ data due to scrubbing in the sampling system. Problem was resolved prior to Test No. 2.

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 2 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NO _x ppm	THC - 1 min ppm *	THC - 10 min ppm *
11:55	8.92	7.91	64.1	135	110	111	21.7	
11:56	9.52	7.44	57.9	115	110	110	19.2	
11:57	9.16	7.75	73.1	111	106	106	22.1	
11:58	9.33	7.58	75.1	113	102	104	20.9	
11:59	8.64	8.14	89.5	133	100	101	31.1	
12:00	9.22	7.62	88.1	129	99	100	23.0	
12:01	9.18	7.68	75.1	115	104	105	21.8	
12:02	9.15	7.76	74.0	138	104	106	22.0	
12:03	9.58	7.42	65.5	118	104	106	18.6	
12:04	9.21	7.69	69.3	130	106	106	21.9	22.2
12:05	9.09	7.76	70.5	136	107	109	21.8	22.2
12:06	9.25	7.63	69.5	119	105	106	20.7	22.4
12:07	9.15	7.73	65.1	130	105	106	21.9	22.4
12:08	8.49	8.28	94.4	175	102	102	33.6	23.6
12:09	9.37	7.55	76.3	147	102	105	21.0	22.6
12:10	8.90	7.93	72.2	142	106	107	23.1	22.6
12:11	9.22	7.68	70.0	151	106	108	21.9	22.6
12:12	9.27	7.65	68.1	129	108	108	21.1	22.5
12:13	9.43	7.54	76.6	120	103	104	20.6	22.7
12:14	8.92	7.93	74.6	151	106	108	23.5	22.9
12:15	9.32	7.64	67.6	134	108	109	20.1	22.7
12:16	8.76	8.04	63.2	133	105	106	25.9	23.2
12:17	9.00	7.85	81.1	155	105	107	23.7	23.4
12:18	9.06	7.84	57.9	147	110	112	20.6	22.1
12:19	9.43	7.52	59.5	110	107	107	20.3	22.1
12:20	9.53	7.50	63.5	107	106	107	18.8	21.6
12:21	9.38	7.61	67.1	113	104	105	21.7	21.6
12:22	9.01	7.89	74.1	153	109	111	22.8	21.8
12:23	8.86	7.98	67.7	144	111	111	23.8	22.1
12:24	9.19	7.74	65.7	139	109	110	22.4	22.0
12:25	8.75	8.05	78.7	124	105	105	26.8	22.7
12:26	9.31	7.67	63.3	135	104	107	20.9	22.2
12:27	8.92	7.93	60.8	138	110	111	23.7	22.2
12:28	9.42	7.61	59.0	132	107	109	20.3	22.2
12:29	9.51	7.52	62.4	122	108	109	19.9	22.1
12:30	9.37	7.62	57.3	126	106	107	19.9	22.2
12:31	9.32	7.65	63.8	123	107	108	21.2	22.2
12:32	9.37	7.64	71.5	119	103	104	21.2	22.0
12:33	9.06	7.85	62.8	120	106	106	22.7	21.9
12:34	8.82	8.06	75.9	150	98	100	30.8	22.7
12:35	9.33	7.64	74.9	137	105	108	20.6	22.1
12:36	9.09	7.82	59.1	124	106	106	22.3	22.2
12:37	9.50	7.54	58.4	122	105	106	19.4	21.8
12:38	9.44	7.58	69.8	127	106	106	19.9	21.8
12:39	9.39	7.64	63.7	119	105	106	20.4	21.8
12:40	9.15	7.78	74.9	134	105	106	22.0	22.1
12:41	9.04	7.87	65.0	132	109	111	20.7	22.0
12:42	8.63	8.20	68.7	147	108	108	25.9	22.5
12:43	9.48	7.52	74.0	131	102	103	20.4	22.2
12:44	8.92	8.00	62.6	146	106	107	22.6	21.4
12:45	9.50	7.56	72.2	136	103	106	19.6	21.3
12:46	9.18	7.78	67.4	132	107	108	22.0	21.3
12:47	9.37	7.65	72.9	136	107	108	19.5	21.3
12:48	8.94	7.97	67.0	147	109	110	22.5	21.6
12:49	9.40	7.63	76.4	136	107	107	19.9	21.5
12:50	9.32	7.68	72.4	115	103	103	21.7	21.5
12:51	9.05	7.86	104	139	98.0	99.3	27.5	22.1
12:52	9.17	7.78	94.9	135	100	103	21.9	21.7
12:53	9.12	7.87	85.6	152	107	108	21.8	21.9
12:54	9.57	7.49	65.8	120	105	106	17.7	21.4
12:55	9.50	7.54	73.6	118	105	105	19.5	21.4
Min	8.49	7.42	57.3	107	98.0	99.3	17.7	21.3
Max	9.58	8.28	104	175	111	112	33.6	23.6
Avg	9.19	7.74	70.7	132	105	107	22.1	22.1
St Dev	0.26	0.19	9.5	13.4	2.8	2.8	2.9	0.5

* Wet Basis as equivalent methane

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 3 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NOx ppm	THC - 1 min ppm *	THC - 10 min ppm *
13:25	8.60	8.16	81.9	177	105	105	26.9	
13:26	8.91	7.98	60.5	173	112	115	18.9	
13:27	8.91	7.98	58.9	171	115	116	19.1	
13:28	9.40	7.64	56.0	147	114	116	16.5	
13:29	9.16	7.81	60.0	156	115	116	17.2	
13:30	9.45	7.59	54.8	138	113	114	16.1	
13:31	8.88	8.00	66.1	147	112	112	21.7	
13:32	8.90	7.99	65.0	158	112	114	19.3	
13:33	8.33	8.41	68.0	183	113	114	24.9	
13:34	9.08	7.83	64.3	168	108	111	20.1	20.1
13:35	9.08	7.84	59.8	139	114	115	18.6	19.2
13:36	9.27	7.72	59.9	147	112	113	18.8	19.2
13:37	9.18	7.79	58.7	158	114	116	17.5	19.0
13:38	9.15	7.79	56.9	157	116	117	17.5	19.1
13:39	8.94	7.94	55.5	168	119	121	18.5	19.3
13:40	8.82	8.04	58.6	166	116	117	20.6	19.7
13:41	8.74	8.07	62.9	163	117	118	21.0	19.7
13:42	8.64	8.13	67.9	162	112	112	25.1	20.3
13:43	9.11	7.84	64.1	167	109	113	17.7	19.5
13:44	8.93	7.98	54.5	162	118	119	19.8	19.5
13:45	8.82	8.00	54.7	183	115	119	18.2	19.5
13:46	8.96	7.94	48.2	184	124	125	17.1	19.3
13:47	9.24	7.69	49.9	157	118	119	16.6	19.2
13:48	8.78	8.03	56.9	169	115	116	19.1	19.4
13:49	8.99	7.89	58.1	155	115	117	18.0	19.3
13:50	8.65	8.13	55.3	160	118	119	20.8	19.3
13:51	8.82	7.96	63.4	193	108	111	21.2	19.4
13:52	8.75	8.05	58.3	181	119	121	19.2	18.8
13:53	9.08	7.83	57.8	162	116	117	17.7	18.8
13:54	8.91	7.93	54.5	183	120	122	18.2	18.6
13:55	9.10	7.79	53.5	171	122	123	16.3	18.4
13:56	9.18	7.73	49.1	147	123	124	16.8	18.4
13:57	8.97	7.87	60.8	145	114	114	19.1	18.6
13:58	8.30	8.40	59.7	196	112	114	22.0	18.9
13:59	8.52	8.23	55.5	183	114	116	23.5	19.5
14:00	9.01	7.86	53.7	164	114	118	17.9	19.2
14:01	8.29	8.37	61.7	209	117	118	28.8	19.9
14:02	9.33	7.62	72.6	169	114	117	17.1	19.7
14:03	9.09	7.81	48.0	151	121	121	17.1	19.7
14:04	9.12	7.78	49.9	166	118	119	16.7	19.5
14:05	8.88	7.94	51.7	159	120	121	19.1	19.8
14:06	8.96	7.90	61.6	159	117	118	18.6	20.0
14:07	8.28	8.41	60.6	206	115	116	24.5	20.5
14:08	9.03	7.80	59.2	161	116	119	18.6	20.2
14:09	8.86	7.97	56.8	171	122	124	18.9	19.7
14:10	8.93	7.92	58.4	182	120	121	19.0	19.8
14:11	9.42	7.55	51.4	141	119	120	15.7	18.5
14:12	9.12	7.79	67.3	133	114	115	20.2	18.8
14:13	8.93	7.91	73.2	169	117	120	18.4	19.0
14:14	8.87	7.95	60.4	160	118	119	18.4	19.1
14:15	9.02	7.86	53.7	153	120	121	17.0	18.9
14:16	8.44	8.24	61.4	187	113	113	25.9	19.6
14:17	9.18	7.70	67.6	167	111	115	17.7	19.0
14:18	8.80	8.09	67.1	164	113	113	23.3	19.4
14:19	8.92	7.92	85.2	195	109	112	20.5	19.6
14:20	9.02	7.87	55.1	167	120	121	17.3	19.4
14:21	9.28	7.65	54.5	147	118	118	16.4	19.5
14:22	8.79	8.03	55.4	166	116	117	18.6	19.3
14:23	9.34	7.62	52.5	138	114	115	16.1	19.1
14:24	8.32	8.38	72.3	175	110	111	33.9	20.6
14:25	8.76	8.08	131	202	97.1	100	27.7	21.7
Min	8.28	7.55	48.0	133	97.1	100	15.7	18.4
Max	9.45	8.41	131	209	124	125	33.9	21.7
Avg	8.93	7.93	60.9	166	115	117	19.7	19.4
St Dev	0.28	0.21	11.7	17.0	4.5	4.3	3.5	0.6

* Wet Basis as equivalent methane

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 4 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NOx ppm	THC - 1 min ppm *	THC - 10 min ppm *
14:37	8.56	8.12	55.5	191	119	121	18.5	
14:38	9.15	7.75	44.2	169	122	123	15.2	
14:39	8.80	8.02	43.7	176	123	123	17.6	
14:40	8.87	7.95	49.2	177	120	122	17.2	
14:41	8.77	8.03	43.4	153	125	126	17.9	
14:42	8.91	7.92	48.8	160	116	117	19.3	
14:43	8.60	8.17	47.1	186	116	119	19.1	
14:44	8.89	7.96	49.1	168	117	119	18.2	
14:45	9.04	7.85	45.3	159	119	120	16.7	
14:46	8.93	7.93	48.8	181	119	121	16.7	17.6
14:47	9.07	7.81	41.6	160	123	125	15.7	17.4
14:48	9.13	7.79	43.6	137	122	122	16.9	17.5
14:49	8.93	7.95	47.4	155	117	118	17.2	17.5
14:50	8.36	8.44	48.2	193	116	117	22.8	18.1
14:51	9.26	7.64	47.8	161	113	114	16.0	17.9
14:52	8.85	7.99	45.2	165	118	120	17.5	17.7
14:53	9.04	7.85	49.2	163	116	119	17.6	17.5
14:54	9.21	7.72	46.7	155	122	123	15.5	17.2
14:55	9.15	7.78	49.4	155	116	117	16.4	17.2
14:56	8.80	8.04	47.0	180	117	118	18.1	17.4
14:57	9.01	7.88	49.8	149	115	116	17.4	17.5
14:58	8.54	8.23	46.7	178	116	117	19.9	17.8
14:59	8.58	8.19	56.1	202	108	110	21.8	18.3
15:00	9.14	7.78	45.3	145	117	120	15.9	17.6
15:01	8.95	7.90	48.2	157	116	117	17.9	17.8
15:02	9.27	7.69	44.0	158	119	121	14.6	17.5
15:03	9.11	7.84	42.5	157	121	121	15.9	17.3
15:04	9.34	7.62	41.3	143	118	119	15.0	17.3
15:05	8.88	8.00	47.0	171	115	116	17.9	17.4
15:06	9.30	7.65	46.8	136	114	115	16.0	17.2
15:07	8.67	8.15	55.2	148	112	113	20.3	17.5
15:08	9.25	7.70	56.4	156	107	109	17.5	17.3
15:09	9.12	7.78	50.9	135	111	112	17.2	16.8
15:10	9.43	7.58	53.3	136	108	110	15.7	16.8
15:11	9.19	7.74	47.5	143	113	114	15.9	16.6
15:12	9.51	7.50	48.3	132	111	111	15.1	16.6
15:13	8.80	8.04	60.5	164	108	110	20.6	17.1
15:14	9.02	7.89	54.3	171	111	112	17.2	17.3
15:15	9.30	7.69	46.3	139	114	115	15.7	17.1
15:16	9.03	7.88	53.6	152	108	109	19.3	17.4
15:17	9.00	7.89	49.0	172	110	114	16.3	17.0
15:18	9.27	7.71	44.0	146	115	116	15.7	16.9
15:19	9.30	7.68	43.3	141	113	116	15.1	16.6
15:20	9.17	7.77	44.3	148	114	115	15.9	16.7
15:21	9.63	7.45	43.0	125	110	111	14.4	16.5
15:22	9.07	7.88	54.4	137	106	107	18.0	16.8
15:23	9.28	7.69	50.7	147	109	111	15.5	16.3
15:24	8.94	7.94	48.2	124	110	111	18.2	16.4
15:25	9.87	7.20	50.4	129	105	110	14.3	16.3
15:26	9.95	6.92	36.1	196	147	154	9.2	15.2
15:27	10.75	5.95	27.5	218	130	131	7.3	14.3
15:28	12.15	4.62	141.5	113	114	116	9.5	13.7
15:29	13.36	3.84	204.8	57.3	99.0	99.3	7.3	12.9
15:30	13.76	3.64	72.6	31.5	94.8	95.2	7.3	12.1
15:31	13.87	3.58	31.3	24.3	92.2	92.8	7.2	11.4
15:32	13.87	3.58	28.3	21.3	90.5	91.8	7.4	10.3
15:33	13.91	3.56	26.9	19.6	92.4	92.8	7.4	9.5
15:34	13.82	3.60	26.5	18.5	90.0	91.7	7.6	8.4
15:35	13.84	3.59	26.8	17.8	93.2	93.7	7.6	7.8
15:36	14.03	3.49	26.9	17.1	83.3	84.7	7.5	7.6
15:37	13.98	3.51	26.5	16.6	88.3	89.7	7.5	7.6
Min	8.36	3.49	26.5	16.6	83.3	84.7	7.2	7.6
Max	14.03	8.44	204.8	218	147	154	22.8	18.3
Avg	9.84	7.12	49.8	138	112	114	15.3	15.8
St Dev	1.75	1.57	25.2	51.7	10.9	11.2	4.1	3.0

* Wet Basis as equivalent methane

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 5 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NOx ppm	THC - 1 min ppm *	THC - 10 min ppm *
16:00	9.40	7.60	105.1	122	99.4	101	19.2	
16:01	9.58	7.47	124.6	123	101	102	20.2	
16:02	9.81	7.30	112.9	113	97.8	98.8	17.7	
16:03	9.77	7.35	135.4	106	94.7	95.6	19.7	
16:04	9.37	7.63	113.3	137	100	102	19.7	
16:05	9.37	7.65	111.0	144	103	104	20.3	
16:06	9.03	7.90	106.1	153	103	104	20.6	
16:07	9.08	7.78	106.0	145	104	105	22.5	
16:08	9.31	7.67	92.6	131	102	104	18.7	
16:09	9.00	7.93	95.3	155	106	108	20.9	20.0
16:10	9.38	7.63	80.7	166	108	110	17.6	19.8
16:11	9.24	7.74	82.0	154	110	111	18.2	19.6
16:12	9.40	7.61	79.8	147	109	111	16.7	19.5
16:13	8.94	7.97	81.6	171	110	111	20.2	19.5
16:14	9.13	7.82	78.0	165	110	111	18.6	19.4
16:15	8.69	8.15	74.8	177	111	112	22.2	19.6
16:16	9.16	7.84	82.8	165	107	109	20.9	19.6
16:17	9.00	7.91	62.8	164	114	117	18.5	19.2
16:18	9.00	7.94	68.6	175	111	113	20.5	19.4
16:19	9.29	7.70	59.2	155	112	115	17.1	19.0
16:20	9.26	7.73	68.1	162	115	115	18.3	19.1
16:21	9.13	7.82	72.2	149	110	111	19.1	19.2
16:22	8.86	8.05	72.5	172	111	111	19.7	19.5
16:23	8.94	7.96	61.3	171	114	116	18.9	19.4
16:24	8.56	8.24	72.2	188	111	112	24.5	20.0
16:25	9.10	7.87	66.1	178	111	115	18.6	19.6
16:26	8.79	8.09	61.8	175	118	119	21.3	19.6
16:27	9.30	7.71	66.5	177	113	114	17.3	19.5
16:28	9.10	7.86	58.4	155	118	119	18.5	19.3
16:29	9.31	7.70	62.8	172	115	116	16.7	19.3
16:30	8.75	8.14	67.2	171	113	114	20.9	19.6
16:31	9.13	7.83	60.5	168	115	118	17.0	19.3
16:32	8.57	8.26	54.4	171	117	117	21.3	19.5
16:33	8.92	7.96	58.3	189	113	114	20.5	19.7
16:34	8.82	8.07	58.6	180	116	118	19.6	19.2
16:35	9.63	7.52	62.9	165	117	119	15.5	18.9
16:36	10.89	6.57	39.0	162	129	132	9.3	17.7
16:37	10.08	7.13	35.1	172	134	134	11.5	17.1
16:38	9.38	7.63	40.5	155	124	124	15.7	16.8
16:39	9.07	7.86	51.1	163	120	122	17.3	16.8
16:40	9.06	7.88	51.9	160	118	119	17.9	16.5
16:41	8.69	8.17	63.9	188	116	117	21.4	17.0
16:42	9.05	7.89	54.8	190	113	116	18.9	16.7
16:43	8.93	7.97	57.9	166	118	118	18.8	16.6

Clean Harbors, Sarnia
CEM Sampling at the Incinerator Exhaust Stack
Test 5 - August 17, 2022

Time	O ₂ %	CO ₂ %	CO ppm	SO ₂ ppm	NO ppm	NOx ppm	THC - 1 min ppm *	THC - 10 min ppm *
16:44	9.46	7.57	61.9	142	114	115	16.6	16.3
16:45	9.31	7.69	64.0	145	116	118	16.6	16.4
16:46	9.55	7.51	65.5	141	111	112	16.0	17.1
16:47	9.20	7.75	68.4	131	111	112	18.1	17.7
16:48	9.33	7.70	72.2	134	109	111	17.6	17.9
16:49	8.88	7.99	76.6	136	109	110	21.2	18.3
16:50	9.11	7.81	81.6	150	106	108	20.7	18.6
16:51	9.28	7.72	67.9	143	109	111	17.6	18.2
16:52	9.19	7.75	80.6	144	107	108	19.7	18.3
16:53	9.52	7.53	75.6	135	106	107	16.0	18.0
16:54	9.56	7.53	85.1	137	107	108	18.0	18.1
16:55	9.45	7.59	89.5	144	105	107	17.2	18.2
16:56	9.02	7.90	77.9	134	107	108	19.7	18.6
16:57	8.95	7.95	70.8	143	108	110	20.4	18.8
16:58	8.83	8.04	87.5	162	109	112	20.9	19.1
16:59	9.07	7.85	61.4	176	110	112	17.6	18.8
17:00	8.89	8.00	70.8	150	114	114	20.1	18.7
17:01	9.24	7.78	73.9	154	109	112	17.6	18.7
17:02	9.28	7.70	59.0	145	115	115	16.2	18.4
17:03	9.39	7.62	65.1	141	111	112	16.2	18.4
17:04	8.95	7.96	67.4	164	112	113	19.8	18.6
17:05	9.07	7.88	74.3	148	111	113	19.4	18.8
17:06	8.59	8.24	75.7	172	112	113	21.5	19.0
17:07	8.87	8.07	71.2	167	110	112	22.0	19.1
17:08	9.00	7.91	65.4	148	111	114	18.6	18.9
17:09	8.92	7.99	72.2	169	113	113	20.9	19.2
17:10	9.22	7.77	70.9	164	112	113	17.7	19.0
17:11	9.29	7.70	73.1	148	112	114	17.8	19.0
17:12	9.19	7.78	70.5	138	111	112	17.8	19.2
17:13	9.02	7.90	65.8	147	111	112	18.8	19.4
17:14	8.92	7.97	59.6	159	112	114	18.6	19.3
17:15	8.45	8.34	63.4	182	113	113	23.4	19.7
17:16	9.10	7.81	77.1	180	103	107	19.8	19.5
17:17	8.83	8.04	62.2	147	114	115	19.6	19.3
17:18	9.21	7.75	60.0	147	111	114	17.4	19.2
17:19	9.11	7.84	63.5	154	114	114	19.4	19.0
17:20	9.34	7.67	75.4	148	112	113	17.1	19.0
17:21	8.90	7.99	77.5	159	109	110	21.3	19.3
17:22	9.04	7.89	77.3	149	109	110	19.0	19.4
17:23	8.67	8.15	66.5	155	112	113	21.1	19.7
17:24	8.72	8.11	68.4	182	107	108	22.6	20.1
17:25	8.98	7.94	65.9	148	111	113	18.6	19.6
17:26	8.91	8.01	69.9	155	113	113	20.9	19.7
17:27	9.32	7.68	62.7	146	112	114	16.7	19.4
17:28	9.17	7.80	78.5	146	111	112	19.5	19.6
17:29	9.23	7.75	85.0	149	108	108	19.4	19.6
17:30	8.88	8.00	100.8	147	106	107	23.5	20.3
Min	8.45	6.57	35.1	106	94.7	95.6	9.3	16.3
Max	10.89	8.34	135.4	190	134	134	24.5	20.3
Avg	9.14	7.82	73.0	156	111	112	18.9	18.8
St Dev	0.34	0.25	17.2	17.0	5.7	5.7	2.3	1.0

* Wet Basis as equivalent methane

APPENDIX 18

**Clean Harbors One-Minute Average
Combustion Gas Results
(8 pages)**

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	9:25:00	50.54	0.00	0.00	0.08	16.80	10.06	0.41	59.20
2022-08-17	9:26:00	55.87	0.00	0.00	0.08	17.40	9.85	0.41	59.80
2022-08-17	9:27:00	60.41	0.00	0.00	0.08	16.50	10.35	0.26	51.90
2022-08-17	9:28:00	55.83	0.00	0.00	0.08	19.20	9.72	0.45	50.90
2022-08-17	9:29:00	64.12	0.00	0.00	0.08	18.30	9.77	0.51	78.60
2022-08-17	9:30:00	47.29	0.00	0.00	0.08	20.10	9.36	0.52	63.50
2022-08-17	9:31:00	91.86	0.00	0.00	0.08	25.00	8.91	0.45	88.60
2022-08-17	9:32:00	51.59	0.00	0.00	0.08	18.90	9.59	0.60	97.40
2022-08-17	9:33:00	66.70	0.00	0.00	0.08	21.50	8.97	0.47	94.10
2022-08-17	9:34:00	45.57	0.00	0.00	0.08	16.60	9.98	0.47	93.30
2022-08-17	9:35:00	54.55	0.00	0.00	0.08	18.40	9.75	0.36	61.50
2022-08-17	9:36:00	47.79	0.00	0.00	0.08	20.00	9.75	0.37	70.40
2022-08-17	9:37:00	57.67	0.00	0.00	0.08	19.80	9.32	0.47	78.90
2022-08-17	9:38:00	48.68	0.00	0.00	0.08	19.70	9.60	0.45	63.30
2022-08-17	9:39:00	57.24	0.00	0.00	0.08	23.00	8.97	0.32	92.00
2022-08-17	9:40:00	49.74	0.00	0.00	0.08	17.70	9.41	0.40	86.20
2022-08-17	9:41:00	56.47	0.00	0.00	0.08	22.00	9.41	0.40	82.00
2022-08-17	9:42:00	52.20	0.00	0.00	0.08	17.20	9.55	0.41	118.40
2022-08-17	9:43:00	58.97	0.00	0.00	0.08	17.90	9.77	0.56	70.40
2022-08-17	9:44:00	46.31	0.00	0.00	0.08	16.80	9.63	0.36	84.10
2022-08-17	9:45:00	62.28	0.00	0.00	0.08	20.30	9.43	0.37	68.30
2022-08-17	9:46:00	55.42	0.00	0.00	0.08	18.70	9.48	0.36	85.10
2022-08-17	9:47:00	49.20	0.00	0.00	0.09	22.10	9.26	0.36	96.60
2022-08-17	9:48:00	51.78	0.00	0.00	0.08	21.30	8.76	0.37	120.40
2022-08-17	9:49:00	56.98	0.00	0.00	0.08	18.40	9.49	0.41	81.60
2022-08-17	9:50:00	48.03	0.00	0.00	0.08	18.30	9.49	0.60	75.40
2022-08-17	9:51:00	43.54	0.00	0.00	0.08	16.30	9.70	0.45	72.00
2022-08-17	9:52:00	58.57	0.00	0.00	0.08	18.20	9.70	0.36	57.10
2022-08-17	9:53:00	45.57	0.00	0.00	0.08	16.90	9.90	0.36	61.30
2022-08-17	9:54:00	60.39	0.00	0.00	0.08	19.70	9.27	0.33	68.50
2022-08-17	9:55:00	52.61	0.00	0.00	0.08	17.80	9.76	0.40	67.70
2022-08-17	9:56:00	85.77	0.00	0.00	0.08	22.40	8.94	0.45	63.80
2022-08-17	9:57:00	52.07	0.00	0.00	0.08	17.00	9.70	0.45	90.10
2022-08-17	9:58:00	68.89	0.00	0.00	0.08	19.50	9.48	0.40	54.20
2022-08-17	9:59:00	64.47	0.00	0.00	0.08	18.30	9.79	0.33	66.60
2022-08-17	10:00:00	54.81	0.00	0.00	0.08	18.10	9.57	0.26	78.80
2022-08-17	10:01:00	58.76	0.00	0.00	0.08	17.20	9.99	0.22	73.10
2022-08-17	10:02:00	47.92	0.00	0.00	0.08	19.00	9.35	0.30	65.30
2022-08-17	10:03:00	44.95	0.00	0.00	0.08	18.40	9.14	0.37	90.20
2022-08-17	10:04:00	48.49	0.00	0.00	0.08	21.40	9.34	0.33	61.40
2022-08-17	10:05:00	61.21	0.00	0.00	0.08	21.90	8.91	0.41	98.10
2022-08-17	10:06:00	53.03	0.00	0.00	0.08	20.10	9.70	0.33	85.40
2022-08-17	10:07:00	49.04	0.00	0.00	0.08	19.20	9.07	0.41	90.30
2022-08-17	10:08:00	46.96	0.00	0.00	0.08	16.60	9.81	0.37	78.90
2022-08-17	10:09:00	51.18	0.00	0.00	0.08	19.80	9.60	0.36	63.20
2022-08-17	10:10:00	48.37	0.00	0.00	0.08	17.50	10.02	0.25	84.00
2022-08-17	10:11:00	45.89	0.00	0.00	0.08	19.10	9.18	0.22	75.80
2022-08-17	10:12:00	59.61	0.00	0.00	0.08	18.10	9.67	0.51	61.90
2022-08-17	10:13:00	64.71	0.00	0.00	0.09	22.30	8.99	0.51	95.40
2022-08-17	10:14:00	48.48	0.00	0.00	0.08	17.50	9.70	1.33	82.60
2022-08-17	10:15:00	66.40	0.00	0.00	0.08	22.40	8.81	0.60	105.00
2022-08-17	10:16:00	45.99	0.00	0.00	0.08	17.90	9.65	0.63	127.90
2022-08-17	10:17:00	56.76	0.00	0.00	0.08	17.00	10.06	0.51	47.50
2022-08-17	10:18:00	50.68	0.00	0.00	0.08	17.30	9.44	0.41	61.20
2022-08-17	10:19:00	58.55	0.00	0.00	0.08	19.70	9.66	0.33	63.10
2022-08-17	10:20:00	52.34	0.00	0.00	0.09	19.00	9.23	0.36	77.60
2022-08-17	10:21:00	58.57	0.00	0.00	0.08	22.70	9.25	0.43	67.50
2022-08-17	10:22:00	88.84	0.00	0.00	0.08	22.90	9.02	0.56	84.90

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	10:23:00	54.97	0.00	0.00	0.08	18.10	9.54	0.60	66.70
2022-08-17	10:24:00	67.38	0.00	0.00	0.08	21.80	9.33	0.60	60.30
2022-08-17	10:25:00	57.00	0.00	0.00	0.09	16.60	9.88	0.65	55.90
2022-08-17	10:26:00	63.46	0.00	0.00	0.08	18.60	9.88	0.52	43.20
2022-08-17	10:27:00	60.32	0.00	0.00	0.08	17.40	9.89	0.42	52.60
2022-08-17	10:28:00	54.68	0.00	0.00	0.08	19.30	9.69	0.36	55.80
2022-08-17	10:29:00	57.45	0.00	0.00	0.08	16.90	9.72	0.47	55.00
2022-08-17	10:30:00	72.03	0.00	0.00	0.08	22.10	9.31	0.56	43.60
2022-08-17	10:31:00	63.61	0.00	0.00	0.08	18.10	10.13	0.47	73.70
2022-08-17	10:32:00	83.13	0.00	0.00	0.08	19.40	9.87	0.52	55.40
2022-08-17	10:33:00	91.79	0.00	0.00	0.09	20.90	9.89	0.52	35.70
2022-08-17	10:34:00	61.47	0.00	0.00	0.08	17.80	10.11	0.47	40.90
2022-08-17	10:35:00	70.01	0.00	0.00	0.08	17.30	10.11	0.37	36.90
2022-08-17	10:36:00	80.56	0.00	0.00	0.08	19.80	9.72	0.30	36.00
2022-08-17	10:37:00	64.47	0.00	0.00	0.09	19.30	9.52	0.21	47.90
2022-08-17	10:38:00	71.30	0.00	0.00	0.08	22.10	9.53	0.33	76.20
2022-08-17	10:39:00	59.13	0.00	0.00	0.08	21.90	8.65	0.36	108.10
2022-08-17	10:40:00	48.62	0.00	0.00	0.08	16.90	9.90	0.32	65.20
2022-08-17	10:41:00	95.83	0.00	0.00	0.09	22.60	9.26	0.26	58.90
2022-08-17	10:42:00	47.22	0.00	0.00	0.08	16.60	9.72	0.28	75.10
2022-08-17	10:43:00	62.80	0.00	0.00	0.08	17.80	9.72	0.45	60.00
2022-08-17	10:44:00	53.27	0.00	0.00	0.08	16.40	9.72	0.50	63.60
2022-08-17	10:45:00	68.22	0.00	0.00	0.09	20.20	9.51	0.52	56.90
2022-08-17	10:46:00	59.72	0.00	0.00	0.08	17.60	9.53	0.56	75.70
2022-08-17	10:47:00	71.80	0.00	0.00	0.08	25.00	9.10	0.48	83.70
2022-08-17	10:48:00	76.00	0.00	0.00	0.08	21.30	9.69	0.41	132.90
2022-08-17	10:49:00	62.24	0.00	0.00	0.08	20.90	9.49	0.36	79.40
2022-08-17	10:50:00	58.46	0.00	0.00	0.08	19.60	9.26	0.48	90.30
2022-08-17	10:51:00	70.77	0.00	0.00	0.08	17.50	9.73	0.48	69.80
2022-08-17	10:52:00	64.64	0.00	0.00	0.08	17.90	9.73	0.33	57.80
2022-08-17	10:53:00	64.39	0.00	0.00	0.08	18.70	9.94	0.37	54.30
2022-08-17	10:54:00	75.40	0.00	0.00	0.08	21.00	9.11	0.36	85.80
2022-08-17	10:55:00	53.33	0.00	0.00	0.09	21.20	9.65	0.26	71.60
2022-08-17	10:56:00	55.60	0.00	0.00	0.08	22.70	8.61	0.37	83.50
2022-08-17	10:57:00	44.06	0.00	0.00	0.08	18.10	9.51	0.30	91.50
2022-08-17	10:58:00	51.69	0.00	0.00	0.08	20.40	9.31	0.36	79.40
2022-08-17	10:59:00	48.95	0.00	0.00	0.08	17.00	9.40	0.41	79.20
2022-08-17	11:00:00	59.94	0.00	0.00	0.08	18.30	9.83	0.37	59.60
2022-08-17	11:01:00	63.46	0.00	0.00	0.08	16.70	9.82	0.26	64.40
2022-08-17	11:02:00	71.05	0.00	0.00	0.08	23.30	9.82	0.32	55.20
2022-08-17	11:03:00	48.47	0.00	0.00	0.08	17.00	9.37	0.36	94.20
2022-08-17	11:04:00	62.05	0.00	0.00	0.08	23.60	9.34	0.37	50.50
2022-08-17	11:05:00	54.57	0.00	0.00	0.08	20.40	9.90	0.36	106.20
2022-08-17	11:06:00	64.38	0.00	0.00	0.08	20.10	9.64	0.30	62.60
2022-08-17	11:07:00	50.90	0.00	0.00	0.08	18.60	9.22	0.33	75.40
2022-08-17	11:08:00	63.24	0.00	0.00	0.08	18.30	9.72	0.36	64.40
2022-08-17	11:09:00	58.66	0.00	0.00	0.08	17.50	9.72	0.33	63.30
2022-08-17	11:10:00	60.08	0.00	0.00	0.08	19.60	9.95	0.30	58.50
2022-08-17	11:11:00	64.14	0.00	0.00	0.08	21.20	9.47	0.45	59.70
2022-08-17	11:12:00	63.78	0.00	0.00	0.08	19.80	9.73	0.36	77.00
2022-08-17	11:13:00	99.18	0.00	0.00	0.08	28.30	8.86	0.37	67.30
2022-08-17	11:14:00	48.03	0.00	0.00	0.08	17.50	9.43	0.26	104.10
2022-08-17	11:15:00	76.19	0.00	0.00	0.08	21.80	9.66	0.17	46.60
2022-08-17	11:16:00	61.46	0.00	0.00	0.08	17.10	9.81	0.18	68.80
2022-08-17	11:17:00	63.21	0.00	0.00	0.08	18.10	9.80	0.26	49.90
2022-08-17	11:18:00	68.25	0.00	0.00	0.08	17.50	10.01	0.11	48.80
2022-08-17	11:19:00	67.83	0.00	0.00	0.08	22.70	9.37	0.48	74.20
2022-08-17	11:20:00	52.04	0.00	0.00	0.08	18.10	9.59	0.48	84.40

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	11:21:00	69.32	0.00	0.00	0.08	23.40	9.60	0.48	49.50
2022-08-17	11:22:00	77.03	0.00	0.00	0.08	23.20	9.28	0.48	44.90
2022-08-17	11:23:00	66.79	0.00	0.00	0.08	18.90	9.76	0.48	70.10
2022-08-17	11:24:00	77.25	0.00	0.00	0.08	20.40	9.15	0.52	60.60
2022-08-17	11:25:00	55.64	0.00	0.00	0.09	17.70	9.95	0.62	59.50
2022-08-17	11:26:00	74.75	0.00	0.00	0.08	18.90	9.96	0.72	46.90
2022-08-17	11:27:00	77.55	0.00	0.00	0.08	21.50	9.75	0.63	37.30
2022-08-17	11:28:00	97.90	0.00	0.00	0.08	21.60	9.54	0.76	57.50
2022-08-17	11:29:00	71.31	0.00	0.00	0.08	21.80	9.95	0.48	34.60
2022-08-17	11:30:00	73.87	0.00	0.00	0.08	28.30	8.61	0.53	111.10
2022-08-17	11:31:00	76.93	0.00	0.00	0.08	21.80	8.83	0.43	158.10
2022-08-17	11:32:00	45.62	0.00	0.00	0.08	22.30	9.03	0.48	115.10
2022-08-17	11:33:00	45.59	0.00	0.00	0.08	18.90	9.32	0.41	112.40
2022-08-17	11:34:00	48.15	0.00	0.00	0.08	17.70	9.76	0.41	124.00
2022-08-17	11:35:00	46.08	0.00	0.00	0.08	17.20	9.78	0.26	75.50
2022-08-17	11:36:00	47.99	0.00	0.00	0.08	21.50	8.87	0.25	113.50
2022-08-17	11:37:00	55.95	0.00	0.00	0.08	17.60	9.84	0.41	95.60
2022-08-17	11:38:00	88.92	0.00	0.00	0.09	30.70	9.19	0.37	50.40
2022-08-17	11:39:00	49.12	0.00	0.00	0.08	20.70	8.77	0.30	115.00
2022-08-17	11:40:00	52.52	0.00	0.00	0.08	19.20	9.39	0.30	84.90
2022-08-17	11:41:00	65.60	0.00	0.00	0.09	20.40	9.18	0.28	76.90
2022-08-17	11:42:00	45.02	0.00	0.00	0.08	16.90	9.54	0.30	90.70
2022-08-17	11:43:00	54.52	0.00	0.00	0.08	17.90	9.32	0.17	67.60
2022-08-17	11:44:00	51.73	0.00	0.00	0.08	21.00	9.94	0.22	64.70
2022-08-17	11:45:00	53.01	0.00	0.00	0.08	19.10	8.85	0.30	112.50
2022-08-17	11:46:00	41.91	0.00	0.00	0.09	17.90	9.71	0.22	73.40
2022-08-17	11:47:00	73.14	0.00	0.00	0.08	25.30	8.82	0.21	66.40
2022-08-17	11:48:00	59.35	0.00	0.00	0.08	19.10	9.25	0.36	108.60
2022-08-17	11:49:00	68.29	0.00	0.00	0.08	23.20	9.25	0.30	77.80
2022-08-17	11:50:00	59.64	0.00	0.00	0.08	18.40	9.46	0.45	77.60
2022-08-17	11:51:00	52.84	0.00	0.00	0.08	18.30	9.46	0.45	84.20
2022-08-17	11:52:00	43.78	0.00	0.00	0.08	16.70	9.90	0.36	74.80
2022-08-17	11:53:00	61.16	0.00	0.00	0.08	19.10	9.90	0.45	42.00
2022-08-17	11:54:00	60.68	0.00	0.00	0.08	19.80	9.69	0.56	43.80
2022-08-17	11:55:00	72.31	0.00	0.00	0.08	22.20	9.26	0.48	56.60
2022-08-17	11:56:00	82.14	0.00	0.00	0.08	21.50	8.85	0.41	62.10
2022-08-17	11:57:00	60.30	0.00	0.00	0.08	19.50	9.81	0.37	60.50
2022-08-17	11:58:00	56.19	0.00	0.00	0.08	20.00	9.40	0.41	67.00
2022-08-17	11:59:00	53.16	0.00	0.00	0.08	18.90	9.94	0.26	54.50
2022-08-17	12:00:00	46.02	0.00	0.00	0.08	18.70	9.27	0.30	89.30
2022-08-17	12:01:00	55.51	0.00	0.00	0.08	18.30	10.31	0.18	61.80
2022-08-17	12:02:00	72.69	0.00	0.00	0.08	20.10	9.64	0.06	47.50
2022-08-17	12:03:00	57.65	0.00	0.00	0.08	19.40	9.85	0.22	46.80
2022-08-17	12:04:00	109.37	0.00	0.00	0.08	25.00	8.73	0.22	77.40
2022-08-17	12:05:00	68.04	0.00	0.00	0.08	18.00	9.63	0.35	60.10
2022-08-17	12:06:00	76.93	0.00	0.00	0.08	21.20	9.44	0.37	39.80
2022-08-17	12:07:00	60.43	0.00	0.00	0.08	17.80	10.08	0.45	79.70
2022-08-17	12:08:00	54.28	0.00	0.00	0.08	18.00	10.08	0.56	43.30
2022-08-17	12:09:00	74.53	0.00	0.00	0.08	19.40	9.65	0.30	59.60
2022-08-17	12:10:00	81.17	0.00	0.00	0.08	20.20	9.44	0.36	66.80
2022-08-17	12:11:00	58.07	0.00	0.00	0.09	18.80	9.64	0.48	40.30
2022-08-17	12:12:00	71.31	0.00	0.00	0.08	22.90	9.69	0.41	53.80
2022-08-17	12:13:00	89.09	0.00	0.00	0.08	24.10	8.40	0.42	107.50
2022-08-17	12:14:00	59.93	0.00	0.00	0.08	18.80	9.86	0.25	78.50
2022-08-17	12:15:00	64.86	0.00	0.00	0.08	21.40	9.22	0.18	61.50
2022-08-17	12:16:00	59.87	0.00	0.00	0.08	17.90	9.73	0.15	84.80
2022-08-17	12:17:00	76.08	0.00	0.00	0.09	19.60	9.73	0.36	58.20
2022-08-17	12:18:00	62.54	0.00	0.00	0.08	18.60	9.93	0.22	36.40

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	12:19:00	72.71	0.00	0.00	0.08	20.80	9.30	0.27	83.40
2022-08-17	12:20:00	49.32	0.00	0.00	0.08	17.20	9.73	0.48	68.60
2022-08-17	12:21:00	85.34	0.00	0.00	0.08	27.30	9.14	0.48	52.60
2022-08-17	12:22:00	54.78	0.00	0.00	0.08	18.40	9.72	0.46	89.20
2022-08-17	12:23:00	54.81	0.00	0.00	0.08	18.90	9.48	0.56	85.10
2022-08-17	12:24:00	57.35	0.00	0.00	0.08	18.80	10.32	0.45	39.50
2022-08-17	12:25:00	63.02	0.00	0.00	0.08	17.20	9.89	0.32	31.20
2022-08-17	12:26:00	64.54	0.00	0.00	0.09	22.10	9.67	0.15	27.10
2022-08-17	12:27:00	61.98	0.00	0.00	0.08	19.70	9.47	0.17	87.20
2022-08-17	12:28:00	68.11	0.00	0.00	0.09	21.30	9.07	0.26	62.80
2022-08-17	12:29:00	74.07	0.00	0.00	0.08	21.90	9.76	0.26	80.20
2022-08-17	12:30:00	76.27	0.00	0.00	0.08	22.10	8.94	0.15	46.90
2022-08-17	12:31:00	49.31	0.00	0.00	0.08	18.10	9.92	0.00	72.10
2022-08-17	12:32:00	54.46	0.00	0.00	0.08	19.40	9.28	0.31	72.30
2022-08-17	12:33:00	50.04	0.00	0.00	0.08	17.20	9.78	0.32	57.70
2022-08-17	12:34:00	57.07	0.00	0.00	0.08	17.50	10.00	0.32	47.80
2022-08-17	12:35:00	47.10	0.00	0.00	0.08	18.10	9.77	0.26	46.90
2022-08-17	12:36:00	63.88	0.00	0.00	0.08	18.70	9.77	0.25	53.70
2022-08-17	12:37:00	63.50	0.00	0.00	0.08	16.90	9.77	0.37	45.20
2022-08-17	12:38:00	64.74	0.00	0.00	0.08	21.70	9.34	0.26	47.90
2022-08-17	12:39:00	101.13	0.00	0.00	0.08	25.80	9.40	0.20	61.40
2022-08-17	12:40:00	55.07	0.00	0.00	0.08	18.50	9.82	0.22	76.80
2022-08-17	12:41:00	56.83	0.00	0.00	0.08	19.10	9.51	0.37	47.20
2022-08-17	12:42:00	73.91	0.00	0.00	0.09	18.60	9.99	0.33	45.90
2022-08-17	12:43:00	64.89	0.00	0.00	0.08	17.20	9.78	0.16	61.10
2022-08-17	12:44:00	72.82	0.00	0.00	0.08	22.40	9.75	0.18	35.50
2022-08-17	12:45:00	73.58	0.00	0.00	0.08	19.50	9.47	0.30	68.00
2022-08-17	12:46:00	48.13	0.00	0.00	0.09	20.10	9.52	0.30	60.50
2022-08-17	12:47:00	72.19	0.00	0.00	0.09	24.30	8.90	0.28	76.70
2022-08-17	12:48:00	49.16	0.00	0.00	0.08	17.70	10.11	0.22	67.70
2022-08-17	12:49:00	60.69	0.00	0.00	0.08	21.00	9.07	0.30	73.60
2022-08-17	12:50:00	46.75	0.00	0.00	0.08	16.30	9.80	0.18	63.90
2022-08-17	12:51:00	87.02	0.00	0.00	0.09	21.50	9.37	0.15	52.00
2022-08-17	12:52:00	64.60	0.00	0.00	0.08	18.20	9.82	0.11	70.30
2022-08-17	12:53:00	61.79	0.00	0.00	0.08	22.20	9.34	0.21	75.10
2022-08-17	12:54:00	53.62	0.00	0.00	0.08	16.30	9.78	0.18	65.80
2022-08-17	12:55:00	99.44	0.00	0.00	0.08	23.20	9.78	0.11	38.30
2022-08-17	12:56:00	99.03	0.00	0.00	0.08	23.80	10.00	0.16	68.20
2022-08-17	12:57:00	74.83	0.00	0.00	0.09	24.70	9.41	0.26	53.50
2022-08-17	12:58:00	66.54	0.00	0.00	0.08	18.40	9.46	0.41	95.70
2022-08-17	12:59:00	62.50	0.00	0.00	0.08	17.80	10.01	0.22	44.60
2022-08-17	13:00:00	81.59	0.00	0.00	0.08	19.10	9.81	0.17	46.40
2022-08-17	13:01:00	92.22	0.00	0.00	0.09	21.00	9.81	0.25	45.60
2022-08-17	13:02:00	83.09	0.00	0.00	0.08	21.70	9.61	0.21	46.50

August 17/2022		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
Test		AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	%	AT-263	AT-264-2NEW
Units		PPM	PPM	%	%	PPM	AT-261A-2NEW	%	PPM
Max		109.37	0.00	0.00	0.09	30.70	10.35	1.33	158.10
Min		41.91	0.00	0.00	0.08	16.30	8.40	0.00	27.10
Average		62.24	0.00	0.00	0.08	19.74	9.55	0.37	69.70
Variance		171.21	0.00	0.00	0.00	6.13	0.13	0.02	449.02

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	13:53:00	58.60	0.00	0.00	0.08	20.90	9.20	0.30	101.90
2022-08-17	13:54:00	41.86	0.00	0.00	0.08	17.80	9.42	0.26	85.30
2022-08-17	13:55:00	62.16	0.00	0.00	0.08	23.50	9.02	0.26	86.60
2022-08-17	13:56:00	63.73	0.00	0.00	0.08	18.90	9.12	0.22	126.00
2022-08-17	13:57:00	63.84	0.00	0.00	0.08	20.00	8.91	0.26	117.80
2022-08-17	13:58:00	43.86	0.00	0.00	0.08	17.20	9.50	0.15	86.30
2022-08-17	13:59:00	60.64	0.00	0.00	0.08	19.00	9.25	0.26	115.70
2022-08-17	14:00:00	43.65	0.00	0.00	0.08	16.80	9.47	0.18	104.80
2022-08-17	14:01:00	50.41	0.00	0.00	0.08	19.40	9.68	0.31	80.60
2022-08-17	14:02:00	56.77	0.00	0.00	0.09	22.10	9.27	0.30	66.10
2022-08-17	14:03:00	50.78	0.00	0.00	0.08	24.70	8.62	0.26	124.60
2022-08-17	14:04:00	57.71	0.00	0.00	0.08	23.80	8.41	0.28	120.00
2022-08-17	14:05:00	48.12	0.00	0.00	0.08	18.10	9.40	0.37	93.30
2022-08-17	14:06:00	124.75	0.00	0.00	0.08	29.30	8.33	0.40	126.90
2022-08-17	14:07:00	40.52	0.00	0.00	0.08	16.30	9.82	0.18	112.00
2022-08-17	14:08:00	46.21	0.00	0.00	0.08	18.80	9.39	0.13	82.90
2022-08-17	14:09:00	43.47	0.00	0.00	0.08	18.30	9.39	0.22	91.30
2022-08-17	14:10:00	52.12	0.00	0.00	0.08	21.20	9.19	0.13	90.90
2022-08-17	14:11:00	44.55	0.00	0.00	0.08	19.60	9.45	0.23	76.90
2022-08-17	14:12:00	69.01	0.00	0.00	0.08	23.30	8.58	0.27	150.10
2022-08-17	14:13:00	44.32	0.00	0.00	0.08	17.80	9.46	0.13	93.90
2022-08-17	14:14:00	49.03	0.00	0.00	0.08	19.80	9.26	0.31	105.40
2022-08-17	14:15:00	41.07	0.00	0.00	0.08	17.30	9.72	0.26	111.80
2022-08-17	14:16:00	53.96	0.00	0.00	0.08	17.30	9.71	0.37	71.90
2022-08-17	14:17:00	78.89	0.00	0.00	0.08	22.70	9.51	0.26	50.40
2022-08-17	14:18:00	63.29	0.00	0.00	0.08	20.60	9.31	0.33	101.60
2022-08-17	14:19:00	54.65	0.00	0.00	0.08	19.80	9.10	0.35	92.30
2022-08-17	14:20:00	41.23	0.00	0.00	0.08	20.40	9.53	0.33	83.80
2022-08-17	14:21:00	90.05	0.00	0.00	0.08	26.10	8.44	0.33	116.80
2022-08-17	14:22:00	52.46	0.00	0.00	0.08	17.20	9.52	0.30	106.10
2022-08-17	14:23:00	100.82	0.00	0.00	0.08	28.30	8.62	0.15	80.60
2022-08-17	14:24:00	54.60	0.00	0.00	0.08	17.20	9.08	0.22	139.70
2022-08-17	14:25:00	60.55	0.00	0.00	0.08	18.40	9.32	0.30	99.10
2022-08-17	14:26:00	45.79	0.00	0.00	0.08	18.40	9.74	0.21	69.20
2022-08-17	14:27:00	44.15	0.00	0.00	0.08	19.20	9.10	0.15	97.90
2022-08-17	14:28:00	46.27	0.00	0.00	0.08	17.00	9.77	0.26	59.50
2022-08-17	14:29:00	125.51	0.00	0.00	0.08	50.60	8.46	0.32	95.20
2022-08-17	14:30:00	60.02	0.00	0.00	0.08	18.90	9.40	0.35	132.00
2022-08-17	14:31:00	55.27	0.00	0.00	0.08	20.00	9.56	0.26	108.20
2022-08-17	14:32:00	49.45	0.00	0.00	0.08	20.80	9.57	0.30	81.20
2022-08-17	14:33:00	40.67	0.00	0.00	0.08	16.50	9.29	0.22	105.30
2022-08-17	14:34:00	43.27	0.00	0.00	0.08	16.60	9.69	0.10	53.90
2022-08-17	14:35:00	42.99	0.00	0.00	0.08	20.40	9.67	0.26	75.80
2022-08-17	14:36:00	43.04	0.00	0.00	0.08	17.90	9.02	0.37	122.90
2022-08-17	14:37:00	57.43	0.00	0.00	0.08	23.00	9.67	0.33	60.10
2022-08-17	14:38:00	47.84	0.00	0.00	0.08	22.70	8.35	0.33	112.90
2022-08-17	14:39:00	42.29	0.00	0.00	0.08	18.10	9.29	0.31	139.40
2022-08-17	14:40:00	52.57	0.00	0.00	0.08	23.30	9.27	0.30	69.70
2022-08-17	14:41:00	48.39	0.00	0.00	0.08	18.10	9.27	0.21	143.70
2022-08-17	14:42:00	43.25	0.00	0.00	0.08	19.50	8.86	0.35	145.70
2022-08-17	14:43:00	34.81	0.00	0.00	0.08	15.80	9.75	0.23	122.70
2022-08-17	14:44:00	42.94	0.00	0.00	0.08	21.00	9.12	0.30	112.30
2022-08-17	14:45:00	36.62	0.00	0.00	0.08	16.90	9.11	0.41	118.80
2022-08-17	14:46:00	42.17	0.00	0.00	0.09	20.30	9.11	0.45	87.10
2022-08-17	14:47:00	41.70	0.00	0.00	0.08	18.90	9.82	0.33	92.50
2022-08-17	14:48:00	46.49	0.00	0.00	0.08	20.60	8.73	0.36	118.70
2022-08-17	14:49:00	43.23	0.00	0.00	0.08	17.70	9.44	0.37	108.60
2022-08-17	14:50:00	49.50	0.00	0.00	0.08	19.50	9.22	0.30	79.50

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	14:51:00	35.04	0.00	0.00	0.08	17.80	9.22	0.18	121.80
2022-08-17	14:52:00	35.07	0.00	0.00	0.08	16.90	9.44	0.26	95.20
2022-08-17	14:53:00	47.95	0.00	0.00	0.08	18.90	9.44	0.37	61.90
2022-08-17	14:54:00	38.58	0.00	0.00	0.08	21.70	9.44	0.22	77.60
2022-08-17	14:55:00	51.95	0.00	0.00	0.08	23.90	8.52	0.41	131.30
2022-08-17	14:56:00	37.46	0.00	0.00	0.08	17.00	9.61	0.37	94.80
2022-08-17	14:57:00	41.61	0.00	0.00	0.08	18.70	9.19	0.33	103.30
2022-08-17	14:58:00	44.07	0.00	0.00	0.08	16.80	9.15	0.31	89.00
2022-08-17	14:59:00	43.27	0.00	0.00	0.08	16.60	9.59	0.26	85.30
2022-08-17	15:00:00	38.00	0.00	0.00	0.08	17.20	9.39	0.22	76.50
2022-08-17	15:01:00	39.60	0.00	0.00	0.08	18.60	8.96	0.27	123.80
2022-08-17	15:02:00	40.51	0.00	0.00	0.08	17.80	9.44	0.33	71.20
2022-08-17	15:03:00	47.61	0.00	0.00	0.08	23.70	8.80	0.30	106.90
2022-08-17	15:04:00	42.60	0.00	0.00	0.08	19.60	9.66	0.35	147.00
2022-08-17	15:05:00	37.08	0.00	0.00	0.08	18.60	9.64	0.33	78.30
2022-08-17	15:06:00	39.18	0.00	0.00	0.08	17.60	9.26	0.33	85.70
2022-08-17	15:07:00	36.73	0.00	0.00	0.08	16.30	9.61	0.31	87.20
2022-08-17	15:08:00	39.51	0.00	0.00	0.09	16.80	9.19	0.36	87.10
2022-08-17	15:09:00	38.36	0.00	0.00	0.08	18.70	9.82	0.07	60.80
2022-08-17	15:10:00	39.93	0.00	0.00	0.09	18.30	9.11	0.22	106.10
2022-08-17	15:11:00	49.94	0.00	0.00	0.09	18.80	9.76	0.26	62.20
2022-08-17	15:12:00	53.81	0.00	0.00	0.08	21.40	8.91	0.33	73.90
2022-08-17	15:13:00	47.83	0.00	0.00	0.08	17.30	9.37	0.33	88.20
2022-08-17	15:14:00	58.66	0.00	0.00	0.08	19.70	9.34	0.37	56.20
2022-08-17	15:15:00	42.89	0.00	0.00	0.08	16.00	9.74	0.37	58.40
2022-08-17	15:16:00	45.71	0.00	0.00	0.08	17.20	9.52	0.33	70.20
2022-08-17	15:17:00	44.83	0.00	0.00	0.08	16.30	9.94	0.30	51.50
2022-08-17	15:18:00	59.96	0.00	0.00	0.08	19.20	9.11	0.38	87.10
2022-08-17	15:19:00	40.48	0.00	0.00	0.08	16.60	9.22	0.36	108.50
2022-08-17	15:20:00	43.89	0.00	0.00	0.08	17.70	9.65	0.35	64.90
2022-08-17	15:21:00	52.19	0.00	0.00	0.08	21.00	9.90	0.33	70.90
2022-08-17	15:22:00	39.50	0.00	0.00	0.09	18.60	9.22	0.26	102.80
2022-08-17	15:23:00	0.78	0.00	0.00	0.08	3.60	21.17	0.35	0.00
2022-08-17	15:24:00	37.73	0.00	0.00	0.08	17.90	10.07	0.30	0.00
2022-08-17	15:25:00	37.89	0.00	0.00	0.08	17.00	9.40	0.31	46.50
2022-08-17	15:26:00	41.72	0.00	0.00	0.08	17.30	10.06	0.21	35.50
2022-08-17	15:27:00	58.05	0.00	0.00	0.08	19.60	9.20	0.41	46.20
2022-08-17	15:28:00	37.62	0.00	0.00	0.08	18.10	9.68	0.31	70.80
2022-08-17	15:29:00	46.41	0.00	0.00	0.08	21.10	9.27	0.27	41.40
2022-08-17	15:30:00	34.23	0.00	0.00	0.08	12.90	10.45	0.11	45.60
2022-08-17	15:31:00	26.68	0.00	0.00	0.08	9.30	10.02	0.06	102.30
2022-08-17	15:32:00	24.50	0.00	0.00	0.09	9.80	10.82	0.07	155.40
2022-08-17	15:33:00	465.83	0.00	0.00	0.09	11.90	12.27	0.06	37.50
2022-08-17	15:34:00	162.86	0.00	0.00	0.08	10.00	13.94	0.06	0.00
2022-08-17	15:35:00	24.23	0.00	0.00	0.09	10.20	14.35	0.06	0.00
2022-08-17	15:36:00	23.32	0.00	0.00	0.08	10.10	14.57	0.07	0.00
2022-08-17	15:37:00	22.15	0.00	0.00	0.08	10.30	14.57	0.15	0.00
2022-08-17	15:38:00	22.08	0.00	0.00	0.09	10.00	14.57	0.25	0.00
2022-08-17	15:39:00	23.05	0.00	0.00	0.08	10.50	14.57	0.20	0.00
2022-08-17	15:40:00	23.37	0.00	0.00	0.08	10.30	14.57	0.06	0.00
2022-08-17	15:41:00	23.79	0.00	0.00	0.08	10.40	14.78	0.07	0.00
2022-08-17	15:42:00	22.93	0.00	0.00	0.08	10.50	14.78	0.06	0.00
2022-08-17	15:43:00	22.89	0.00	0.00	0.08	10.60	14.78	0.11	0.00
2022-08-17	15:44:00	22.77	0.00	0.00	0.09	10.60	14.78	0.17	0.00
2022-08-17	15:45:00	21.83	0.00	0.00	0.08	8.20	13.10	0.11	0.00
2022-08-17	15:46:00	20.82	0.00	0.00	0.08	7.70	10.91	0.15	0.00
2022-08-17	15:47:00	20.57	0.00	0.00	0.08	6.10	13.02	0.11	167.40
2022-08-17	15:48:00	24.12	0.00	0.00	0.08	6.60	14.57	0.15	203.00

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	15:49:00	24.54	0.00	0.00	0.08	10.20	12.58	0.18	160.20
2022-08-17	15:50:00	32.04	0.00	0.00	0.08	12.90	11.04	0.23	55.90
2022-08-17	15:51:00	39.24	0.00	0.00	0.09	13.90	10.87	0.15	19.40
2022-08-17	15:52:00	86.65	0.00	0.00	0.09	17.60	10.22	0.22	1.10
2022-08-17	15:53:00	70.09	0.00	0.00	0.08	18.50	9.64	0.33	23.60
2022-08-17	15:54:00	64.98	0.00	0.00	0.09	21.80	8.93	0.30	83.20
2022-08-17	15:55:00	79.13	0.00	0.00	0.08	18.10	9.35	0.30	77.20
2022-08-17	15:56:00	87.68	0.00	0.00	0.08	18.30	10.24	0.30	32.90
2022-08-17	15:57:00	101.29	0.00	0.00	0.08	19.10	9.60	0.37	33.60
2022-08-17	15:58:00	101.39	0.00	0.00	0.08	17.70	10.40	0.33	23.10
2022-08-17	15:59:00	98.82	0.00	0.00	0.08	19.20	10.40	0.22	0.00
2022-08-17	16:00:00	113.09	0.00	0.00	0.08	21.00	10.61	0.26	1.10
2022-08-17	16:01:00	142.08	0.00	0.00	0.08	22.10	9.94	0.33	28.10
2022-08-17	16:02:00	86.67	0.00	0.00	0.08	19.90	10.18	0.30	37.90
2022-08-17	16:03:00	106.59	0.00	0.00	0.09	22.30	9.56	0.30	28.10
2022-08-17	16:04:00	103.63	0.00	0.00	0.08	18.20	10.05	0.38	57.90
2022-08-17	16:05:00	96.43	0.00	0.00	0.08	21.70	9.65	0.20	42.50
2022-08-17	16:06:00	104.27	0.00	0.00	0.08	18.60	10.11	0.23	43.00
2022-08-17	16:07:00	131.58	0.00	0.00	0.09	20.30	10.12	0.26	37.00
2022-08-17	16:08:00	142.41	0.00	0.00	0.08	19.20	10.18	0.27	24.70
2022-08-17	16:09:00	96.88	0.00	0.00	0.08	23.00	9.56	0.33	53.40
2022-08-17	16:10:00	97.70	0.00	0.00	0.08	22.70	9.79	0.36	67.00
2022-08-17	16:11:00	84.51	0.00	0.00	0.08	23.40	9.12	0.41	76.00
2022-08-17	16:12:00	98.34	0.00	0.00	0.08	21.40	9.12	0.38	70.30
2022-08-17	16:13:00	91.82	0.00	0.00	0.09	20.80	9.76	0.50	54.90
2022-08-17	16:14:00	81.52	0.00	0.00	0.08	22.10	9.15	0.41	75.20
2022-08-17	16:15:00	58.37	0.00	0.00	0.08	18.70	9.80	0.33	97.30
2022-08-17	16:16:00	86.29	0.00	0.00	0.08	20.70	9.59	0.38	83.20
2022-08-17	16:17:00	67.20	0.00	0.00	0.08	19.20	9.80	0.18	68.10
2022-08-17	16:18:00	89.34	0.00	0.00	0.08	21.20	9.14	0.18	101.70
2022-08-17	16:19:00	61.00	0.00	0.00	0.08	19.50	9.33	0.31	86.80
2022-08-17	16:20:00	85.92	0.00	0.00	0.08	23.70	8.89	0.33	107.90
2022-08-17	16:21:00	77.28	0.00	0.00	0.08	18.60	9.34	0.31	90.40
2022-08-17	16:22:00	63.65	0.00	0.00	0.08	21.20	9.34	0.30	95.30
2022-08-17	16:23:00	62.31	0.00	0.00	0.08	19.00	9.42	0.38	103.80
2022-08-17	16:24:00	73.12	0.00	0.00	0.09	20.30	9.66	0.38	76.30
2022-08-17	16:25:00	62.63	0.00	0.00	0.08	19.70	9.64	0.36	97.40
2022-08-17	16:26:00	80.13	0.00	0.00	0.08	21.10	9.42	0.36	68.10
2022-08-17	16:27:00	58.01	0.00	0.00	0.08	20.90	9.01	0.42	96.50
2022-08-17	16:28:00	57.76	0.00	0.00	0.08	22.70	9.23	0.20	102.00
2022-08-17	16:29:00	61.26	0.00	0.00	0.08	23.70	8.40	0.26	120.80
2022-08-17	16:30:00	48.16	0.00	0.00	0.09	19.20	9.45	0.26	111.00
2022-08-17	16:31:00	64.41	0.00	0.00	0.08	25.30	9.02	0.33	89.70
2022-08-17	16:32:00	45.56	0.00	0.00	0.08	17.20	9.61	0.31	115.50
2022-08-17	16:33:00	62.63	0.00	0.00	0.09	22.10	9.39	0.37	70.10
2022-08-17	16:34:00	49.70	0.00	0.00	0.08	18.10	9.81	0.45	105.50
2022-08-17	16:35:00	74.92	0.00	0.00	0.08	22.10	8.97	0.30	88.70
2022-08-17	16:36:00	42.31	0.00	0.00	0.08	17.20	9.31	0.36	99.70
2022-08-17	16:37:00	59.57	0.00	0.00	0.08	23.40	8.73	0.41	99.50
2022-08-17	16:38:00	49.56	0.00	0.00	0.08	19.10	9.67	0.33	131.60
2022-08-17	16:39:00	66.06	0.00	0.00	0.08	21.70	9.01	0.32	113.70
2022-08-17	16:40:00	38.36	0.00	0.00	0.08	13.20	10.53	0.36	98.70
2022-08-17	16:41:00	31.07	0.00	0.00	0.08	11.90	11.38	0.38	92.00
2022-08-17	16:42:00	31.32	0.00	0.00	0.08	14.00	10.48	0.26	109.10
2022-08-17	16:43:00	49.24	0.00	0.00	0.08	20.10	9.63	0.35	74.40
2022-08-17	16:44:00	42.36	0.00	0.00	0.08	18.90	9.19	0.35	92.70
2022-08-17	16:45:00	53.91	0.00	0.00	0.08	22.60	9.44	0.33	76.10
2022-08-17	16:46:00	46.03	0.00	0.00	0.08	21.90	8.78	0.46	117.80

		Analyzers							
		Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
		PPM	PPM	%	%	PPM	%	%	PPM
\$Date	\$Time	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	AT-261A-2NEW	AT-263	AT-264-2NEW
2022-08-17	16:47:00	47.00	0.00	0.00	0.08	18.60	9.31	0.35	123.70
2022-08-17	16:48:00	56.17	0.00	0.00	0.08	20.20	9.31	0.46	94.00
2022-08-17	16:49:00	58.93	0.00	0.00	0.08	18.40	9.65	0.31	64.90
2022-08-17	16:50:00	62.16	0.00	0.00	0.08	16.90	9.85	0.30	66.70
2022-08-17	16:51:00	66.15	0.00	0.00	0.08	19.40	9.42	0.26	50.30
2022-08-17	16:52:00	63.93	0.00	0.00	0.08	17.40	9.63	0.37	55.30
2022-08-17	16:53:00	83.43	0.00	0.00	0.08	22.90	9.02	0.46	54.00
2022-08-17	16:54:00	62.64	0.00	0.00	0.08	18.50	10.11	0.42	77.90
2022-08-17	16:55:00	67.07	0.00	0.00	0.08	21.50	9.60	0.37	63.20
2022-08-17	16:56:00	79.24	0.00	0.00	0.08	19.80	9.77	0.41	71.60
2022-08-17	16:57:00	72.32	0.00	0.00	0.08	18.10	9.78	0.45	54.40
2022-08-17	16:58:00	105.66	0.00	0.00	0.08	19.60	9.78	0.30	56.80
2022-08-17	16:59:00	81.42	0.00	0.00	0.08	19.20	9.78	0.31	67.60
2022-08-17	17:00:00	69.82	0.00	0.00	0.08	21.80	9.36	0.45	52.30
2022-08-17	17:01:00	80.18	0.00	0.00	0.08	25.70	9.33	0.41	64.90
2022-08-17	17:02:00	58.71	0.00	0.00	0.08	21.20	9.10	0.46	88.00
2022-08-17	17:03:00	53.38	0.00	0.00	0.08	17.70	9.36	0.38	110.50
2022-08-17	17:04:00	83.40	0.00	0.00	0.08	22.50	9.15	0.48	71.80
2022-08-17	17:05:00	57.21	0.00	0.00	0.08	17.70	9.57	0.37	76.70
2022-08-17	17:06:00	59.53	0.00	0.00	0.08	18.90	9.57	0.33	70.30
2022-08-17	17:07:00	50.63	0.00	0.00	0.08	17.20	9.78	0.30	59.50
2022-08-17	17:08:00	77.56	0.00	0.00	0.08	20.70	9.09	0.33	95.20
2022-08-17	17:09:00	75.44	0.00	0.00	0.08	18.90	9.33	0.36	66.70
2022-08-17	17:10:00	62.52	0.00	0.00	0.08	22.10	8.65	0.30	102.60
2022-08-17	17:11:00	58.36	0.00	0.00	0.08	20.70	9.82	0.45	95.70
2022-08-17	17:12:00	62.11	0.00	0.00	0.08	21.40	9.31	0.37	69.10
2022-08-17	17:13:00	68.69	0.00	0.00	0.08	20.40	9.10	0.45	105.10
2022-08-17	17:14:00	64.78	0.00	0.00	0.08	20.10	9.43	0.48	84.70
2022-08-17	17:15:00	70.74	0.00	0.00	0.08	18.70	9.43	0.33	73.70
2022-08-17	17:16:00	59.50	0.00	0.00	0.08	20.70	9.26	0.35	50.50
2022-08-17	17:17:00	55.25	0.00	0.00	0.08	20.00	9.26	0.37	67.00
2022-08-17	17:18:00	61.57	0.00	0.00	0.08	20.40	9.26	0.50	84.20
2022-08-17	17:19:00	77.48	0.00	0.00	0.08	30.20	8.65	0.51	95.80
2022-08-17	17:20:00	53.81	0.00	0.00	0.08	18.50	9.36	0.48	114.10
2022-08-17	17:21:00	63.82	0.00	0.00	0.08	21.20	9.15	0.38	72.90
2022-08-17	17:22:00	46.22	0.00	0.00	0.08	17.10	9.57	0.46	68.90
2022-08-17	17:23:00	88.28	0.00	0.00	0.08	21.90	9.36	0.36	68.90
2022-08-17	17:24:00	62.90	0.00	0.00	0.08	18.10	9.80	0.13	69.90
2022-08-17	17:25:00	86.04	0.00	0.00	0.08	22.00	8.98	0.37	84.10
2022-08-17	17:26:00	61.01	0.00	0.00	0.08	18.80	9.41	0.45	70.50
2022-08-17	17:27:00	62.06	0.00	0.00	0.08	24.10	8.99	0.50	80.30
2022-08-17	17:28:00	54.33	0.00	0.00	0.08	21.20	9.73	0.37	125.30

August 17/2022	Analyzers							
	Backup CO	Main HCl	Main CO2	Main H2O	THC	Backup O2	Opacity	Backup SO2
	AT-205-2NEW	AT-213A-1NEW	AT-213B-1NEW	AT-213CB	AT-259-1NEW	%	AT-263	AT-264-2NEW
Test	PPM	PPM	%	%	PPM	AT-261A-2NEW	%	PPM
Units								
Max	465.83	0.00	0.00	0.09	50.60	21.17	0.51	203.00
Min	0.78	0.00	0.00	0.08	3.60	8.33	0.06	0.00
Average	59.60	0.00	0.00	0.08	18.83	9.85	0.30	79.04
Variance	1369.00	0.00	0.00	0.00	20.61	2.37	0.01	1382.61

APPENDIX 19

**Clean Harbors One-Minute Average
Process Data
(8 pages)**

SDate	STime	Waste Flows										Air Flows										Temperatures										Pressures																																																																																																																																																																																																																																							
		Rich		Emulsion		Lean		Alkaline		TDU Flow		Leachate		PAC		Primary		Secondary		Stack Velocity		Stack Flow		Primary		Secondary A		Secondary B		Quench		SDA		Stack		Incinerator		SDA Inlet		BH Inlet		BH dP																																																																																																																																																																																																																													
		LPM	FT-229	LPM	FT-219C	LPM	FT-223	LPM	PV-207	LPM	FT-313B	LPM	FT-313	LPM	PV-211	SC-PAC-FT	PV-236	m3/h	PV-209	m3/h	FT-260-VEL	m/s	FT-260-aream	Rm3/s	TE-240	Degrees C	TE-241	Degrees C	TE-203	Degrees C	TE-204	Degrees C	TE-258	Degrees C	PT-249	mmH2O	PT-615	mmH2O	PT-615	mmH2O	PDI-622	mmH2O																																																																																																																																																																																																																													
2022-08-17	12:52:00	35.27	6.71	160.05	186.08	4.76	285.45	14.29	34.36	17044	11489	25.62	107357	1344.1	1123.1	1119.0	448.8	193.5	191.6	-12.2	-57.1	-103.6	296.1	2022-08-17	12:53:00	32.67	6.55	157.71	185.67	4.74	284.40	14.29	34.36	17138	11376	25.38	106452	1345.1	1124.2	1120.1	448.9	194.0	191.6	-9.7	-51.8	-100.0	304.0	2022-08-17	12:54:00	31.70	6.74	162.71	184.59	4.75	285.00	14.29	34.62	17194	11511	24.99	104824	1340.3	1118.4	1115.7	448.7	193.5	191.6	-5.8	-46.5	-93.8	326.0	2022-08-17	12:55:00	33.95	6.63	158.96	185.81	4.72	283.28	14.29	33.92	16694	11393	25.00	104849	1343.4	1115.4	1112.4	448.5	192.0	191.6	-5.7	-45.9	-88.4	335.4	2022-08-17	12:56:00	35.55	6.78	160.14	185.36	4.81	288.60	14.29	34.91	17363	11489	25.46	106809	1343.4	1116.3	1113.5	448.1	191.5	191.6	-11.8	-56.1	-104.3	308.3	2022-08-17	12:57:00	35.16	6.80	159.54	186.17	4.72	282.98	14.29	34.62	17031	11365	25.94	108935	1347.5	1121.5	1117.7	447.9	191.5	191.6	-8.9	-50.5	-99.1	319.7	2022-08-17	12:58:00	34.34	6.72	159.63	184.91	4.76	285.75	14.29	33.76	17469	11539	26.41	110919	1342.1	1121.2	1118.7	447.7	191.5	191.6	-17.2	-65.6	-116.7	285.5	2022-08-17	12:59:00	35.10	6.65	159.01	185.54	4.75	285.08	14.29	33.84	17275	11618	25.91	108783	1339.4	1116.9	1114.7	447.5	192.0	191.6	-16.5	-62.3	-109.4	298.8	2022-08-17	13:00:00	33.98	6.56	162.75	184.10	4.81	288.68	14.29	34.18	17250	11579	26.32	110527	1339.0	1113.4	1113.4	447.3	192.0	191.6	-13.9	-60.9	-111.0	289.9	2022-08-17	13:01:00	32.54	6.56	159.01	184.86	4.72	282.90	14.29	33.92	17056	11523	24.97	104903	1340.0	1115.4	1112.4	447.6	192.5	191.6	-11.9	-55.9	-101.8	300.8	2022-08-17	13:02:00	31.26	6.56	158.06	183.65	4.72	283.13	14.29	34.91	17613	11770	25.35	106449	1343.8	1118.2	1114.6	447.5	192.0	191.6	-18.3	-64.5	-117.1	306.1

August 17/2022		Waste Flows										Air Flows										Temperatures										Pressures				
Test	Units	Rich	Emulsion	Lean	Alkaline	TDU Flow	Leachate	PAC Flow	Primary	Secondary	Stack Velocity	Stack Flow	Primary	Secondary A	Secondary B	Quench	SprayDryer	Stack	Incinerator	SDA Inlet	BH Inlet	BH dP														
		LPM	LPM	LPM	LPM	FT-313B	PV-211	SC-PAC-FT	PV-236	m3/h	m3/h	FT-260-VEL	FT-260-aream	TE-240	TE-241A	TE-241B	Degrees C	Degrees C	Degrees C	PT-249A	PT-249B	PDI-622														
Max		37.86	7.10	163.08	187.29	4.94	296.55	14.29	35.25	18125	11770	28.41	118909	1361.4	1137.7	1132.8	457.0	198.5	194.7	-1.6	-40.4	-84.1														
Min		31.26	6.21	153.24	183.65	4.28	256.58	13.13	33.47	16544	11264	24.07	108800	1332.9	1108.0	1105.4	447.3	188.0	189.6	-30.1	-82.8	-128.6														
Average		35.09	6.75	158.21	185.46	4.72	283.29	14.11	34.38	17247	11514	25.82	108016	1345.7	1122.6	1119.0	453.3	194.5	193.0	-14.3	-58.6	-103.9														
Variance		1.63	0.02	2.69	0.42	0.02	84.37	0.04	0.21	86961	9773	0.76	13365572	30.6	21.3	19.6	5.6	3.4	40.5	91.2	110.8															

SDate	STime	Waste Flows				Air Flows				Temperatures						Pressures							
		Rich LPM	Emulsion LPM	Lean LPM	Alkaline LPM	TDU Flow LPM	TDU Flow SCFM	Leachate LPM	PAC Lbs/h	Primary m3/h	Secondary m3/h	Stack Velocity m/s	Stack Flow Rm3/s	Primary Degrees C	Secondary A Degrees C	Secondary B Degrees C	Quench Degrees C	SDA Degrees C	Stack Degrees C	Incinerator mmH2O	SDA Inlet mmH2O	BH Inlet mmH2O	BH GP mmH2O
2022-08-17	17:20:00	34.38	6.56	160.57	184.19	4.76	FT-313B	FT-313	PV-211	SC-PAC-FT	PV-236	PV-209	FT-260-VEL	FT-260-RFORM	TE-240	TE-241	TE-203	TE-204	TE-258	PT-242A	PT-249	PT-615	PDT-622
2022-08-17	17:21:00	33.39	6.33	159.54	183.15	4.71	282.38	14.21	35.04	16369	11388	26.88	112748	1386.8	1140.1	1136.1	449.1	194.0	193.3	-9.0	-44.0	-93.0	308.8
2022-08-17	17:22:00	33.71	6.41	161.04	183.29	4.71	282.75	14.21	34.28	16781	11506	26.13	109252	1382.6	1138.0	1133.9	449.0	194.5	193.3	-18.3	-56.4	-106.4	288.3
2022-08-17	17:23:00	34.07	6.38	159.77	183.20	4.72	283.28	14.21	33.71	16681	11416	26.01	108773	1383.5	1136.4	1132.9	449.1	195.0	193.3	-13.6	-51.0	-99.3	297.7
2022-08-17	17:24:00	34.23	6.35	160.44	184.05	4.76	285.75	14.21	33.76	16550	11315	26.07	109019	1385.0	1134.2	1130.9	448.9	195.5	193.3	-11.7	-47.0	-97.0	289.7
2022-08-17	17:25:00	33.81	6.43	159.54	183.47	4.76	285.30	14.21	34.07	16425	11433	25.43	106315	1385.9	1135.3	1130.9	448.9	195.0	193.3	-10.1	-43.3	-91.0	298.1
2022-08-17	17:26:00	33.83	6.72	160.76	184.59	4.73	283.80	14.21	33.81	16406	11545	25.34	106291	1385.4	1135.2	1130.9	449.1	195.0	193.3	-6.9	-38.5	-88.8	323.7
2022-08-17	17:27:00	34.08	6.51	159.67	183.96	4.75	285.00	14.21	34.05	16138	11281	25.34	105967	1387.6	1139.4	1134.2	448.9	194.5	193.3	-4.6	-36.1	-82.2	330.6
2022-08-17	17:28:00	34.52	6.51	161.47	184.14	4.74	284.40	14.21	34.31	16831	11438	25.81	107976	1385.4	1140.0	1136.2	448.9	193.5	193.3	-12.7	-48.5	-97.4	301.1

Test	Units	Max	Min	Average	Variance	Waste Flows				Air Flows				Temperatures						Pressures							
						Rich LPM	Emulsion LPM	Lean LPM	Alkaline LPM	TDU Flow LPM	TDU Flow SCFM	Leachate LPM	PAC Lbs/h	Primary m3/h	Secondary m3/h	Stack Velocity m/s	Stack Flow Rm3/s	Primary Degrees C	Secondary A Degrees C	Secondary B Degrees C	Quench Degrees C	SprayDryer Degrees C	Stack Degrees C	Incinerator mmH2O	SDA Inlet mmH2O	SD Outlet mmH2O	Baghouse PDI-622 mmH2O
August 17/2022						34.38	6.56	160.57	184.19	4.76	FT-313B	FT-313	PV-211	SC-PAC-FT	PV-236	PV-209	FT-260-VEL	FT-260-RFORM	TE-240	TE-241A	TE-203	TE-204	TE-258	PT-242A	PT-249	PT-615	PDT-622
						33.39	6.33	159.54	183.15	4.71	282.38	14.40	16369	11388	26.88	112748	1386.8	1140.1	1136.1	449.1	194.0	193.3	-9.0	-44.0	-93.0	308.8	
						33.71	6.41	161.04	183.29	4.71	282.75	14.21	16781	11506	26.13	109252	1382.6	1138.0	1133.9	449.0	194.5	193.3	-18.3	-56.4	-106.4	288.3	
						34.07	6.38	159.77	183.20	4.72	283.28	14.21	16681	11416	26.01	108773	1383.5	1136.4	1132.9	449.1	195.0	193.3	-13.6	-51.0	-99.3	297.7	
						34.23	6.35	160.44	184.05	4.76	285.75	14.21	16550	11315	26.07	109019	1385.0	1134.2	1130.9	448.9	195.5	193.3	-11.7	-47.0	-97.0	289.7	
						33.81	6.43	159.54	183.47	4.76	285.30	14.21	16425	11433	25.43	106315	1385.9	1135.3	1130.9	448.9	195.0	193.3	-10.1	-43.3	-91.0	298.1	
						33.83	6.72	160.76	184.59	4.73	283.80	14.21	16406	11545	25.34	106291	1385.4	1135.2	1130.9	449.1	195.0	193.3	-6.9	-38.5	-88.8	323.7	
						34.08	6.51	159.67	183.96	4.75	285.00	14.21	16138	11281	25.34	105967	1387.6	1139.4	1134.2	448.9	194.5	193.3	-4.6	-36.1	-82.2	330.6	
						34.52	6.51	161.47	184.14	4.74	284.40	14.21	16831	11438	25.81	107976	1385.4	1140.0	1136.2	448.9	193.5	193.3	-12.7	-48.5	-97.4	301.1	