



Report:

Mercury Emission Testing at the Clean Harbors Sarnia Facility (June 2023)

Date: July 25, 2023



Report:

Mercury Emission Testing at the Clean Harbors Sarnia Facility (June 2023)

Submitted to: Mackenzie Costello
Senior Environmental Compliance Manager
Clean Harbors Canada
4090 Telfer Road, RR #1 Corunna, Ontario NON 1G0
Tel: (519) 864-3890
Cell: (343) 370-6701
E-mail: costello.mackenzie@cleanharbors.com

Prepared by: Tina Sanderson, B.Sc.
Senior Project Manager, Emission Testing
ORTECH Consulting Inc.
804 Southdown Rd., Mississauga, Ontario L5J 2Y4
Tel: (905) 822-4120, Ext. 522
Email: tsanderson@ortech.ca

Report No.: 22278
10 pages, 5 Appendices

Revision History

| Version | Date | Summary Changes/Purpose of Revision |
|---------|---------------|-------------------------------------|
| 1 | July 25, 2023 | None |
| | | |
| | | |

NOTICE:

This report was prepared by ORTECH Consulting Inc. (ORTECH) solely for the Client identified above and is to be used exclusively for the purposes set out in the report. The material in this report reflects the judgment of ORTECH based on information available to them at the time of preparation. Unless manifestly incorrect, ORTECH assumes information provided by others is accurate. Changed conditions or information occurring or becoming known after the date of this report could affect the results and conclusions presented. Unless otherwise required by law or regulation, this report shall not be shared with any Third Party without the express written consent of ORTECH. ORTECH accepts no responsibility for damages, if any, suffered by any Third Party which makes use of the results and conclusions presented in this report.

Table of Contents

| | Page |
|--|------|
| EXECUTIVE SUMMARY | 4 |
| 1. INTRODUCTION | 5 |
| 2. SAMPLING LOCATION | 5 |
| 3. SAMPLING METHODOLOGY | 6 |
| 4. ANALYSIS METHODOLOGY | 7 |
| 5. QUALITY ASSURANCE/QUALITY CONTROL PROGRAM | 8 |
| 6. RESULTS | 9 |
| 7. FACILITY PROCESS DATA | 10 |
| | |
| APPENDIX 1 Data Tables | |
| APPENDIX 2 Mercury Field Data Sheets | |
| APPENDIX 3 ORTECH Equipment Calibration Data | |
| APPENDIX 4 Mercury Analytical Report | |
| APPENDIX 5 Clean Harbors Process Data | |

EXECUTIVE SUMMARY

ORTECH Consulting Inc. (ORTECH) was requested by Clean Harbors Canada Inc. (Clean Harbors) to conduct a mercury emission testing program at the incineration facility located in Corunna, Ontario.

Mercury emission tests were performed at the Incinerator Exhaust Stack following the procedures outlined in US EPA Method 30B, “*Determination of Total Vapour Phase Mercury Emissions from Coal-Fired Combustion Sources Using Carbon Sorbent Traps*” to determine the amount of total vapour phase mercury present in the gas stream.

The test method states that the recovery spike must be within 50 to 150 percent of the expected mass collected in the traps during sampling. Six pairs of tube samples were collected during two days of testing on June 27 and June 28, 2023. To try to ensure that at least one of the spike concentrations would fall within the concentration range requirements of the test method one tube from each of the six pairs of adsorbent tubes were spiked with increasing amounts of mercury, ranging from 150 ng to 2000 ng, by the analytical laboratory prior to commencing the test program.

The results of three of the pairs of tubes, including the spikes that best represented the mercury concentration in the stack gas at the time of testing, are reported.

The average combustion gas values for each test period were obtained from the plant continuous emission monitoring (CEM) system. The average oxygen concentration for each test was used to determine the dry reference concentration adjusted to 11% oxygen.

The average mercury emission data from the triplicate total vapour phase mercury tests reported is provided below:

| Mercury Parameter | Average |
|--|---------|
| Dry Reference Concentration ($\mu\text{g}/\text{Rm}^3$)* | 7.37 |
| Dry Adjusted Concentration ($\mu\text{g}/\text{Rm}^3$)** | 6.19 |

* reference conditions are 25°C and 1 atmosphere

** at 25°C and 1 atmosphere, adjusted to 11% oxygen

During the emission testing program, the powdered activated carbon (PAC) injection rate was 23.6 lb/hr.

1. INTRODUCTION

ORTECH Consulting Inc. (ORTECH) was requested by Clean Harbors Canada Inc. (Clean Harbors) to conduct a mercury emission testing program at the incineration facility located in Corunna, Ontario.

Mercury emission tests were performed at the Incinerator Exhaust Stack following the procedures outlined in US EPA Method 30B to determine the amount of total vapour phase mercury present in the gas stream.

The average combustion gas values for each test period were obtained from the plant continuous emission monitoring (CEM) system. The average oxygen concentration for each test was used to determine the dry reference concentration adjusted to 11% oxygen.

Six pairs of adsorbent tubes were collected during two days of sampling on June 27 and June 28, 2023. The spike tubes from each test pair were spiked with increasing amounts of mercury, ranging from 150 ng to 2000 ng, prior to commencing the test program to try to ensure that at least one of the spike concentrations would fall within the concentration range requirements of the test method. The test method states that the recovery spike should be within 50 to 150 percent of the expected mass collected in the traps during sampling. The results of three of the pairs of tubes, including the spikes that best represented the mercury concentration in the stack gas at the time of testing, are reported.

All tables referenced herein are included in Appendix 1.

2. SAMPLING LOCATION

The Incinerator Exhaust Stack has an inside diameter of 1.47 meters at the sampling platform and 1.22 meters at the stack exit. The stack height above grade is 68.6 meters.

Mercury sampling was conducted at the breeching connecting the induced draft fan to the stack. Sampling was conducted at a single point in the center of the duct.

Previous testing programs conducted by ORTECH at the Clean Harbors Incinerator Exhaust Stack have shown that there is no stack gas stratification between the breeching connecting the induced draft fan to the stack and the stack sampling platform location.

3. SAMPLING METHODOLOGY

Mercury emission tests were performed following the procedures outlined in US EPA Method 30B, “Determination of Total Vapour Phase Mercury Emissions from Coal-Fired Combustion Sources Using Carbon Sorbent Traps”.

ORTECH used a dual probe assembly so that the mercury traps are positioned 1 to 2 inches apart. Each probe was heated to approximately 135°C to prevent condensation of the stack gas on the sampling media. The mercury traps used for sampling are specially designed for use at wet sources; each tube had an extended section of glass to allow for the heating of the stack gas before it comes into contact with the sampling media.

The sampling methodology is briefly described as follows. Each sorbent trap was removed from the clean sorbent trap storage container, the end caps were removed from the traps and the traps were attached to the end of the sampling probe and leak checked. The probe was inserted into the stack and the sample pumps were started. Stack gas was drawn through the traps and into the sampling probe and the sampled gas stream then passed through a series of empty impingers followed by a silica gel trap to remove any remaining traces of moisture prior to the pump and dry gas meter.

A run consisted of paired mercury traps, identified as either A or B, sampled simultaneously. In each tube pair one of either the A or B tube was spiked with a known quantity of mercury. Due to the variability in the mercury concentration in the stack gas and the necessity to have the spiked tubes prepared at least two weeks in advance of the testing program, six pairs of tubes were used for the sampling program to try to ensure that at least one of the spike concentrations would fall within the concentration range requirements of the test method.

Each test run was sixty minutes in duration at an approximate sampling rate of approximately one liter per minute.

Throughout each test, the following information was measured and recorded for each sampling train:

- Elapsed sampling time
- Dry gas meter volume
- Dry gas meter temperatures
- Control module orifice pressure
- Sampling pump vacuum

At the start and finish of each sampling run the sampling trains were leak-checked. The leakage rate for each train must not exceed 4% of the average sampling rate for the collection period. If a trap pair did not have an acceptable initial leak check, the leak was found and repaired and/or the traps were replaced with a new pair until no leak was discernible. All the leak checks performed for the traps used showed no discernible leak through the test train.

Field testing data sheets for the mercury tests are provided in Appendix 2.

All of the sampling equipment used during the emission testing program was calibrated following the applicable reference method. Equipment calibration data is provided in Appendix 3.

4. ANALYSIS METHODOLOGY

At the end of each successful sampling run, the mercury traps were removed from the test train, capped and placed in their appropriate sample container. Each trap was labeled prior to being shipped to Ohio Lumex for analysis.

The traps were analyzed by thermal decomposition with atomic absorption following the procedures detailed in US EPA Method 7473 (direct thermal desorption with atomic absorption and no gold amalgamation). The method is applicable for total mercury “direct” testing of 40 CFR Part 75 Appendix K and EPA Method 30B sorbent traps.

The analysis is briefly described as follows. The sorbent trap tube end cap is removed; the glass wool plug closest to the appropriate carbon bed is carefully removed and separated from the carbon fraction. The sorbent is transferred into a quartz ladle and then covered with anhydrous sodium carbonate. The ladle is inserted into the heated analyzer thermo catalytic conversion chamber. Mercury is converted from a bound state to the atomic state by thermal decomposition in the furnace and is then detected by atomic absorption. The mercury concentration is measured and recorded using an automated data acquisition system. Both the glass wool plug and the sorbent of each bed are analyzed for the trap and the final mercury mass is the sum of the measurements.

The Ohio Lumex analytical report for total vapour phase mercury is provided in Appendix 4.

5. QUALITY ASSURANCE/QUALITY CONTROL PROGRAM

The analysis of samples for mercury was performed by thermal decomposition with atomic absorption. Specific analytical QC procedures for the mercury analysis are summarized below:

- Calibrations are performed on the day of the analysis.
- Three or more calibration points are used for the calibration curve.
- The field samples analyzed must fall within a calibrated range.
- For each calibration curve, $R^2 \geq 0.99$, and the analyzer response must be within $\pm 10\%$ for each standard used in the calibration.
- Following calibration, a second source standard is analyzed. The measured value of the independently prepared standard must be within $\pm 10\%$ of the expected value.
- A blank analysis is conducted prior to analyzing the samples and must be less than the method detection limit.
- At the end of each set of analysis, a calibration standard is tested which must be within $\pm 10\%$ of the expected value.

Six unspiked mercury traps and six pre-spiked mercury traps were ordered approximately two weeks before the field testing program from Ohio Lumex. The pre-spiked mercury traps were spiked with known quantities of mercury ranging from 150 ng to 2000 ng in order to try to ensure that at least one of the traps met the spiking criterion stated in the test method. The recovery spike should be within 50 to 150 percent of the expected mass collected in the traps during sampling according to the test method. The spiking levels for the field recovery traps was estimated using mercury emission data from previous testing programs conducted between 2014 and 2022. The average mercury collected for Test No. 2, Test No. 3 and Test No. 4 was 442.6 ng.

The field spike recovery provides specific verification of the performance of the combined sampling and analytical approach for the test program. The spike recovery for Test No. 2, Test No. 3 and Test No. 4 was 94.1%, 95.7% and 100.0%, respectively. US EPA Method 30B requires the spike recovery to be between 85% and 115%.

US EPA Method 30B requires the paired sorbent trap agreement to be $\leq 10\%$ relative deviation for mercury concentrations greater than $1 \mu\text{g}/\text{Rm}^3$ or $\leq 20\%$ relative deviation for mercury concentrations less than $1 \mu\text{g}/\text{Rm}^3$. If the paired trap agreement is greater than the above stated limits the run is not valid. All of the traps collected during the test program had concentrations greater than $1 \mu\text{g}/\text{Rm}^3$. The average dry adjusted mercury concentration ranged from a low of $6.13 \mu\text{g}/\text{Rm}^3$ (Tube Pair No. 2) to a high of $6.22 \mu\text{g}/\text{Rm}^3$ (Tube Pair No. 3) for the three tests reported. The paired trap agreement was 1.6% for Test No. 2, 2.0% for Test No. 3, and 0.01% for Test No. 4.

6. RESULTS

Six mercury test runs were collected during two days of sampling on June 27 and June 28, 2023. A run consisted of paired mercury traps, identified as either A or B, sampled simultaneously. The spike tubes from each test pair were spiked with increasing amounts of mercury, ranging from 150 ng to 2000 ng, prior to commencing the test program to try to ensure that at least one of the spike concentrations would fall within the concentration range requirements of the test method. The results for Test No. 2, Test No. 3 and Test No. 4 are reported.

The sampling schedule is summarized in Table 1. This information includes test dates and times for each of the mercury test runs performed. All test times match plant time.

Mercury emission sample analyses for Test No. 2, Test No. 3 and Test No. 4 are provided in Table 2. Mercury was detected in Section 1 of each trap in quantities greater than the method detection limit (0.6 ng) in all of the traps. Mercury was also collected in Section 2 in three of the six traps in quantities greater than the method detection limit. However, the amount detected in Section 2 was less than 0.6% of the mercury collected in Section 1 in all traps, indicating that there was no breakthrough or potential loss of mercury. US EPA Method 30B recommends that $\leq 10\%$ of the total mercury collected should be collected in Section 2 for mercury concentrations greater than $1 \mu\text{g}/\text{Rm}^3$ or $\leq 20\%$ of the total mercury collected should be collected in Section 2 for mercury concentrations less than $1 \mu\text{g}/\text{Rm}^3$.

Included in Table 2 are the mercury concentration calculations for Test No. 2, Test No. 3 and Test No. 4. The average oxygen concentration measured by the Clean Harbors CEM system for each test was used to determine the dry reference concentration adjusted to 11% oxygen.

Six unspiked mercury traps and six pre-spiked mercury traps were ordered approximately two weeks before the field testing program from Ohio Lumex. US EPA Method 30B states that it is acceptable to use the field recovery runs as test runs for emission testing as long as they meet the paired trap agreement criteria. The mass of the mercury spike initially present in each of the spiked traps was subtracted from the total mercury collected in Section 1 of the trap. The difference represents the amount of mercury in the stack gas.

The mercury emission data from the total vapour phase mercury tests is provided below:

| Mercury Parameter | Test 1 | Test 2 | Test 3 | Average |
|--|--------|--------|--------|---------|
| Dry Reference Conc. ($\mu\text{g}/\text{Rm}^3$)* | 7.66 | 7.25 | 7.20 | 7.37 |
| Dry Adjusted Conc. ($\mu\text{g}/\text{Rm}^3$)** | 6.13 | 6.22 | 6.20 | 6.19 |

* reference conditions are 25°C and 1 atmosphere

** at 25°C and 1 atmosphere, adjusted to 11% oxygen

The incinerator exhaust stack mercury concentration limit as stated in Environmental Compliance Approval No. 8-1030-94-006 (formerly Certificate of Approval (Air) No. 8-1030-94-006) is 50 $\mu\text{g}/\text{Rm}^3$ adjusted to 11% oxygen. The mercury concentrations were below this limit during the test program.

The spiked mercury trap recovery calculations are shown in Table 3; the spike recovery for Test No. 2, Test No. 3 and Test No. 4 was 94.1%, 95.7% and 100.0%, respectively. US EPA Method 30B requires the spike recovery to be between 85% and 115%.

7. FACILITY PROCESS DATA

Incinerator process data was supplied by Clean Harbors personnel for the emission test periods. The process data is provided in Appendix 5 as average values for each test for the following process parameters:

- incinerator feed rates (rich, lean, emulsion and alkaline streams)
- volumetric flowrates (secondary air and stack gases)
- temperatures (primary zone, secondary zone, spray dryer inlet and outlet, stack gases)
- pressures (burner, spray dryer outlet, baghouse differential)
- combustion gas stack concentrations (O_2 and SO_2)
- stack gas opacity
- carbon injection rate

During the emission testing program, the average powdered activated carbon (PAC) injection rate was 23.6 lb/hr.

APPENDIX 1

**Data Tables
(2 pages)**

Table 1: Mercury Test Schedule

| Test Number | Test Date | Sampling Period | | Sampling Time |
|-------------|---------------|-----------------|--------|---------------|
| | | Start | Finish | min |
| 1 | June 27, 2023 | 11:45 | 12:45 | 60 |
| 2 | June 27, 2023 | 13:05 | 14:05 | 60 |
| 3 | June 27, 2023 | 14:23 | 15:23 | 60 |
| 4 | June 27, 2023 | 15:44 | 16:44 | 60 |
| 5 | June 28, 2023 | 9:30 | 10:30 | 60 |
| 6 | June 28, 2023 | 10:42 | 11:42 | 60 |

Note: All test times match plant time.

Table 2: Mercury Emission Data

| Test/Run No. | Tube ID | Mercury Collected | | | Dry Gas Volume Sampled Rm ^{3*} | Mercury Concentration | | Paired Trap Agreement % |
|--------------|---------|-------------------|-----------------|-------------|--|--------------------------------------|--------------------------------------|----------------------------|
| | | Section 1 ng | Section 2 ng | Total ng | | Dry Reference µg/Rm ^{3*} | Dry Adjusted µg/Rm ^{3**} | |
| 2 | A | 489.4 | 2.7 | 492.1 | 0.0632 | 7.78 | 6.23 | - |
| | B*** | 458.5 | <0.6 | <459.1 | 0.0609 | 7.54 | 6.04 | - |
| | Average | | | | | 7.66 | 6.13 | 1.6 |
| 3 | A*** | 413.3 | 0.4 | 413.7 | 0.0582 | 7.10 | 6.09 | - |
| | B | 484.2 | 0.4 | 484.6 | 0.0655 | 7.40 | 6.35 | - |
| | Average | | | | | 7.25 | 6.22 | 2.0 |
| 4 | A | 383.1 | 0.9 | 384.0 | 0.0534 | 7.19 | 6.20 | - |
| | B*** | 420.0 | 1.9 | 421.9 | 0.0586 | 7.20 | 6.20 | - |
| | Average | | | | | 7.20 | 6.20 | 0.01 |
| Average | | | | 442.6 | | 7.37 | 6.19 | |

Note: Concentration data is only reported for three tests as required by US EPA Method 30B

* At 25°C and 1 atmosphere

** At 25°C and 1 atmosphere, adjusted to 11% oxygen

*** Spiked tube, mercury collected corrected for the original spike (250 ng for Test No. 2, 400 ng for Test No. 3 and 600 ng for Test No. 4).

Table 3: Mercury Spike Tube Recovery

| Test No. | Total Collected | Spike Tube Volume Sampled | Mercury Concentration | Total Collected | Unspike Tube Volume Sampled | Mercury Concentration | Spike Concentration | Spike Recovery |
|----------|-----------------|---------------------------|-----------------------|-----------------|-----------------------------|-----------------------|---------------------|----------------|
| | ng | Rm ^{3*} | ng/Rm ^{3*} | ng | Rm ^{3*} | ng/Rm ^{3*} | ng/Rm ^{3*} | % |
| 2 | 709 | 0.0609 | 11643 | 492.1 | 0.0632 | 7780 | 3863 | 94.1 |
| 3 | 814 | 0.0582 | 13972 | 484.6 | 0.0655 | 7401 | 6571 | 95.7 |
| 4 | 1022 | 0.0586 | 17431 | 384.0 | 0.0534 | 7195 | 10237 | 100.0 |
| Average | | | | | | | | 96.6 |

Note: The spike tubes were spiked with mercury by the analytical laboratory prior to sampling. The original spike concentrations were 250 ng for Test No. 2, 400 ng for Test No. 3 and 600 ng for Test No. 4.

APPENDIX 2

**Mercury Field Data Sheets
(7 pages)**

**Clean Harbors, Sarnia
Mercury Tube Sampling Train
Sample Volume Corrections**

Incinerator Exhaust Stack

| Test # - Tube (tube pair field ID) | DGMCF | Initial DGM Reading (L) | Final DGM Reading (L) | Actual Vol. Sampled (L) | Barometric Pressure (in Hg) | Average DGM Pressure del H (in H ₂ O) | Average DGM Temperature (°C) | Corrected Volume (L)* | Corrected Volume (Rm ³)* |
|---------------------------------------|----------------|-------------------------------|-----------------------------|-------------------------------|-----------------------------------|--|------------------------------------|-----------------------------|--|
| T1A OL618282 (Spiked) T1B OL629572 | 1.012 0.993 | 24.6 17.6 | 90.1 83.7 | 65.5 66.1 | 29.07 29.07 | 2.0 1.0 | 28.3 29.8 | 64.02 62.93 | 0.0640 0.0629 |
| T2A OL629554 T2B OL661382 (Spiked) | 1.012 0.993 | 94.1 89.2 | 159.1 154.2 | 65.0 65.0 | 29.09 29.09 | 2.0 1.0 | 29.9 34.9 | 63.25 60.90 | 0.0632 0.0609 |
| T3A OL569050 (Spiked) T3B OL529553 | 1.012 0.993 | 62.0 57.2 | 122.0 126.7 | 60.0 69.5 | 29.12 29.12 | 2.0 1.0 | 30.9 33.5 | 58.24 65.48 | 0.0582 0.0655 |
| T4A OL663194 T4B OL610647 (Spiked) | 1.012 0.993 | 24.0 29.0 | 78.7 91.4 | 54.7 62.4 | 29.14 29.14 | 2.0 1.0 | 29.5 34.5 | 53.37 58.62 | 0.0534 0.0586 |
| T5A OL620087 (Spiked) T5B OL661398 | 1.012 0.993 | 83.3 94.7 | 140.7 157.0 | 57.4 62.3 | 29.38 29.38 | 2.0 1.0 | 30.2 29.2 | 56.35 60.05 | 0.0564 0.0600 |
| T6A OL663104 T6B OL618297 (Spiked) | 1.012 0.993 | 43.7 58.6 | 98.4 119.1 | 54.7 60.5 | 29.39 29.39 | 2.0 1.0 | 32.1 35.5 | 53.38 57.14 | 0.0534 0.0571 |

* dry at 25°C and 1 atmosphere

ORTECH
Mercury Tube Data Sheet

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 1 |

| | |
|----------------|--------------|
| Test location: | Stack |
| Date: | June 27 2020 |
| Project No.: | 22278 |

Train A

| | | | |
|----------------------|----------|--------|---|
| Tube Identification: | OL618282 | Spiked | <input checked="" type="radio"/> Yes <input type="radio"/> No |
| Spike Concentration | 150 | ng | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | V0572 |
| Barometer | ENV. CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.07 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 24.6 | 22 | 2 | 5.5 |
| 5 | 30.5 | 24 | 2 | 5.5 |
| 10 | 36.0 | 25 | 2 | 5.5 |
| 15 | 41.8 | 26 | 2 | 5.5 |
| 20 | 46.6 | 28 | 2 | 5.5 |
| 25 | 51.6 | 29 | 2 | 5.5 |
| 30 | 57.0 | 29 | 2 | 5.5 |
| 35 | 62.1 | 30 | 2 | 5.5 |
| 40 | 68.1 | 31 | 2 | 5.5 |
| 45 | 73.1 | 31 | 2 | 5.5 |
| 50 | 79.0 | 31 | 2 | 5.5 |
| 55 | 84.4 | 31 | 2 | 5.5 |
| 60 | 90.1 | 31 | 2 | 5.5 |

| | | | | | |
|--------------|------|--------------------|-----------------|-------------------|-------|
| Start Time: | 1145 | Initial Leak Check | 2.0 LPM@ 15 "Hg | DGMCF: | 1.012 |
| Finish Time: | 1245 | Final Leak Check | 2.0 LPM@ 15 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 2 |

Train B

| | | | |
|----------------------|----------|--------|---|
| Tube Identification: | OL629572 | Spiked | Yes <input type="radio"/> No <input checked="" type="radio"/> |
| Spike Concentration | | ng | |

| | |
|------------------|-------|
| Measuring Device | MII |
| Control Module | V0574 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 17.6 | 23 | | 5.5 |
| 5 | 23.0 | 25 | | 5.5 |
| 10 | 28.5 | 26 | | 5.5 |
| 15 | 34.1 | 27 | | 5.5 |
| 20 | 39.2 | 27 | | 5.5 |
| 25 | 45.1 | 29 | | 5.5 |
| 30 | 50.0 | 30 | | 5.5 |
| 35 | 55.5 | 31 | | 5.5 |
| 40 | 61.0 | 33 | | 5.5 |
| 45 | 66.5 | 34 | | 5.5 |
| 50 | 72.0 | 34 | | 5.5 |
| 55 | 78.0 | 34 | | 5.5 |
| 60 | 84.0 | 34 | | 5.5 |

| | | | | | |
|--------------|------|--------------------|-----------------|-------------------|------|
| Start Time: | 1145 | Initial Leak Check | 2.0 LPM@ 16 "Hg | DGMCF: | .993 |
| Finish Time: | 1245 | Final Leak Check | 2.0 LPM@ 15 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 1 |

| | |
|-----------|----|
| Operator: | DM |
|-----------|----|

ORTECH Mercury Tube Data Sheet

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 2 |

| | |
|----------------|------------|
| Test location: | Stack |
| Date: | June 21/25 |
| Project No.: | 22278 |

Train A

| | | | | |
|----------------------|----------|--------|-----|----|
| Tube Identification: | OL629554 | Spiked | Yes | No |
| Spike Concentration | | ng | | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | VOST 2 |
| Barometer | ENV. CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.09 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 94.1 | 28 | 2 | 0 |
| 5 | 100.5 | 30 | 2 | 0 |
| 10 | 105.2 | 30 | 2 | 0 |
| 15 | 111.1 | 30 | 2 | 0 |
| 20 | 116.1 | 30 | 2 | 0 |
| 25 | 121.5 | 30 | 2 | 0 |
| 30 | 126.5 | 30 | 2 | 0 |
| 35 | 132.0 | 30 | 2 | 0 |
| 40 | 137.6 | 30 | 2 | 0 |
| 45 | 142.9 | 30 | 2 | 0 |
| 50 | 148.2 | 30 | 2 | 0 |
| 55 | 153.7 | 30 | 2 | 0 |
| 60 | 159.1 | 30 | 2 | 0 |

| | | | | | |
|--------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1305 | Initial Leak Check | <0.1 LPM@ 15 "Hg | DGMCF: | 1.012 |
| Finish Time: | 1405 | Final Leak Check | <0.1 LPM@ 15 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 2 |

Train B

| | | | | |
|----------------------|----------|--------|-----|----|
| Tube Identification: | OL661382 | Spiked | Yes | No |
| Spike Concentration | 250 | ng | | |

| | |
|------------------|--------|
| Measuring Device | MII |
| Control Module | VOST 4 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 89.2 | 32 | 1 | 0 |
| 5 | 95.3 | 35 | 1 | 0 |
| 10 | 100.0 | 35 | 1 | 0 |
| 15 | 109.9 | 35 | 1 | 0 |
| 20 | 109.9 | 35 | 1 | 0 |
| 25 | 114.9 | 36 | 1 | 0 |
| 30 | 121.1 | 36 | 1 | 0 |
| 35 | 127.0 | 36 | 1 | 0 |
| 40 | 132.5 | 35 | 1 | 0 |
| 45 | 137.9 | 35 | 1 | 0 |
| 50 | 143.0 | 35 | 1 | 0 |
| 55 | 148.7 | 34 | 1 | 0 |
| 60 | 154.2 | 34 | 1 | 0 |

| | | | | | |
|--------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1305 | Initial Leak Check | <0.1 LPM@ 16 "Hg | DGMCF: | 1.993 |
| Finish Time: | 1405 | Final Leak Check | 2.4 LPM@ 17 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 1 |

| | |
|-----------|----|
| Operator: | DM |
|-----------|----|

ORTECH
Mercury Tube Data Sheet

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 3 |

| | |
|----------------|------------|
| Test location: | Stack |
| Date: | June 27/23 |
| Project No.: | 22278 |

Train A

| | | | |
|----------------------|----------|--------|---|
| Tube Identification: | 02569050 | Spiked | <input checked="" type="radio"/> Yes <input type="radio"/> No |
| Spike Concentration | 400 | ng | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | VOST 2 |
| Barometer | ENV. CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.13 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 62.0 | 28 | 2 | 88 |
| 5 | 67.5 | 30 | 2 | |
| 10 | 73.0 | 31 | 2 | |
| 15 | 78.0 | 32 | 2 | |
| 20 | 83.0 | 32 | 2 | |
| 25 | 87.1 | 32 | 2 | |
| 30 | 92.2 | 31 | 2 | |
| 35 | 97.3 | 31 | 2 | |
| 40 | 102.3 | 31 | 2 | |
| 45 | 107.3 | 31 | 2 | |
| 50 | 112.2 | 31 | 2 | |
| 55 | 117.1 | 31 | 2 | |
| 60 | 122.0 | 31 | 2 | |

| | | | | | |
|--------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1423 | Initial Leak Check | <0.1 LPM@ 17 "Hg | DGMCF: | 1.012 |
| Finish Time: | 1523 | Final Leak Check | <0.1 LPM@ 16 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 2 |

Train B

| | | | |
|----------------------|----------|--------|---|
| Tube Identification: | 02629553 | Spiked | Yes <input type="radio"/> No <input checked="" type="radio"/> |
| Spike Concentration | | ng | |

| | |
|------------------|--------|
| Measuring Device | MII |
| Control Module | VOST 4 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 57.2 | 31 | 1 | 88 |
| 5 | 63.5 | 33 | 1 | |
| 10 | 69.0 | 34 | 1 | |
| 15 | 74.0 | 34 | 1 | |
| 20 | 79.9 | 34 | 1 | |
| 25 | 86.0 | 34 | 1 | |
| 30 | 91.0 | 34 | 1 | |
| 35 | 96.9 | 34 | 1 | |
| 40 | 102.9 | 34 | 1 | |
| 45 | 109.5 | 34 | 1 | |
| 50 | 115.2 | 33 | 1 | |
| 55 | 121.1 | 33 | 1 | |
| 60 | 126.7 | | | |

| | | | | | |
|--------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1423 | Initial Leak Check | <0.1 LPM@ 15 "Hg | DGMCF: | 0.993 |
| Finish Time: | 1523 | Final Leak Check | <0.1 LPM@ 16 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 1 |

| | |
|-----------|----|
| Operator: | DM |
|-----------|----|

ORTECH
Mercury Tube Data Sheet

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 4 |

| | |
|----------------|-----------|
| Test location: | Stack |
| Date: | Jun 27/23 |
| Project No.: | 22278 |

Train A

| | | | |
|----------------------|----------|--------|----------|
| Tube Identification: | 02663194 | Spiked | Yes (No) |
| Spike Concentration | | ng | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | VOST 2 |
| Barometer | ENV. CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.14 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 24.0 | 26 | 2 | 5 |
| 5 | 29.3 | 28 | 2 | 5 |
| 10 | 33.3 | 29 | 2 | 5 |
| 15 | 37.3 | 30 | 2 | 5 |
| 20 | 41.3 | 30 | 2 | 5 |
| 25 | 45.0 | 30 | 2 | 5 |
| 30 | 50.0 | 30 | 2 | 5 |
| 35 | 54.4 | 30 | 2 | 5 |
| 40 | 58.0 | 31 | 2 | 5 |
| 45 | 63.0 | 30 | 2 | 5 |
| 50 | 68.0 | 30 | 2 | 5 |
| 55 | 73.1 | 30 | 2 | 5 |
| 60 | 78.7 | 30 | 2 | 5 |

| | | | | | | |
|--------------|------|--------------------|------|-----|-------------------|-------|
| Start Time: | 1544 | Initial Leak Check | LPM@ | "Hg | DGMCF: | 1.012 |
| Finish Time: | 1644 | Final Leak Check | LPM@ | "Hg | Sample Volume: | |
| | | | | | Average DGM Temp: | |
| | | | | | Average DGM Δ H: | 2 |

Train B

| | | | |
|----------------------|----------|--------|----------|
| Tube Identification: | 02610647 | Spiked | Yes (No) |
| Spike Concentration | 600 | ng | |

| | |
|------------------|--------|
| Measuring Device | MII |
| Control Module | VOST 4 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 29.0 | 31 | 1 | 5 |
| 5 | 35.2 | 32 | 1 | 5 |
| 10 | 40.1 | 33 | 1 | 5 |
| 15 | 45.0 | 34 | 1 | 5 |
| 20 | 50.1 | 35 | 1 | 5 |
| 25 | 55.0 | 36 | 1 | 5 |
| 30 | 60.1 | 37 | 1 | 5 |
| 35 | 65.2 | 37 | 1 | 5 |
| 40 | 70.0 | 37 | 1 | 5 |
| 45 | 75.7 | 37 | 1 | 5 |
| 50 | 80.0 | 37 | 1 | 5 |
| 55 | 85.4 | 37 | 1 | 5 |
| 60 | 91.4 | 37 | 1 | 5 |

| | | | | | | |
|--------------|------|--------------------|------|-----|-------------------|------|
| Start Time: | 1644 | Initial Leak Check | LPM@ | "Hg | DGMCF: | .993 |
| Finish Time: | 1644 | Final Leak Check | LPM@ | "Hg | Sample Volume: | |
| | | | | | Average DGM Temp: | |
| | | | | | Average DGM Δ H: | 1 |

| | |
|-----------|----|
| Operator: | DR |
|-----------|----|

ORTECH
Mercury Tube Data Sheet

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 5 |

| | |
|----------------|---------------|
| Test location: | Stack |
| Date: | JUNE 28, 2023 |
| Project No.: | 22278 |

Train A

| | | | | |
|----------------------|----------|--------|--------------------------------------|--------------------------|
| Tube Identification: | 0L620087 | Spiked | <input checked="" type="radio"/> Yes | <input type="radio"/> No |
| Spike Concentration | 1000 | ng | | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | VOST 2 |
| Barometer | ENV: CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.38 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 83.3 | 26 | 2 | 5 |
| 5 | 88.0 | 30 | 2 | 6 |
| 10 | 93.0 | 30 | 2 | 6 |
| 15 | 97.5 | 31 | 2 | 6 |
| 20 | 101.8 | 31 | 2 | 6 |
| 25 | 106.3 | 31 | 2 | 6 |
| 30 | 111.3 | 30 | 2 | 6 |
| 35 | 116.3 | 30 | 2 | 6 |
| 40 | 121.2 | 30 | 2 | 6 |
| 45 | 126.0 | 31 | 2 | 6 |
| 50 | 131.0 | 31 | 2 | 10 |
| 55 | 136.0 | 30 | 2 | 10 |
| 60 | 140.7 | 30 | 2 | 10 |

| | | | | | |
|--------------|-------|--------------------|------------------|-------------------|-------|
| Start Time: | 9:30 | Initial Leak Check | 2.01 LPM@ 16 "Hg | DGMCF: | 1.012 |
| Finish Time: | 10:30 | Final Leak Check | 2.01 LPM@ 16 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 2 |

Train B

| | | | | |
|----------------------|----------|--------|---------------------------|-------------------------------------|
| Tube Identification: | 0L661398 | Spiked | <input type="radio"/> Yes | <input checked="" type="radio"/> No |
| Spike Concentration | | ng | | |

| | |
|------------------|--------|
| Measuring Device | MII |
| Control Module | VOST 4 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 94.7 | 21 | 1 | 5 |
| 5 | 100.0 | 25 | 1 | 5 |
| 10 | 105.0 | 27 | 1 | 5 |
| 15 | 110.0 | 28 | 1 | 5 |
| 20 | 115.1 | 28 | 1 | 5 |
| 25 | 120.5 | 29 | 1 | 5 |
| 30 | 125.5 | 31 | 1 | 5 |
| 35 | 130.5 | 31 | 1 | 5 |
| 40 | 136.1 | 31 | 1 | 5 |
| 45 | 141.5 | 32 | 1 | 5 |
| 50 | 146.9 | 32 | 1 | 5 |
| 55 | 152.0 | 32 | 1 | 5 |
| 60 | 157.0 | 32 | 1 | 5 |

| | | | | | |
|--------------|-------|--------------------|------------------|-------------------|-------|
| Start Time: | 9:30 | Initial Leak Check | 2.01 LPM@ 16 "Hg | DGMCF: | 0.993 |
| Finish Time: | 10:30 | Final Leak Check | 2.01 LPM@ 16 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | 1 |

| | |
|-----------|----------|
| Operator: | D. J. U. |
|-----------|----------|

**ORTECH
Mercury Tube Data Sheet**

| | |
|-----------------|---------------|
| Plant: | Clean Harbors |
| Plant Location: | Corunna |
| Test No.: | 6 |

| | |
|----------------|-----------|
| Test location: | Stack |
| Date: | Jun 28/13 |
| Project No.: | 22278 |

Train A

| | | | |
|----------------------|----------|--------|----------|
| Tube Identification: | OL603104 | Spiked | Yes (No) |
| Spike Concentration | | ng | |

| | |
|------------------|-----------|
| Measuring Device | MII |
| Control Module | VOST 2 |
| Barometer | ENV. CAN. |

| | |
|---------------------|-------|
| Barometric Pressure | 29.39 |
|---------------------|-------|

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 43.7 | 27 | 2 | MII |
| 5 | 48.2 | 30 | 2 | |
| 10 | 52.7 | 31 | 2 | |
| 15 | 57.1 | 32 | 2 | |
| 20 | 61.5 | 33 | 2 | |
| 25 | 66.0 | 33 | 2 | |
| 30 | 70.4 | 33 | 2 | |
| 35 | 74.8 | 33 | 2 | |
| 40 | 79.2 | 33 | 2 | |
| 45 | 83.7 | 33 | 2 | |
| 50 | 87.4 | 33 | 2 | |
| 55 | 93.4 | 33 | 2 | |
| 60 | 98.4 | 33 | 2 | |

| | | | | | |
|--------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1042 | Initial Leak Check | 5.01 LPM@ 16 "Hg | DGMCF: | 1.012 |
| Finish Time: | 1142 | Final Leak Check | 5.01 LPM@ 17 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | |

Train B

| | | | |
|----------------------|----------|--------|----------|
| Tube Identification: | OL618297 | Spiked | Yes (No) |
| Spike Concentration | 2000 | ng | |

| | |
|------------------|--------|
| Measuring Device | MII |
| Control Module | VOST 4 |

| Clock Time | Dry Gas Meter L | Average Meter Temperature °C | Meter Pressure Δ H "H ₂ O | Pump Vacuum "Hg Gauge |
|------------|--------------------|---------------------------------|--|-----------------------------|
| 0 | 58.6 | 30 | | 5 |
| 5 | 63.6 | 31 | | |
| 10 | 68.5 | 32 | | |
| 15 | 73.5 | 33 | | |
| 20 | 78.0 | 35 | | |
| 25 | 83.4 | 36 | | |
| 30 | 88.0 | 37 | | |
| 35 | 93.0 | 38 | | |
| 40 | 98.1 | 38 | | |
| 45 | 102.6 | 38 | | |
| 50 | 108.2 | 38 | | |
| 55 | 114.1 | 39 | | |
| 60 | 120.1 | 39 | | |

| | | | | | |
|---------------|------|--------------------|------------------|-------------------|-------|
| Start Time: | 1042 | Initial Leak Check | 5.01 LPM@ 16 "Hg | DGMCF: | 1.993 |
| Finish Time: | 1142 | Final Leak Check | 5.01 LPM@ 17 "Hg | Sample Volume: | |
| | | | | Average DGM Temp: | |
| | | | | Average DGM Δ H: | |
| Operator: JMU | | | | | |

APPENDIX 3



**ORTECH Equipment Calibration Data
(4 pages)**

ORTECH

Dry Gas Meter Calibration Data

| | | |
|-----------------------|--------------------|----------|
| Calibration Procedure | 03-J004 | 03-J004 |
| Meter Number | Vost 2 | A10117 |
| Date | June 29, 2023 | A01463 |
| Barometric Pressure | 29.53 | COE20028 |
| System Leak Check | <0.01 Lpm @ 17 "Hg | |

| MII NUMBERS | |
|-------------|----------|
| DGM | A10117 |
| Gasometer | A01463 |
| Barometer | COE20028 |

| | |
|--------------------------|---|
| Calibrated By | David Ufley |
| Signature |  |
| Reviewed and Accepted By |  |

ft³ = cm³ * 1.332 litres per cm³ / 28.3168 litres per ft³


$$DGMCF = \frac{V_{std} \text{ ft}^3}{V_{dgm} \text{ ft}^3} \times \frac{T_{dgm} \text{ } ^\circ\text{F} + 460}{T_{std} \text{ } ^\circ\text{F} + 460} \times \frac{P_{bar} \text{ (in. Hg)}}{(P_{bar} \text{ in. Hg} + DGM \text{ Pressure}) / 13.6}$$

| Gasometer Reading cm | Gasometer Volume | | Gasometer Temperature °C | DGM Reading L | | DGM Volume ft ³ | DGM Average Temperature °C | DGM Pressure in. H ₂ O | DGM Outlet °C | DGM Calibration Factor | Time min. | Flow Rate lpm |
|-------------------------|------------------|-------|-----------------------------|------------------|--------|-------------------------------|-------------------------------|--------------------------------------|------------------|---------------------------|--------------|---------------------|
| | Initial | Final | | Initial | Final | | | | | | | |
| 50.30 | 34.80 | 15.50 | 24.0 | 14.300 | 34.750 | 0.722 | 27.0 | 2.0 | 27.0 | 1.015 | 20 | 1.0 |
| 49.00 | 33.60 | 15.40 | 24.0 | 34.750 | 55.200 | 0.722 | 29.0 | 2.0 | 29.0 | 1.015 | 20 | 1.0 |
| 49.10 | 33.90 | 15.20 | 23.0 | 55.200 | 75.650 | 0.722 | 29.5 | 2.0 | 29.5 | 1.007 | 20 | 1.0 |

DGMCF AVERAGE
1 Lpm 1.012

Acceptance Criteria:
Individual values of DGM calibration factor must be within ± 1.5% of the average value.
If not the calibration must be repeated. Also, the DGMCF average value must be 1.00 ± 0.05, otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use.
(Environment Canada Reference Method EPS 1/RM/8, Section 6)

ORTECH Trendicator Calibration

| | |
|--------------------------|--|
| Calibration Procedure | 03-J005 |
| Trendicator Type | Nutech |
| MII | A10117 |
| Date | June 29, 2023 |
| Calibrated By | David Utley |
| Signature |  |
| Reviewed and Accepted By | |

| Fluke Calibrator Output (COE 20024) (°C) | Trendicator Display Value | | Percent Difference (%) |
|--|---------------------------|--------------------------|------------------------------|
| | Before Adjustment (°C) | After Adjustment (°C) | |
| 0 | 0 | | 0.0 |
| 20 | 20 | | 0.0 |
| 50 | 50 | | 0.0 |
| 100 | 101 | | -1.0 |
| 150 | 151 | | -0.7 |
| 200 | 201 | | -0.5 |
| 300 | 300 | | 0.0 |
| 400 | 401 | | -0.3 |
| 500 | 500 | | 0.0 |
| 600 | 600 | | 0.0 |

$$\% \text{ Difference} = \frac{(\text{micromite} - \text{after adjustment reading}) \times 100}{\text{micromite}}$$

Acceptance Criteria:


Trendicator display must read within $\pm 1.5\%$ of the micromite value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use. (MOE Source Testing Code, Version #2, Method 5)

ORTECH

Dry Gas Meter Calibration Data

| | | |
|-----------------------|---------------|-----------|
| Calibration Procedure | 03-J004 | 03-J004 |
| Meter Number | Vost 4 | A11542 |
| Date | June 29, 2023 | A01463 |
| Barometric Pressure | 29.53 | COE 20028 |
| System Leak Check | <.01 @ 18 "Hg | |

| MII NUMBERS | |
|-------------|-----------|
| DGM | A11542 |
| Gasometer | A01463 |
| Barometer | COE 20028 |

| | |
|--------------------------|---|
| Calibrated By | David Ujkey |
| Signature |  |
| Reviewed and Accepted By | |

ft³ = cm³ * 1.332 litres per cm³ / 28.3168 litres per ft³


$$DGMCF = \frac{V_{std} \text{ ft}^3}{V_{dgm} \text{ ft}^3} \cdot \frac{T_{dgm} \text{ } ^\circ\text{F} + 460}{T_{std} \text{ } ^\circ\text{F} + 460} \cdot \frac{P_{bar} \text{ (in. Hg)}}{(P_{bar} \text{ in. Hg} + DGM \text{ Pressure} / 13.6)}$$

| Gasometer Reading cm | Gasometer Volume | | Gasometer Temperature °C | DGM Reading | | DGM Volume ft ³ | DGM Average Temperature °C | DGM Pressure in. H ₂ O | DGM Outlet °C | DGM Calibration Factor | Time min. | Flow Rate lpm |
|-------------------------|------------------|-------|-----------------------------|-------------|--------|-------------------------------|-------------------------------|--------------------------------------|------------------|---------------------------|--------------|---------------------|
| | Initial | Final | | Initial | Final | | | | | | | |
| 58.40 | 43.30 | 15.10 | 21.0 | 95.20 | 115.50 | 0.717 | 23.0 | 1.0 | 26.0 | 0.995 | 20 | 1.0 |
| 53.50 | 38.10 | 15.40 | 21.0 | 15.50 | 36.40 | 0.738 | 24.0 | 1.0 | 24.0 | 0.989 | 20 | 1.0 |
| 50.70 | 35.60 | 15.10 | 21.0 | 36.40 | 56.90 | 0.724 | 26.0 | 1.0 | 25.0 | 0.995 | 20 | 1.0 |

DGMCF AVERAGE
1Lpm 0.993

Acceptance Criteria:
Individual values of DGM calibration factor must be within ± 1.5% of the average value. If not the calibration must be repeated. Also, the DGMCF average value must be 1.00 ± 0.05, otherwise the meter must be repaired and/or adjusted as necessary and recalibrated prior to use. (Environment Canada Reference Method EPS 1/RM/8, Section 6)

ORTECH Trendicator Calibration

| | |
|--------------------------|--|
| Calibration Procedure | 03-J005 |
| Trendicator Type | Nutech |
| MII | A11542 |
| Date | June 29, 2023 |
| Calibrated By | David Utley |
| Signature |  |
| Reviewed and Accepted By | |

| Fluke Calibrator Output (COE 20024) (°C) | Trendicator Display Value | | Percent Difference (%) |
|--|---------------------------|--------------------------|------------------------------|
| | Before Adjustment (°C) | After Adjustment (°C) | |
| 0 | 0 | | 0.0 |
| 20 | 20 | | 0.0 |
| 50 | 50 | | 0.0 |
| 100 | 100 | | 0.0 |
| 150 | 150 | | 0.0 |
| 200 | 200 | | 0.0 |
| 300 | 300 | | 0.0 |
| 400 | 400 | | 0.0 |
| 500 | 500 | | 0.0 |
| 600 | 600 | | 0.0 |

$$\% \text{ Difference} = \frac{(\text{micromite} - \text{after adjustment reading}) \times 100}{\text{micromite}}$$

Acceptance Criteria:

Trendicator display must read within $\pm 1.5\%$ of the micromite value at each output. Otherwise, the Trendicator must be repaired and/or adjusted as necessary, and recalibrated prior to use. (MOE Source Testing Code, Version #2, Method 5)

APPENDIX 4

**Mercury Analytical Report
(17 pages)**

Sorbent Trap Analysis Report

Date: 7/10/23

Analyst[s]: Alexis Aldhizer
 Project: 2032667-HG

Turnaround: Standard

Company: ORTECH

Contact: Chris Before
 Phone: 905-822-4120 ext. 324
 Email: cbefore@ortech.ca

Method: EPA 7473

Method Uncertainty: ± 10%
 MDL: 0.6 ng
 LOQ: 5 ng

| Trap ID | Pre-Filter Mass [ng] | AGS Mass [ng] | Section 1 Mass [ng] | Section 2 Mass [ng] | Total Mass [ng] ¹ | Section 3 Mass [ng] | Spike Level [ng] | Breakthrough [%] ² | Spike Recovery [%] ³ | Source | Notes | Affected Section |
|----------|----------------------|---------------|---------------------|---------------------|------------------------------|---------------------|------------------|-------------------------------|---------------------------------|--------|-------|------------------|
| OL618282 | | | 961.8 | 0.4 | 962.2 | | 150 | 0.0% | N/A | | | |
| OL629572 | | | 801.2 | 0.3 | 801.5 | | | 0.0% | | | | |
| OL629554 | | | 489.4 | 2.7 | 492.1 | | | 0.6% | | | | |
| OL661382 | | | 708.5 | 0.0 | 708.5 | 250 | | 0.0% | N/A | | | |
| OL569050 | | | 813.3 | 0.4 | 813.7 | 400 | | 0.0% | N/A | | | |
| OL629553 | | | 484.2 | 0.4 | 484.6 | | | 0.1% | | | | |
| OL663194 | | | 383.1 | 0.9 | 384.0 | | | 0.2% | | | | |
| OL610647 | | | 1020 | 1.9 | 1022 | 600 | | 0.2% | N/A | | | |
| OL620087 | | | 4077 | 1.2 | 4078 | 1000 | | 0.0% | N/A | | | |
| OL661398 | | | 3236 | 0.8 | 3237 | | | 0.0% | | | | |
| OL663104 | | | 1606 | 0.8 | 1607 | | | 0.1% | | | | |
| OL618297 | | | 3596 | 0.9 | 3597 | 2000 | | 0.0% | N/A | | | |

¹ Total Mass = PF+AGS+S1+S2

² Breakthrough = S2 / (PF+AGS+S1)

³ For P512B only Spike Recovery = S3 / Spike Level

⁴ Data invalidation qualifier - refer to notes

ATTENTION: A response factor was used to calculate certain values on this report. Italicized masses appear on the report as rounded to the nearest tenth nanogram.



Analyst : Alexis Aldridge
 File Name : 230710_ALA_ORTECH_2032667-HG
 Analyzer : 1644
 Cell type : Short
 Temperature [°C] : 680
 Flow Rate [L/min] : 1.5
 MDI [ng] : 0.6
 SD : 0.7

| Trap ID | Pf Mass [ng] | ACS Mass [ng] | Section 1 Mass [ng] | Section 2 Mass [ng] | Section 3 Mass [ng] | Section 4 Mass [ng] | Spike Level [ng] | Source | Notes | Affected Section |
|---------|--------------|---------------|---------------------|---------------------|---------------------|---------------------|------------------|--------|-------|------------------|
| 1 | OL618282 | | 961.8 | 0.4 | | | 134 | | | |
| 2 | OL629572 | | 801.2 | 0.3 | | | | | | |
| 3 | OL629554 | | 489.4 | 2.7 | | | | | | |
| 4 | OL661382 | | 708.5 | 0.0 | | | 256 | | | |
| 5 | OL560050 | | 813.3 | 0.4 | | | 407 | | | |
| 6 | OL629553 | | 484.2 | 0.4 | | | | | | |
| 7 | OL663194 | | 383.1 | 0.9 | | | | | | |
| 8 | OL610647 | | 1020 | 1.9 | | | 690 | | | |
| 9 | OL620087 | | 4077 | 1.2 | | | 830 | | | |
| 10 | OL661398 | | 3236 | 0.8 | | | | | | |
| 11 | OL663104 | | 1606 | 0.8 | | | | | | |
| 12 | OL618297 | | 3596 | 0.9 | | | 3090 | | | |
| 13 | | | | | | | | | | |
| 14 | | | | | | | | | | |
| 15 | | | | | | | | | | |
| 16 | | | | | | | | | | |
| 17 | | | | | | | | | | |
| 18 | | | | | | | | | | |
| 19 | | | | | | | | | | |
| 20 | | | | | | | | | | |
| 21 | | | | | | | | | | |
| 22 | | | | | | | | | | |
| 23 | | | | | | | | | | |
| 24 | | | | | | | | | | |

Additional Notes

| Daily Calibration ¹ | | | Continuing Calibration Verifications ² | | | Active Hg Standard Bank ³ | | | |
|--------------------------------|-----------|-----------------|---|-----------|-----------------|--------------------------------------|-----------------------|----------------|-----------|
| Lot Std. ID | Std. [ng] | Calculated [ng] | Lot Std. ID | Std. [ng] | Calculated [ng] | Kit (Used) | Concentration [µg/ml] | Lot Std. ID | Exp. Date |
| U2-MFB729102 A | 5.0 | see cal. report | U2-HG729095 A | 1000.0 | 990.4 | | | U2-MFB729102 B | 5/25/2024 |
| U2-MFB729102 A | 10.0 | see cal. report | U2-HG729095 A | 1000.0 | 997.6 | | 0.1 | U2-MFB729103 B | 4/27/2024 |
| U2-MFB729103 A | 100.0 | see cal. report | U2-HG729095 A | 1000.0 | 1002 | | 1 | U2-HG729026 B | 4/27/2024 |
| U2-HG729095 A | 1000.0 | see cal. report | U2-HG729095 A | 1000.0 | 1026 | | 10 | U2-MFB719966 B | 4/27/2024 |
| U2-MFB719966 A | 5000.0 | see cal. report | | | | | 100 | U2-MFB719966 B | 4/27/2024 |
| U2-MFB719966 A | 10000.0 | see cal. report | | | | | 1000 | U2-HG723184 B | 4/27/2024 |
| | | | | | | | 0.1 | U2-MFB729102 A | 4/27/2024 |
| | | | | | | | 1 | U2-MFB729103 A | 4/27/2024 |
| | | | | | | | 10 | U2-HG729095 A | 4/27/2024 |
| | | | | | | | 100 | U2-MFB719966 A | 4/27/2024 |
| | | | | | | | 1 (Independent) | U2-HG720306 | 4/27/2024 |
| | | | | | | | 10 (Independent) | U2-MFB719967 | 4/27/2024 |
| | | | | | | | 100 (Independent) | U2-MFB681004 | 1/11/2024 |

Independent Calibration Verification²

| Lot Std. ID | Std. [ng] | Calculated [ng] |
|--------------|-----------|-----------------|
| U2-MFB719967 | 1000 | 997.0 |

Response Factor (Method 308 Only)⁴

| Lot Std. ID | Std. [ng] | Area/Mass |
|----------------|-----------|-----------|
| U2-MFB729102 A | 1 | 53.5 |

Pipette Identification
 AG
 RF Pipette ID (if different from cal)

Method Blank measured mass⁵
 0.1

¹ Performed daily prior to analysis of sorbent traps, after the SOP for Instrument Calibration for acceptance criteria
² Performed immediately after calibration curve is verified, must range within 10% of expected value
³ Performed between every 10 samples for method 308 and after every analytical batch
⁴ Response factor value must fall between the 100 and MDL
⁵ Subject to change, for analyst convenience only
⁶ Method blank must be measured at a value less than 100
⁷ Data Investigation number - refer to notes

Other Reagents
 Sodium Carbonate 2202861006
 Inducted Activated Carbon 4041

Immediately report any QA/QC failures or anything suspicious to the QA/QC Manager


Analyst Signature: *Alexis Aldridge*
 By signing this report I confirm that the above data are true to the best of my knowledge.

Date: 07/10/2023



REPORT


Report created 10.07.2023 08:29:47
 Instrument UNKNOWN(0) Serial 1644
 number
 Calibration created 10.07.2023 08:29:44
 Calibration name 230710_ALA_5-10000ng



Results


| N | Mercury mass, ng | S-Blank | Ref.data, ppb | Calculated, ppb | d, % |
|---|------------------|---------|---------------|-----------------|------|
| 1 | 10.00 | 498700 | 10000.0 | 9188.9 | -8.1 |
| 2 | 5.00 | 268300 | 5000.0 | 4943.6 | -1.1 |
| 3 | 1.00 | 54460 | 1000.0 | 1003.3 | 0.3 |
| 4 | 0.10 | 5679 | 100.0 | 104.6 | 4.6 |
| 5 | 0.01 | 545 | 10.0 | 10.0 | 0.4 |
| 6 | 0.01 | 282 | 5.0 | 5.2 | 3.8 |

Calibration S - Sblank = a · m
 Algorithm WLSM
 Correlation coefficient 0.999451
 Residual standard deviation 257.104735
 Coefficient a = 54280.0000
 Blank Sblank = 0.0000



TEST 1A

Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



OL618282

Unspiked Spiked At: 150ng
Sampling Method: Cold Vapor Adsorption Via Impinger Sampling
 Certified Accuracy: ±10%, Traceable to NIST

QA/QC Signature (Trap Assembly) _____

QA/QC Signature (Spiker) _____

- Guffy Pre-filter 140 mm
- Dichro Flow AGS 300 mm
- Katic Pre-filter 185 mm 450 mm

Production Lot: S-4CEA Carbon Lot: 4C

Spike Date: 3/17/2022 Spike Time: 1455 Type of Trap: 308

TO BE FILLED OUT BY SAMPLING TECHNICIAN

| | | | |
|---|-----------------------------------|------|------|
| Plant/Source: _____ | PRE-Run Leak Check (circle one): | PASS | FAIL |
| Boiler ID: _____ | Run START: _____ | Date | Time |
| Sampling Location: _____ <small>(Block, PSD Inlet, etc.)</small> | Run END: _____ | Date | Time |
| Run Number (optional): _____ | POST-Run Leak Check (circle one): | PASS | FAIL |
| Sampling Train (circle one): | A | B | |
| Notes: _____ | | | |

SAMPLING CONDITIONS AND PARAMETERS

| | |
|---|---|
| Ave Duct Temp (E): _____ | Estimated Ave Hg Concentration (µg/dscm): _____ |
| Ave Trap Temp (F): _____ | Circle Event if Occurred During Sampling: |
| Ave Flow Rate (cc/min): _____ | STARTUP SHUTDOWN |
| Total Volume (L) _____ or (dscm): _____ | <small>For CEMENT MILLS Only</small> |
| | No. of RAW MILL OFF Events During Sampling: _____ |

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 2 of Sorbent Trap (ng): _____

Note: Analyser Calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody


Signatures along with Date/Time Required for acquisition, removal, and lab analysis of trap.

| Signature | Date | Time | Security Seal |
|-------------------------------------|---------|-------|--|
| Trap inserted by _____ | | | If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap removed and sealed by _____ | | | |
| Courier/Other (if Applicable) _____ | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Courier/Other (if Applicable) _____ | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap removed by _____ | 7-3-23 | 1220 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| _____ | 7/10/23 | 12:23 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

Contamination of the trap media, moisture condensation in a major cause of breakthrough and false low or no-detect traps. Use of a desiccant trap is recommended for long-term storage. Refer to SOP.

OHIO LUMEX TEST 13

Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



OL629572

SPIKED **SPIKED AT:** _____ **QA/QC Signature (Trap Assembly):** Will C

Don Lot: U-1210 Spike Date: _____
 UCC: 40 Spike Time: _____

High Flow Fast Pre-filer 165 mm 240 mm
 Static Pre-filer AGS 300 mm 450 mm

Signature (Pack): _____ Type of Trap: 30B

TRAPPING INFORMATION

City / Source: _____ PRE-Run Leak Check: PASS FAIL
 Trap ID: _____ Run Start Date/Time: 7/3/23
 Trapping Location: _____ Run End Date/Time: 7/3/23
 Number (Optional): _____

Trap Type: A B POST-Run Leak Check: PASS FAIL

TRAPPING CONDITIONS AND PARAMETERS

Duct Temp (F°): _____ Estimated Avg. Hg Concentration (µg/dscm): _____
 Trap Temp (F°): _____ Events Occurred During Sampling: Startup Shutdown
 Flow Rate (cc/min): _____ **CEMENT ONLY**
 Volume (L) _____ or (dscm) _____ # of RAW MILL OFF events during sampling: _____


REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____
Note: Analyser calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

| Signature | Date | Time | Security Seal |
|-----------|----------------|--------------|--|
| _____ | _____ | _____ | If applicable place chain of custody seal here (see security seal instruction sheet) |
| _____ | _____ | _____ | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| _____ | <u>7-3-23</u> | <u>1220</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| _____ | <u>7/10/23</u> | <u>12:28</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |


Seal must be intact and unbroken at the time of analysis. Any break or damage to the seal is a major cause of measurement failure in sorbent traps and should be prevented.



OHIO LUMEX

Test 2 A

Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form



OL629554

UNSPIKED SPIKED AT: _____

Production Lot: G-1210 Spike Date: _____

Carbon Lot: AC Spike Time: _____

QA/QC Signature: _____

QA/QC Signature of the Analyst: *[Signature]*

High Filter FLDry Pre-Filter 185 mm 240 mm

Sulfic Pre-Filter AGS 300 mm 450 mm

Type of Trap: **30B**

SAMPLING INFORMATION

Facility / Source: _____

Boiler ID: _____

Sampling Location: _____

Run Number (Optional): _____

Sampling Train: A B

PRE-Run Leak Check: PASS FAIL

Run Start Date/Time: _____ / _____

Run End Date/Time: _____ / _____

POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°): _____

Avg. Trap Temp (F°): _____

Avg. Flow Rate (cfm/min): _____

Total Volume (L) _____ or (gpm) _____

Estimated Avg. Hg Concentration (µg/dscm): _____

Event Occurred During Sampling: Startup Shutdown

CEMENT ONLY

of RAW MILL OFF events during sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (µg): _____

When a sample is returned to Ohio Lumex, the sample must be sealed in a way that allows for re-analysis. Please contact us if you require assistance returning the sample.

CHAIN OF CUSTODY


| Signature | Date | Time | Security Seal |
|---|---------|-------|--|
| Sampled Material by: | | | If applicable place chain of custody into here (see security seal instruction sheet) |
| Sampled prepared for shipment by: | | | |
| Container (if applicable): | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sampled received by IAC: <i>[Signature]</i> | 7-3-23 | 12:20 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sampled analyzed by: <i>[Signature]</i> | 7/10/23 | 12:33 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

© 2013 Ohio Lumex Co., Inc. All rights reserved. This form is the property of Ohio Lumex Co., Inc. and is not to be reproduced or distributed without the written consent of Ohio Lumex Co., Inc. The information on this form is for internal use only and is not to be used for regulatory reporting purposes. Accuracy is not guaranteed.

TEST 2 B

OHIO LUMEX Co., Inc.
Hg Sorbent Trap Chain of Custody Form

Trap ID



01661382

WJA

UNSPIKED **SPIKED AT:** 250mg QAPC Signature: *[Signature]*

Production Lot: 2537A Spike Date: 1/25/2023

IPDN Lot: 4C Spike Time: 1520

QAPC Signature: *[Signature]* Type of Trap: 308

High Flow Fully Pre-Tare 185 mm 240 mm

Static Pre-Tare 405 300 mm 450 mm

SAMPLING INFORMATION

Facility / Source: PRE-Run Leak Check: PASS FAIL

Boiler ID: Run Start Date/Time: / /

Sampling Location: Run End Date/Time: / /

Run Number (Optional):

Sampling Train: A B POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F): Estimated Avg. Hg Concentration (ug/dscm):

Avg. Trap Temp (F): Event Occurred During Sampling: Startup Shutdown

Avg. Flow Rate (cc/min): **CEMENT ONLY**

Total Volume (L) or (dscm) # of RAW MILL OFF events during sampling

REQUIRED IF RETURNING TO OHIO LUMEX


Estimated Hg Mass in Section 1 of Sorbent Trap (mg):

When another sorbent trap will be returned to the user, labeling the trap may result in a false reading. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY


| | Signature | Date | Time | Security Seal |
|-------------------------------|--------------------|---------|-------|---|
| Trap(s) taken by: | | | | If applicable place chain of custody seal here. (See security seal instruction sheet) |
| Trap(s) prepared/returned by: | | | | |
| Trap(s) received by: | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap(s) received by lab: | <i>[Signature]</i> | 7-3-23 | 1220 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap(s) received by: | <i>[Signature]</i> | 7/10/23 | 12:37 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

Best Before: January 2024



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form

Trap ID



OL569050

T3A

Unspiked Spiked At: 400ng

Spike Method Cold Vapor Adsorption via impinger Sampling
Certified Accuracy ± 10% Traceable to NIST

QA/QC Signature (Trap Assembly) _____

QA/QC Signature (Spike) _____

High Flow 150 mm
 Stack Pre-Filter 150 mm
 Stack Pre-Filter 185 mm

Production Lot: S-4851 Carbon Lot: 4C

Spike Date: 3/19/2022 Spike Time: 1312 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____ Date _____ Time _____

Sampling Location: _____

Run Number (optional): _____ (Mark POST-Run, etc.) Run END: _____ Date _____ Time _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

STARTUP SHUTDOWN

Ave Flow Rate (cc/min): _____

Total Volume (L) _____ or (dscm) _____ For CEMENT MILLS Only

No. of RAW MILL OFF-Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____

Note: Analyze calibration range and be sure based on this value. Sampling that does not result in out-of-calibration analysis. Please contact us if you require assistance interpreting this value.

Chain of Custody

Signatures along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap.

| | Signature | Date | Time | Security Seal |
|-------------------------------|--------------------|----------------|--------------|--|
| Trap inserted by | | | | If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap removed and sealed by | | | | |
| Courier/Other (If Applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Courier/Other (If Applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by | <i>[Signature]</i> | <u>7-3-23</u> | <u>1220</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap analyzed by | <i>[Signature]</i> | <u>7/10/23</u> | <u>12:45</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

In case of poor sampling conditions, provide moisture condensation in the trap mouth. Moisture condensation is a major cause of breakthrough and spike loss in sorbent traps. Request for replacement of all traps. One-time use and does not regenerate. Activated Carbon - Tel: 10305

Best Before: January 2025


OHIO LUMEX CO., INC.

10310 Bruce Industrial Pkwy

Channahon, IL 61018-1724


30310 Bruce Industrial Pkwy

Channahon, IL 61018-1724



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form

T3 B



OL629553

UNSPIKED SPIKED AT: _____

QA/QC Signature (other name): Wells C

Production Lot: D-1210 Spike Date: _____

Carbon Lot: 40 Spike Time: _____

QA/QC Signature: _____

High Flow FV75 Trap filter 185 mm 240 mm
 Static Pre-filter ACS 300 mm 450 mm

Type of Trap: 30B

SAMPLING INFORMATION

Facility / Source: _____

Boiler ID: _____

Sampling Location: _____

Run Number (Optional): _____

Sampling Train: A B

PRE-Run Leak Check: PASS FAIL
 Run Start Date/Time: _____ / _____
 Run End Date/Time: _____ / _____
 POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°): _____

Avg. Trap Temp (F°): _____

Avg. Flow Rate (cc/min): _____

Total Volume (L): _____ of (dscm)

Estimated Avg. Hg Concentration (µg/dscm): _____

Event Occurred During Sampling: Startup Shutdown

CEMENT ONLY

of RAW MILL OFF events during sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 3 of Sorbent Trapping: _____


Note: This use requires proper labeling and handling of the trap, ensuring the trap is sealed and stored properly. Please contact us if you require assistance returning this value.

CHAIN OF CUSTODY

| Signature | Date | Time | Security Seal |
|-------------------------------------|----------------|----------------|---|
| Sampler(s) taken by | | | If applicable place chain of custody seal here (see security seal instruction sheet) |
| Sampler(s) prepared for shipment by | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sampler(s) received by | <u>Wells C</u> | <u>7-3-23</u> | <u>12:20</u> Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sampler(s) analyzed by | <u>Wells C</u> | <u>7/10/23</u> | <u>12:59</u> Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |


Labels and/or markings on the trap must be legible and include the trap ID, flow rate, and volume. A photo of the trap must be taken and stored in the trap's folder. The trap must be sealed and stored in the trap's folder. The trap must be sealed and stored in the trap's folder.

Valid Through: April 2024



Ohio Lumer Co., Inc.
Hg Sorbent Trap Chain of Custody Form

T4A



OL663194

ISPIKED **SPIKED AT:** **DA/DC Signature:** *[Signature]*

Location: U-1139 Spike Date: _____
 In Lot: AC Spike Time: _____
 DC Signature: _____ Type of Trap: **308**

SAMPLING INFORMATION

City / Source: _____ PRE-Run Leak Check: PASS FAIL
 M ID: _____ Run Start Date/Time: _____
 Sampling Location: _____ Run End Date/Time: _____
 Filter Number (Optional): _____
 Sampling Train: A B POST-Run Leak Check: PASS FAIL

SAMPLING CONDITIONS AND PARAMETERS

Duct Temp (F): _____ Estimated Avg. Hg Concentration (ug/dscm): _____
 Trap Temp (F): _____ Event Occurred During Sampling: Startup Shutdown
 Flow Rate (cc/min): _____ **CEMENT ONLY:** _____
 Hg Volume (L) _____ of (dscm) _____ # of RAW MILL OFF events during sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (ug)
Note: Analyser calibration range will be set based on flow rate & pump flow rate (see manual for calibration details). Please contact us if you require assistance determining flow rate.

CHAIN OF CUSTODY

| Signature | Date | Time | Security Seal |
|--------------------|---------|-------|--|
| | | | If applicable place chain of custody seal here (see security seal instruction sheet) |
| | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| <i>[Signature]</i> | 7-3-23 | 12:20 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| <i>[Signature]</i> | 7/10/23 | 13:10 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

OHIO LUMEX



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form



Trap ID
01610647

Unspiked Spiked At: 600ng

Spike Method: Cold Vapor Adsorption via Impinger Sampling
Certified Accuracy: ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly)

QA/QC Signature (Spikes)

- High Flow
- Lowly Pre-Filter
- 11743 mm
- Add
- 11300 mm
- 1185 mm
- 12450 mm

Production Lot: S-4DF9 Carbon Lot: 4C

Spike Date: 05/02/2022 Spike Time: 1218 Type of Trap: 308

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one) **PASS** **FAIL**

Boiler ID: _____ Run START: _____

Sampling Location: _____

Run Number (optional): _____ Run END: _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave DUCT Temp (F): _____ Estimated Ave Hg Concentration (ug/dscm): _____

Ave Trap Temp (F): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) or (dscm): _____ **EXCUSEMENT ONLY**

No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____

Note: Analyser calibration range will be set based on this value. Leaving this blank may result in loss of calibration analysis. Please contact us if you require assistance interpreting this value.


Chain Of Custody

| Signature along with Date/Time required for insertion, removal, lab receiving and lab analysis of trap. | | | | |
|---|--------------------|---------|-------|--|
| | Signature | Date | Time | Security Seal |
| Trap inserted by | | | | If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap removed and sealed by | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| (If Applicable) Courier/Other | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| (If Applicable) Trap received by | <i>[Signature]</i> | 7-3-23 | 1220 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap analyzed by | <i>[Signature]</i> | 7/10/23 | 13:25 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

Best Before: May 2028

OHIO LUMEX

Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form

Trap ID

01620087

Unspiked Spiked At: 1.000mg
Sampling Method: Cold Vapor Adsorption via Impinger Assembly
Certified Accuracy: ± 5%, Traceability: NIST

Production Lot: 5-4DF8 Carbon Lot: 4C

Spike Date: 05/02/2022 Spike Time: 1122 Type of Trap: 30B

QA/QC Signature (Trap Assembly): _____
 QA/QC Signature (Date): 7/10/23

High Flow Fully Pre-Filter 1240 mm
 Static Pre-Filter PASS 1300 mm
 1485 mm 21450 mm

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____ Date _____ Time _____

Sampling Location: _____

Run Number (optional): _____ (DRUCK, FGD, etc.) Run END: _____ Date _____ Time _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Inlet Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Inlet Trap Temp (F°): _____ Circle Event if Occurred During Sampling: _____

Inlet Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CEMENT MILLS Only**

No. of RAW MILL OFF Events During Sampling: _____



REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section I of Sorbent Trap (ng): _____


(i.e. Analyzer Calibration Range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you need assistance estimating this value.)

Chain Of Custody

Recorded along with Date/Time required for insertion, removal, sub-sampling and lab analysis of traps.

| | Signature | Date | Time | Security Seal |
|--|---|----------------|--------------|--|
| Trap inserted by | | | | If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap removed and sealed by | | | | |
| Trap inserted by (if applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap removed and sealed by (if applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by |  | <u>7-3-23</u> | <u>1220</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by |  | <u>7/10/23</u> | <u>13:32</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |


Best Before: 18M



TSB

Ohio Lumex Co., Inc.

Sorbent Trap Chain of Custody Form



OL661398

Unspiked Spiked At _____

Sealing Method: Cold Vapor Adsorption Via Impinger Sealing
Certified Accuracy ± 10%, Traceable to NIST

QA/QC Signature (Trap Assembly) _____

QA/QC Signature (Seal) _____

Production Lot: U-10F4 Carbon Lot: 4C

High Flow 100% Pre-Filtration 240 mm
 Static Pre-Filtration 300 mm 300 mm
 185 mm 450 mm

Spike Date: _____ Spike Time: _____ Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____ Date _____ Time _____

Sampling Location: _____

Run Number (optional): _____ Run END: _____ Date _____ Time _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm) _____ **EMERGENCY USE ONLY**
No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS


Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____

Note: Analyzer calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please contact us if you require assistance estimating this value.

Chain Of Custody


Continued along with Data Files required for insertion, removal, lab recoding and lab analysis of trap.

| | Signature | Date | Time | Security Seal |
|----------------------------|--------------------|---------|-------|--|
| Trap inserted by | | | | If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap removed and sealed by | | | | |
| Trap/Other (if applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap/Other (if applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by | <i>[Signature]</i> | 7-3-23 | 1220 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by | <i>[Signature]</i> | 7/10/23 | 13:38 | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |



Ohio Lumex Co., Inc.
Hg Sorbent Trap Chain of Custody Form

T6A



Trap ID
OL663104

UNSPIKED

Production Lot: *Q7129*

Carbon Lot: *40*

QA/QC Signature: _____

SPIKED AT:

Spike Date: _____

Spike Time: _____

QA/QC Signature (Trap Assembly): *Walt C*

High Flow: **High Flow** **Low Flow**

Pre-filter: **Pre-filter** **None**

Trap Size: **3185 mm** **2400 mm**
 300 mm **25433 mm**

Type of Trap: **308**

SAMPLING INFORMATION

Facility / Source: _____

Boiler ID: _____

Sampling Location: _____

Run Number (Optional): _____

Sampling Train: **A** **B**

PRE-Run Leak Check: **PASS** **FAIL**

Run Start Date/Time: _____ / _____

Run End Date/Time: _____ / _____

POST-Run Leak Check: **PASS** **FAIL**

SAMPLING CONDITIONS AND PARAMETERS

Avg. Duct Temp (F°): _____

Avg. Trip Temp (F°): _____

Avg. Flow Rate (cc/min): _____

Total Volume (L) _____ or (dscm) _____

Estimated Avg. Hg Concentration (ug/dscm): _____

Event Occurred During Sampling: **Startup** **Shutdown**

CEMENT ONLY

of RAWM&L OFF events during sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX

Estimated Hg Mass in Section 1 of Sorbent Trap (mg): _____


Must include section range and other details in the notes. Leaving the blank may result in a non-compliance finding. Please contact us if you require assistance estimating this value.

CHAIN OF CUSTODY

| Sample(s) taken by | Signature | Date | Time | Security Seal |
|------------------------------------|--------------------|----------------|--------------|---|
| Sample(s) prepared for shipment by | | | | If applicable please chain of custody seal here (see security seal instruction sheet) |
| Counter/Diner (if applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sample(s) received by lab | <i>[Signature]</i> | <i>7-3-23</i> | <i>12:20</i> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Sample(s) analyzed by | <i>[Signature]</i> | <i>7/10/23</i> | <i>13:41</i> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |


OHIO LUMEX is not responsible for any measurement errors or data quality issues. It is the user's responsibility to ensure that the cause of measurement failure is not due to a problem with the trap and should be prevented. For more information, please contact us at 1-800-368-6666 or visit our website at www.ohiolumex.com.

Best Before: July 2025



Ohio Lumex Co., Inc.
Sorbent Trap Chain of Custody Form

T6B



OL618297

Unspiked Spiked At: 2,000ng

QA/QC SIGNATURE (Trap Assembly) _____

QA/QC SIGNATURE (Spike) _____

Production Lot: S-4858 Carbon Lot: 4C

High Flow 100% Pre-Filter 200 mm
 Static Pre-Filter DAGS 300 mm
 185 mm 450 mm

Spike Date: 1/20/2022 Spike Time: 1042 Type of Trap: 30B

TO BE FILLED OUT BY SAMPLING TECHNICIAN

Plant/Source: _____ PRE-Run Leak Check (circle one): **PASS** **FAIL**

Boiler ID: _____ Run START: _____ DATE _____ TIME _____

Sampling Location: _____

Run Number (optional): _____ Run END: _____ DATE _____ TIME _____

Sampling Train (circle one): **A** **B** POST-Run Leak Check (circle one): **PASS** **FAIL**

Notes: _____

SAMPLING CONDITIONS AND PARAMETERS

Ave Duct Temp (F°): _____ Estimated Ave Hg Concentration (µg/dscm): _____

Ave Trap Temp (F°): _____ Circle Event if Occurred During Sampling:

Ave Flow Rate (cc/min): _____ **STARTUP** **SHUTDOWN**

Total Volume (L) _____ or (dscm): _____ **For CENSUS-KIDS ONLY**

No. of RAW MILL OFF Events During Sampling: _____

REQUIRED IF RETURNING TO OHIO LUMEX FOR ANALYSIS

Estimated Hg Mass in Section 1 of Sorbent Trap (ng): _____

Note: Analyser calibration range will be set based on this value. Leaving this blank may result in out-of-calibration analysis. Please correct us if you require assistance interpreting this value.

| Chain Of Custody | | | | |
|---|--------------------|----------------|--------------|--|
| <small>Signatures along with Date/Time required for insertion, removal, lab receipt and lab analysis of trap.</small> | | | | |
| | Signature | Date | Time | Security Seal If Applicable Place Chain of Custody seal here (See Security Seal Instruction Sheet) |
| Trap inserted by | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap removed and sealed by | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Courier/Other (If Applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Courier/Other (If Applicable) | | | | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap received by lab | <i>[Signature]</i> | <u>7-3-23</u> | <u>1220</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |
| Trap analyzed by | <i>[Signature]</i> | <u>7/10/23</u> | <u>13:47</u> | Seal intact as received Yes <input type="checkbox"/> No <input type="checkbox"/> |

1. All traps used for sampling must have passed routine inspections by the trap maker. Monthly calibration is a major cause of error.
 2. Traps should be stored in a cool, dry place and should never be exposed to direct sunlight. Refer to 525

ORTECH Consulting Inc. Sample Log
 Mercury Tube Sampler
 Incinerator Exhaust Stack

Job/Report Number: 22278
 Received By: David Wiley
 Job Assigned To: Ohio Lumen
 PO #: 22278-12910


| Tube ID | Spiked? | Sample Date | Sample Description | Approx. Sample Volume m ³ | Sample Analysis |
|----------|---------|---------------|--------------------|--------------------------------------|-----------------|
| OL618282 | Yes | June 27, 2023 | Test 1 Tube A | 0.06 | Hg |
| OL629572 | No | June 27, 2023 | Test 1 Tube B | 0.06 | Hg |
| OL629534 | No | June 27, 2023 | Test 2 Tube A | 0.06 | Hg |
| OL601382 | Yes | June 27, 2023 | Test 2 Tube B | 0.06 | Hg |
| OL669050 | Yes | June 27, 2023 | Test 3 Tube A | 0.06 | Hg |
| OL629553 | No | June 27, 2023 | Test 3 Tube B | 0.06 | Hg |
| OL661294 | No | June 27, 2023 | Test 4 Tube A | 0.06 | Hg |
| OL610647 | Yes | June 27, 2023 | Test 4 Tube B | 0.06 | Hg |
| OL620087 | Yes | June 28, 2023 | Test 5 Tube A | 0.06 | Hg |
| OL661394 | No | June 28, 2023 | Test 5 Tube B | 0.06 | Hg |
| OL663104 | No | June 28, 2023 | Test 6 Tube A | 0.06 | Hg |
| OL618297 | Yes | June 28, 2023 | Test 6 Tube B | 0.06 | Hg |

All tubes sampled at approximately 1 liter/minute for 60 minutes.
 Expected concentrations are approximately 300 - 400ng

Requisitioned To: _____ Date: _____
 Requisitioned By: David Wiley Date: June 29, 2023

This report has been reviewed and approved by:

Anthony Schneider
Directory of Laboratory Services and Analytical R&D

A handwritten signature in black ink, appearing to read "Anthony Schneider". The signature is fluid and cursive, with a long horizontal stroke at the end.

APPENDIX 5

**Clean Harbors Process Data
(12 pages)**

| Date | | Waste Flows | | | | Air Flows | | | | Temperatures | | | | Pressures | | | | Flows | | |
|------------|----------|-------------|--------|----------|----------|-----------|----------|-----------|----------------|--------------|-----------|-----------|--------|-----------|--------|--------------|-----------|----------|----------|-----------|
| Rich | Time | Emulsion | Lean | Alkaline | TDU flow | TDU flow | Leachate | Secondary | Stack Velocity | Stack Flow | Primary | Secondary | Quench | SDA | Stack | Incrinerator | SDA Inlet | BH Inlet | BH dp | PAC |
| FT-219 | FT-219C | FT-219C | FT-223 | PW-207 | FT-313B | FT-313B | PW-211 | PW-236 | FT-260-VEL | Rm2/3 | TE-240 | T-241A | T-241B | TE-203 | TE-204 | TE-242A | PT-249 | PT-615 | POT-622 | SC-PAC-FT |
| 2023-06-27 | 15:44:00 | 30.51 | 5.85 | 160.29 | 4.7325 | 284.025 | 24.525 | 15031.25 | 31.93144 | 70709.93 | 1136.1 | 1135.8 | 503.2 | 503.2 | 189.1 | 189.1 | 35.75 | -110.288 | 331.5625 | 23.24 |
| 2023-06-27 | 15:45:00 | 30.66 | 6.31 | 160.29 | 4.72625 | 283.575 | 24.525 | 15787.5 | 30.11579 | 66533.73 | 1133.8 | 1133.8 | 503.4 | 503.4 | 190.5 | 190.5 | -17.2 | -32.75 | 377.625 | 23.82 |
| 2023-06-27 | 15:46:00 | 30.645 | 5.8 | 160.4363 | 4.735 | 284.1 | 24.525 | 15443.75 | 30.91488 | 65500.63 | 1134.9 | 1134.9 | 503.4 | 503.4 | 189.1 | 189.1 | -14.45 | -26.75 | 387.5625 | 23.74 |
| 2023-06-27 | 15:47:00 | 30.765 | 5.85 | 160.9988 | 4.795 | 287.7 | 24.525 | 16112.5 | 30.17909 | 67145.99 | 1135.4 | 1136 | 503.4 | 503.4 | 189.1 | 189.1 | -20.6 | -36 | 399.625 | 23.98 |
| 2023-06-27 | 15:48:00 | 30.155 | 5.85 | 160.5663 | 4.7725 | 286.35 | 24.525 | 15750 | 30.17582 | 66730.26 | 1136.6 | 1136.6 | 503.4 | 503.4 | 191 | 191 | -13.7 | -28.75 | 379.875 | 24.08 |
| 2023-06-27 | 15:49:00 | 29.79 | 5.325 | 159.5812 | 4.87125 | 292.725 | 24.525 | 15633.5 | 30.24954 | 71096.71 | 1137.7 | 1138.3 | 503.1 | 503.1 | 189.1 | 189.1 | -22.4 | -47 | 407.025 | 24.1825 |
| 2023-06-27 | 15:50:00 | 29.888 | 5.705 | 159.48 | 4.745 | 284.7 | 24.525 | 15683.5 | 29.22799 | 64453.85 | 1135.3 | 1134.3 | 503.1 | 503.1 | 191 | 191 | -15.4 | -30.625 | 382.25 | 23.96 |
| 2023-06-27 | 15:51:00 | 29.745 | 5.56 | 160.29 | 4.74 | 284.4 | 24.525 | 15818.75 | 29.44582 | 65203.02 | 1135.1 | 1135.1 | 504 | 504 | 189.1 | 189.1 | -10.5 | -23.5 | 372.625 | 23.72 |
| 2023-06-27 | 15:52:00 | 29.925 | 5.52 | 160.5712 | 4.7775 | 287.65 | 24.525 | 16781.25 | 29.55808 | 66767.11 | 1137.81 | 1138.8 | 503.9 | 503.9 | 191.5 | 191.5 | -25.75 | -42.875 | 397.1875 | 23.76 |
| 2023-06-27 | 15:53:00 | 30.15 | 5.75 | 160.4363 | 4.85895 | 292.45 | 24.525 | 15863.5 | 30.22209 | 65532.23 | 1138.2 | 1138.2 | 504.6 | 504.6 | 192.5 | 189.1 | -16.4 | -33 | 483.4375 | 24.02 |
| 2023-06-27 | 15:54:00 | 30.66 | 5.99 | 161.4262 | 4.7525 | 287.5 | 24.525 | 15668.75 | 29.86229 | 65505.23 | 1139.4 | 1139.4 | 504.9 | 504.9 | 193 | 193 | -12.25 | -28.75 | 376.625 | 23.52 |
| 2023-06-27 | 15:55:00 | 30.675 | 6.16 | 159.925 | 4.70375 | 282.25 | 24.525 | 15633.5 | 29.60946 | 63598.15 | 1139.1 | 1139.1 | 504.8 | 504.8 | 190.2 | 190.2 | -12.15 | -26.375 | 383.0625 | 23.78 |
| 2023-06-27 | 15:56:00 | 31.215 | 6.16 | 160.1437 | 4.71975 | 282.825 | 24.525 | 15000 | 29.64479 | 65389.13 | 1139.4 | 1139.4 | 504.8 | 504.8 | 192.5 | 190.2 | -24.1 | -41.125 | 397.1325 | 24.04 |
| 2023-06-27 | 15:57:00 | 31.005 | 5.735 | 160.4363 | 4.71975 | 282.825 | 24.525 | 16000 | 29.64479 | 65389.13 | 1139.4 | 1139.4 | 504.8 | 504.8 | 192.5 | 190.2 | -15.05 | -30.25 | 423.575 | 23.06 |
| 2023-06-27 | 15:58:00 | 30.615 | 5.855 | 161.1 | 4.8075 | 283.725 | 24.525 | 15690 | 30.16168 | 65890.57 | 1139.4 | 1139.4 | 504.9 | 504.9 | 192.5 | 190.2 | -11.5 | -26.375 | 376.1625 | 23.9375 |
| 2023-06-27 | 15:59:00 | 30.615 | 5.915 | 160.6163 | 4.70375 | 282.25 | 24.525 | 15650 | 29.28063 | 64288.67 | 1139.7 | 1139.7 | 505.4 | 505.4 | 192.5 | 190.2 | -15.25 | -31.75 | 379.625 | 23.08 |
| 2023-06-27 | 16:00:00 | 31.02 | 5.58 | 161.3812 | 4.725 | 283.5 | 24.525 | 15781.25 | 30.03398 | 65223.21 | 1139.7 | 1139.7 | 505.4 | 505.4 | 192.5 | 190.2 | -15.25 | -31.75 | 379.625 | 23.08 |
| 2023-06-27 | 16:01:00 | 30.705 | 5.46 | 160.4812 | 4.69375 | 281.625 | 24.525 | 15400 | 29.23559 | 64000.54 | 1140.1 | 1140.1 | 504.2 | 504.2 | 191.5 | 190.2 | -9.4 | -23 | 473.3875 | 23.68 |
| 2023-06-27 | 16:02:00 | 30.945 | 5.8 | 160.38 | 4.71125 | 282.625 | 24.525 | 16106.25 | 30.97284 | 67447.16 | 1139.625 | 1138.6 | 505 | 505 | 192 | 190.2 | -31.75 | -46.125 | 376.875 | 23.74 |
| 2023-06-27 | 16:03:00 | 30.75 | 5.89 | 160.335 | 4.74 | 284.4 | 24.525 | 15875 | 30.08653 | 65788.86 | 1139.8 | 1138.6 | 505.2 | 505.2 | 192 | 190.2 | -13.8 | -28.75 | 400.625 | 23.06 |
| 2023-06-27 | 16:04:00 | 31.125 | 5.735 | 160.0087 | 4.695 | 281.7 | 24.525 | 15412.5 | 29.49747 | 64040.18 | 1138.6 | 1138.6 | 504.9 | 504.9 | 192 | 190.2 | -12.1 | -26.75 | 389.0625 | 23.18 |
| 2023-06-27 | 16:05:00 | 31.32 | 5.915 | 161.8088 | 4.67375 | 280.425 | 24.525 | 16075 | 30.71525 | 67327.7 | 1138.7 | 1138.7 | 505 | 505 | 192 | 190.2 | -18.35 | -35.125 | 407.075 | 23.98 |
| 2023-06-27 | 16:06:00 | 30.96 | 5.525 | 160.4363 | 4.6925 | 281.55 | 24.525 | 15600 | 29.71409 | 65010.16 | 1140.6 | 1140.6 | 504.8 | 504.8 | 192 | 190.2 | -10.85 | -24.5 | 376.125 | 23.14 |
| 2023-06-27 | 16:07:00 | 30.54 | 5.885 | 159.8625 | 4.6925 | 281.55 | 24.525 | 15981.25 | 31.75345 | 69486.97 | 1140.6 | 1140.6 | 504.8 | 504.8 | 192 | 190.2 | -34.15 | -55.375 | 384.5625 | 23.14 |
| 2023-06-27 | 16:08:00 | 30.705 | 5.795 | 160.5623 | 4.73875 | 283.925 | 24.525 | 15861.5 | 29.21774 | 63700.86 | 1140.4 | 1140.4 | 504.2 | 504.2 | 191.5 | 190.2 | -15.9 | -33.75 | 388.4375 | 23.96 |
| 2023-06-27 | 16:09:00 | 30.705 | 5.675 | 159.8625 | 4.6925 | 281.55 | 24.525 | 15683.5 | 30.97881 | 64579.94 | 1139.8 | 1140.5 | 504.2 | 504.2 | 191.5 | 190.2 | -11.95 | -25.625 | 376.4375 | 23.86 |
| 2023-06-27 | 16:10:00 | 30.645 | 5.775 | 160.245 | 4.3275 | 259.65 | 24.525 | 15943.75 | 30.14997 | 66338.97 | 1139.8 | 1140.4 | 504.2 | 504.2 | 191 | 190.2 | -18.7 | -34.25 | 385.125 | 23.22 |
| 2023-06-27 | 16:11:00 | 30.84 | 6.365 | 160.4363 | 4.899 | 4.32 | 25.2 | 24.525 | 29.30029 | 64416.57 | 1139.7 | 1139.4 | 505.6 | 505.6 | 191 | 190.2 | -10.4 | -20.25 | 372.375 | 23.92 |
| 2023-06-27 | 16:12:00 | 30.735 | 5.535 | 160.875 | 4.8295 | 257.7 | 24.525 | 15656.25 | 31.96647 | 72840.44 | 1140.5 | 1140.5 | 503.2 | 503.2 | 191 | 190.2 | -35.55 | -53.625 | 379.625 | 24.08 |
| 2023-06-27 | 16:13:00 | 30.945 | 6.165 | 160.875 | 4.8935 | 259.45 | 24.525 | 15937.5 | 30.13208 | 66266.34 | 1140.7031 | 1139.4 | 503.4 | 503.4 | 191 | 190.2 | -18.65 | -32.125 | 386.375 | 23.72 |
| 2023-06-27 | 16:14:00 | 30.885 | 5.955 | 160.38 | 4.82625 | 259.725 | 24.525 | 15725 | 31.02873 | 66999.93 | 1135.4 | 1135.4 | 502.6 | 502.6 | 191.5 | 190.2 | -13.3 | -30.375 | 378.1125 | 24.16 |
| 2023-06-27 | 16:15:00 | 31.095 | 5.97 | 160.29 | 4.8025 | 258.45 | 24.525 | 16275 | 30.56447 | 65094 | 1139.8 | 1140.5 | 502.9 | 502.9 | 191 | 190.2 | -22.25 | -38.875 | 392.925 | 23.56 |
| 2023-06-27 | 16:16:00 | 31.14 | 6.435 | 160.638 | 4.8875 | 258.725 | 24.525 | 15668.75 | 29.89042 | 65792.61 | 1138.4 | 1138.4 | 503 | 503 | 191.5 | 190.2 | -14.85 | -28.875 | 423.575 | 23.16 |
| 2023-06-27 | 16:17:00 | 30.87 | 5.395 | 159.2438 | 4.8963 | 258.375 | 24.525 | 15706.25 | 29.99837 | 63718.61 | 1138.4 | 1138.4 | 502.4 | 502.4 | 191 | 190.2 | -11.5 | -25.25 | 373.0625 | 23.94 |
| 2023-06-27 | 16:18:00 | 30.795 | 5.71 | 160.4363 | 4.80405 | 258.875 | 24.525 | 15818.75 | 30.48437 | 64693.06 | 1138.4 | 1137.4 | 502.6 | 502.6 | 191 | 190.2 | -17.5 | -36.875 | 385.3875 | 23.3 |
| 2023-06-27 | 16:19:00 | 30.93 | 6.215 | 159.925 | 4.8475 | 290.85 | 24.525 | 15618.75 | 29.10755 | 64226.26 | 1135.4 | 1135.4 | 502.6 | 502.6 | 191.5 | 190.2 | -16.15 | -31.625 | 399.75 | 23.3 |
| 2023-06-27 | 16:20:00 | 31.095 | 5.885 | 160.7175 | 4.8825 | 292.95 | 24.525 | 16050 | 30.28273 | 66999.93 | 1135.4 | 1137.7 | 503 | 503 | 191.5 | 190.2 | -10.05 | -22.875 | 372.7875 | 24.16 |
| 2023-06-27 | 16:21:00 | 30.765 | 6.36 | 160.335 | 4.7825 | 284.925 | 24.525 | 15562.5 | 28.46139 | 62271.91 | 1141.781 | 1141.6 | 503.1 | 503.1 | 191 | 190.2 | -7.25 | -23 | 471.025 | 22.94 |
| 2023-06-27 | 16:22:00 | 30.855 | 5.59 | 161.0437 | 4.7675 | 286.05 | 24.525 | 15956.25 | 29.35151 | 66275.04 | 1140.869 | 1140.2 | 503.2 | 503.2 | 191 | 190.2 | -18.3 | -34.625 | 377.5625 | 23.16 |
| 2023-06-27 | 16:23:00 | 31.02 | 6.265 | 160.5712 | 4.6825 | 280.95 | 24.525 | 15693.75 | 29.17219 | 63664.15 | 1138.881 | 1139.5 | 503.6 | 503.6 | 191.5 | 190.2 | -11.5 | -27.75 | 386.375 | 23.6 |
| 2023-06-27 | 16:24:00 | 30.6 | 5.8 | 160.5712 | 4.73 | 283.8 | 24.525 | 16162.5 | 30.48437 | 66895.96 | 1138.2 | 1138.2 | 503.7 | 503.7 | 191.5 | 190.2 | -27.1 | -43.375 | 403.575 | 23.6 |
| 2023-06-27 | 16:25:00 | 30.6 | 5.8 | 160.5712 | 4.73 | 283.8 | 24.525 | 16162.5 | 30.48437 | 66895.96 | 1138.2 | 1138.2 | 503.7 | 503.7 | 191.5 | 190.2 | -27.1 | -43.375 | 403.575 | 23.6 |
| 2023-06-27 | 16:26:00 | 30.66 | 6.35 | 160.5712 | 4.7025 | 282.9 | 24.525 | 15718.75 | 29.71621 | 65222.82 | 1135.4 | 1135.4 | 504 | 504 | 192 | 190.2 | -16.1 | -28.5 | 381.625 | 23.06 |
| 2023-06-27 | 16:27:00 | 30.66 | 5.75 | 160.7625 | 4.69875 | 284.925 | 24.525 | 15607.5 | 30.05536 | 64022.73 | 1134.025 | 1135.3 | 503.3 | 503.3 | 192 | 190.2 | -12.05 | -25.875 | 394.8125 | 23.06 |
| 2023-06-27 | 16:28:00 | 30.66 | 6.35 | 160.5712 | 4.71125 | 284.925 | 24.525 | 15683.5 | 30.17661 | 64022.73 | 1134.025 | 1134.4 | 503.3 | 503.3 | 192 | 190.2 | -19.6 | -36.125 | 387.5625 | 24.08 |
| 2023-06-27 | 16:29:00 | 30.975 | 6.11 | 161.5725 | | | | | | | | | | | | | | | | |

Main Analyzers and Backup Analyzers data table for June 27/2023. Columns include Date, Time, CO, HCl, CO2, H2O, THC, O2, Opacity, SO2, NO, NO2, HF, CO, THC, O2, SO2. Rows list various measurements over time.

Main Analyzers and Backup Analyzers summary table for June 27/2023. Columns include Test 1, Units, CO, HCl, CO2, H2O, THC, O2, Opacity, SO2, NO, NO2, HF, CO, THC, O2, SO2. Rows include units, max, min, average, and variance for each parameter.

June 27/2023

| Date | Time | Main Analyzers | | | | | Backup Analyzers | | | | | | | | | |
|------------|----------|----------------|-------------|-------------|-------------|------------|------------------|-----------|--------------|------------|------------|-----------|------------|------------|-------------|------------|
| | | CO PPM | HCl PPM | CO2 % | H2O % | THC PPM | SO2 PPM | HF PPM | NO2 PPM | NO PPM | NO PPM | CO PPM | THC PPM | SO2 PPM | | |
| | | AT-205-NEW | AT-213A-NEW | AT-213B-NEW | AT-213C-NEW | AT-259-NEW | AT-261A-NEW | AT-263 | Opacity % | SO2 PPM | AT-264-NEW | AT-NO2 | AT-HF | AT-205-NEW | AT-261A-NEW | AT-264-NEW |
| 2023-06-27 | 13:05:00 | 36.21 | 0.21 | 8.61 | 40.79 | 11.8 | 8.42 | 2.15 | 10 | 76.36 | 11.55 | -0.05 | 36.91 | 9.2 | 10.03 | 0.3 |
| 2023-06-27 | 13:06:00 | 36.48 | 0.21 | 8.44 | 40.56 | 14.3 | 8.7 | 2.92 | 5.8 | 77.7 | 8 | 2.34 | 32.59 | 12.2 | 9.82 | 0.3 |
| 2023-06-27 | 13:07:00 | 37.58 | 0.21 | 8.5 | 40.55 | 16.2 | 8.71 | 1.93 | 3 | 83.28 | 8 | 2.34 | 56.71 | 15.1 | 9.4 | 0.3 |
| 2023-06-27 | 13:08:00 | 44.62 | 0.21 | 8.67 | 41.07 | 22.1 | 8.7 | 2.28 | 3 | 87.48 | 11.84 | 2.34 | 64.65 | 19 | 9.19 | 0.3 |
| 2023-06-27 | 13:09:00 | 51.74 | 0.21 | 8.87 | 41.49 | 22 | 8.46 | 1.6 | 5.2 | 85.81 | 14.67 | 2.34 | 68.72 | 22.9 | 8.77 | 0.3 |
| 2023-06-27 | 13:10:00 | 51.6 | 0.21 | 8.9 | 41.47 | 14.8 | 8.23 | 2.12 | 6.4 | 71.11 | 10.98 | 0.03 | 40.35 | 11.5 | 9.53 | 0.3 |
| 2023-06-27 | 13:11:00 | 43.73 | 0.21 | 8.83 | 41.33 | 16.2 | 8.23 | 4.01 | 8.8 | 71.11 | 10.98 | 0.03 | 48.9 | 15 | 9.11 | 0.3 |
| 2023-06-27 | 13:12:00 | 41.07 | 0.21 | 8.79 | 41.32 | 11.3 | 8.23 | 1.78 | 8.8 | 83.48 | 8.4 | 0.03 | 45.15 | 14.4 | 9.96 | 0.3 |
| 2023-06-27 | 13:13:00 | 40.19 | 0.21 | 8.75 | 41.22 | 14.6 | 8.23 | 2.23 | 4.6 | 83.48 | 8.4 | 0.03 | 45.97 | 12.2 | 9.55 | 0.3 |
| 2023-06-27 | 13:14:00 | 40.05 | 0.21 | 8.72 | 41.16 | 16.5 | 8.45 | 1.65 | 3 | 83.48 | 10.84 | 0.03 | 53.7 | 15.5 | 9.35 | 0.3 |
| 2023-06-27 | 13:15:00 | 40.15 | 0.21 | 8.72 | 41.11 | 14 | 8.45 | 2.05 | 3 | 96.03 | 10.84 | 0.03 | 42.07 | 11 | 9.85 | 0.3 |
| 2023-06-27 | 13:16:00 | 40.15 | 0.21 | 8.7 | 41 | 15.6 | 8.45 | 2.2 | 3 | 101.12 | 10.84 | 0.03 | 50.33 | 15 | 9.44 | 0.3 |
| 2023-06-27 | 13:17:00 | 40.3 | 0.21 | 8.72 | 41.13 | 16.7 | 8.45 | 1.78 | 3 | 95.79 | 13.55 | 0.03 | 49.09 | 14.8 | 9.23 | 0.3 |
| 2023-06-27 | 13:18:00 | 40.45 | 0.21 | 8.84 | 41.44 | 17.4 | 8.45 | 2.17 | 3 | 76.99 | 11.17 | 0.03 | 54.34 | 16.1 | 9.23 | 0.3 |
| 2023-06-27 | 13:19:00 | 41.69 | 0.21 | 8.9 | 41.62 | 18.7 | 8.3 | 1.66 | 3 | 83.46 | 11.17 | 0.03 | 61.05 | 21.7 | 8.82 | 0.3 |
| 2023-06-27 | 13:20:00 | 43.13 | 0.21 | 8.84 | 41.36 | 12.2 | 8.23 | 1.96 | 3 | 103.87 | 5.62 | 0.03 | 40.38 | 10 | 9.9 | 0.3 |
| 2023-06-27 | 13:21:00 | 41.43 | 0.21 | 8.71 | 41.03 | 16.1 | 8.23 | 2.23 | 1.7 | 106.78 | 8.05 | 0.03 | 41.74 | 12.4 | 9.27 | 0.3 |
| 2023-06-27 | 13:22:00 | 40.06 | 0.21 | 8.75 | 41.16 | 11.3 | 8.44 | 1.85 | 1.7 | 104.71 | 8.05 | 0.22 | 43.25 | 15.3 | 9.66 | 0.3 |
| 2023-06-27 | 13:23:00 | 39.2 | 0.21 | 8.76 | 41.15 | 13.3 | 8.44 | 2.2 | 1.7 | 104.71 | 8.05 | 0.22 | 38.92 | 10.4 | 9.67 | 0.3 |
| 2023-06-27 | 13:24:00 | 33.82 | 0.21 | 8.71 | 41.12 | 16.6 | 8.44 | 2.11 | 1.7 | 101.94 | 6.31 | 0.22 | 38.63 | 12.5 | 9.27 | 0.3 |
| 2023-06-27 | 13:25:00 | 33.25 | 0.21 | 8.76 | 41.14 | 11.8 | 8.44 | 2.02 | 1.7 | 92.79 | 6.3 | 0.22 | 33.17 | 12.1 | 9.64 | 0.3 |
| 2023-06-27 | 13:26:00 | 32.51 | 0.21 | 8.71 | 41.07 | 17.1 | 8.44 | 2.28 | 3 | 97.11 | 6.3 | 0.22 | 36.71 | 12.1 | 9.44 | 0.3 |
| 2023-06-27 | 13:27:00 | 32.51 | 0.21 | 8.75 | 41.19 | 14.8 | 8.44 | 1.71 | 3 | 97.11 | 6.3 | 0.22 | 37.82 | 13.8 | 9.01 | 0.3 |
| 2023-06-27 | 13:28:00 | 32.61 | 0.21 | 8.82 | 41.35 | 15.7 | 8.44 | 2.23 | 5.5 | 102.41 | 11.44 | 0.54 | 37.08 | 11.7 | 9.41 | 0.3 |
| 2023-06-27 | 13:29:00 | 32.61 | 0.21 | 8.84 | 41.38 | 17.3 | 8.44 | 2.35 | 5.5 | 97.52 | 11.44 | 0.54 | 47.06 | 16.2 | 8.98 | 0.3 |
| 2023-06-27 | 13:30:00 | 33.37 | 0.21 | 8.89 | 41.44 | 13.7 | 8.44 | 1.81 | 5.5 | 97.52 | 11.44 | 0.54 | 37.98 | 13.5 | 9.74 | 0.3 |
| 2023-06-27 | 13:31:00 | 33.66 | 0.21 | 8.83 | 41.22 | 13.6 | 8.44 | 1.81 | 5.5 | 97.52 | 11.44 | 0.54 | 37.98 | 13.5 | 9.74 | 0.3 |
| 2023-06-27 | 13:32:00 | 33.24 | 0.21 | 8.76 | 41.15 | 13.3 | 8.44 | 2.27 | 3 | 100.53 | 8.1 | 0.54 | 35.5 | 12.9 | 9.32 | 0.3 |
| 2023-06-27 | 13:33:00 | 31.8 | 0.21 | 8.74 | 41.08 | 12.1 | 8.44 | 2 | 3 | 94.98 | 6.14 | 0.54 | 34.12 | 11.8 | 9.1 | 0.3 |
| 2023-06-27 | 13:34:00 | 31.46 | 0.21 | 8.73 | 41.07 | 16.4 | 8.44 | 2.11 | 1.7 | 86.19 | 6.11 | 0.06 | 30.71 | 10.1 | 9.79 | 0.3 |
| 2023-06-27 | 13:35:00 | 31.52 | 0.21 | 8.8 | 41.29 | 14.4 | 8.44 | 1.82 | 1.7 | 86.19 | 6.11 | -0.06 | 44.14 | 15 | 9.16 | 0.3 |
| 2023-06-27 | 13:36:00 | 34.46 | 0.21 | 8.8 | 41.25 | 15.6 | 8.44 | 1.47 | 1.7 | 100.93 | 11.73 | -0.06 | 44.94 | 13.3 | 9.4 | 0.3 |
| 2023-06-27 | 13:37:00 | 34.71 | 0.21 | 8.77 | 41.24 | 15.3 | 8.44 | 1.47 | 1.7 | 102.03 | 7.5 | -0.06 | 40.97 | 13.6 | 8.98 | 0.3 |
| 2023-06-27 | 13:38:00 | 33.74 | 0.21 | 8.83 | 41.32 | 10.3 | 8.44 | 2.11 | 1.7 | 84.11 | 4.55 | -0.06 | 28.53 | 9.5 | 9.62 | 0.3 |
| 2023-06-27 | 13:39:00 | 32.85 | 0.21 | 8.86 | 41.44 | 17.6 | 8.44 | 2.18 | 1.7 | 71.62 | 3.5 | -0.06 | 49.45 | 14.4 | 8.98 | 0.3 |
| 2023-06-27 | 13:40:00 | 33.58 | 0.21 | 8.9 | 41.65 | 14 | 8.44 | 1.67 | 0.6 | 82.92 | 8.76 | -0.06 | 47.11 | 15.6 | 9.76 | 0.3 |
| 2023-06-27 | 13:41:00 | 35.87 | 0.21 | 8.87 | 41.53 | 12 | 8.22 | 2.03 | 0.6 | 98.33 | 8.76 | -0.06 | 34.13 | 10.9 | 9.35 | 0.3 |
| 2023-06-27 | 13:42:00 | 35.75 | 0.21 | 8.78 | 41.37 | 15.2 | 8.22 | 1.66 | 0.6 | 95.39 | 8.76 | -0.06 | 47.67 | 15 | 9.15 | 0.3 |
| 2023-06-27 | 13:43:00 | 35.17 | 0.21 | 8.79 | 41.38 | 12 | 8.22 | 1.92 | 0.6 | 95.39 | 7.44 | -0.06 | 35.69 | 10.3 | 9.79 | 0.3 |
| 2023-06-27 | 13:44:00 | 34.72 | 0.21 | 8.73 | 41.12 | 14.2 | 8.22 | 2.12 | 0.6 | 102.78 | 5.62 | -0.06 | 40.2 | 12.6 | 9.37 | 0.3 |
| 2023-06-27 | 13:45:00 | 34.47 | 0.21 | 8.72 | 41.16 | 13.4 | 8.43 | 1.67 | 0.6 | 87.42 | 5.62 | -0.06 | 33.74 | 12.7 | 9.69 | 0.3 |
| 2023-06-27 | 13:46:00 | 32.7 | 0.21 | 8.74 | 41.13 | 12.2 | 8.43 | 2.08 | 0.6 | 86.23 | 6.65 | -0.06 | 34.28 | 10.6 | 9.68 | 0.3 |
| 2023-06-27 | 13:47:00 | 31.97 | 0.21 | 8.69 | 41.04 | 15.1 | 8.43 | 1.7 | 4.1 | 88.08 | 9.55 | 1.4 | 37.82 | 13.2 | 9.27 | 0.3 |
| 2023-06-27 | 13:48:00 | 31.97 | 0.21 | 8.75 | 41.25 | 14.3 | 8.43 | 2.01 | 4.1 | 97.13 | 9.55 | 1.4 | 37.82 | 10.7 | 9.21 | 0.3 |
| 2023-06-27 | 13:49:00 | 32.35 | 0.21 | 8.81 | 41.4 | 21.3 | 8.43 | 2.25 | 4.1 | 98.87 | 10.59 | 1.4 | 60.3 | 19.1 | 9.11 | 0.3 |
| 2023-06-27 | 13:50:00 | 37.06 | 0.21 | 8.93 | 41.6 | 20 | 8.43 | 1.55 | 10.7 | 88.42 | 13.94 | 1.4 | 50.78 | 17.7 | 8.94 | 0.3 |
| 2023-06-27 | 13:51:00 | 39.11 | 0.21 | 8.93 | 41.53 | 13.8 | 8.2 | 2.12 | 10.7 | 90.53 | 12.57 | 0.37 | 41.18 | 14.2 | 9.47 | 0.3 |
| 2023-06-27 | 13:52:00 | 38.08 | 0.21 | 8.85 | 41.24 | 16.6 | 8.2 | 2 | 9.2 | 90.53 | 12.57 | 0.37 | 44.18 | 14.2 | 9.27 | 0.3 |
| 2023-06-27 | 13:53:00 | 35.95 | 0.21 | 8.81 | 41.16 | 11.7 | 8.2 | 1.93 | 9.2 | 93.92 | 14.52 | 0.37 | 34.28 | 12.1 | 9.69 | 0.3 |
| 2023-06-27 | 13:54:00 | 34.13 | 0.21 | 8.77 | 41.1 | 15.3 | 8.41 | 2.16 | 5.6 | 93.92 | 14.52 | 0.37 | 38.36 | 11.8 | 9.26 | 0.3 |
| 2023-06-27 | 13:55:00 | 35.99 | 0.21 | 9.64 | 46.2 | 15.4 | 9.21 | 1.6 | 1.9 | 102.47 | 9.49 | 0 | 45.81 | 16.5 | 9.05 | 0.3 |
| 2023-06-27 | 13:56:00 | 35.64 | 0.21 | 9.64 | 46.19 | 14.3 | 9.21 | 1.96 | 1.9 | 100.86 | 6.48 | 0 | 35.22 | 10.3 | 9.6 | 0.3 |
| 2023-06-27 | 13:57:00 | 35.64 | 0.21 | 7.85 | 46 | 15.7 | 9.21 | 1.77 | 0.8 | 99.86 | 8.34 | 0 | 44.75 | 14.8 | 9.19 | 0.3 |
| 2023-06-27 | 13:58:00 | 35.88 | 0.21 | 8.78 | 46.28 | 11.6 | 9.21 | 1.75 | 0.8 | 102.22 | 9.62 | 0 | 34.26 | 12.9 | 9.19 | 0.3 |
| 2023-06-27 | 13:59:00 | 37.5 | 0.21 | 8.84 | 46.44 | 15 | 9.21 | 2.11 | 3.1 | 102.22 | 12.57 | 0 | 37.14 | 12.9 | 9.21 | 0.3 |
| 2023-06-27 | 14:00:00 | 38.35 | 0.21 | 8.91 | 46.58 | 15.6 | 9.01 | 1.47 | 4.4 | 93.31 | 12.57 | 0 | 51.63 | 16.2 | 9.4 | 0.3 |
| 2023-06-27 | 14:01:00 | 39.63 | 0.21 | 8.87 | 46.44 | 11.6 | 9.01 | 1.97 | 5.6 | 105.6 | 11.49 | 0 | 30.47 | 9.8 | 9.48 | 0.3 |
| 2023-06-27 | 14:02:00 | 39.52 | 0.21 | 8.76 | 46.2 | 13.4 | 9.01 | 3.63 | 5.6 | 110.83 | 11.49 | 0 | 43.35 | 14.8 | 9.27 | 0.3 |
| 2023-06-27 | 14:03:00 | 39.52 | 0.21 | 8.76 | 46.15 | 11.9 | 9.01 | 1.77 | 5.6 | 126.45 | 12.83 | 0 | 42.34 | 14.1 | 9.88 | 0.3 |
| 2023-06-27 | 14:04:00 | 39.42 | 0.21 | 8.72 | 46 | 15.3 | 9.01 | 2.05 | 4.5 | 135.44 | 8.8 | 0 | 39.71 | 11.6 | 9.46 | 0.3 |
| 2023-06-27 | 14:05:00 | 43.13 | 0.21 | 9.54 | 50.6 | 17.2 | 10.07 | 1.58 | 3.1 | 137.93 | 5.46 | 0 | 51.12 | 16.4 | 9.02 | 0.3 |

June 27/2023

| Test 1 | Main Analyzers | | | | | Backup Analyzers | | | | | | | | | |
|----------|----------------|-------------|-------------|-------------|-------------|------------------|-------------|--------------|-------------|-------------|-------------|-------------|-------------|-------------|------------|
| | CO PPM | HCl PPM | CO2 % | H2O % | THC PPM | SO2 PPM | HF PPM | NO2 PPM | NO PPM | CO PPM | THC PPM | SO2 PPM | | | |
| Units | AT-205-NEW | AT-213A-NEW | AT-213B-NEW | AT-213C-NEW | AT-259-NEW | AT-261A-NEW | AT-263 | Opacity % | SO2 PPM | AT-264-NEW | AT-NO2 | AT-HF | AT-205-NEW | AT-261A-NEW | AT-264-NEW |
| Max | 51.7 | 0.2 | 9.6 | 50.6 | 22.1 | 10.1 | 4.0 | 10.7 | 135.4 | 14.7 | 2.3 | 68.7 | 22.9 | 10.0 | 0.3 |
| Average | 37.1 | 0.2 | 8.8 | 42.2 | 15.0 | 8.54 | 2.1 | 7.55 | 101.929 | 7.55 | 0.12 | 75.3285991 | 15.3 | 8.8 | 0.3 |
| Variance | 19.7676503 | 0.063078667 | 4.757379016 | 7.255010929 | 0.124139399 | 0.18713623 | 7.214680743 | 151.3865306 | 7.492359891 | 0.448464317 | 75.33285593 | 7.861344282 | 0.094584918 | 1.53509531 | |

| Main Analyzers | | | Backup Analyzers | | | | | | | | | | | | | |
|----------------|----------|------------|------------------|-------------|---------|------------|-------------|---------|------------|--------|--------|-------|------------|------------|-------------|------------|
| SDate | Time | CO | HCl | CO2 | H2O | THC | OZ | Opacity | SO2 | NO | NO2 | HF | THC | OZ | SO2 | |
| | | AT-205-NEW | AT-213A-NEW | AT-213B-NEW | AT-213C | AT-259-NEW | AT-261A-NEW | AT-263 | AT-264-NEW | AT-NO | AT-NO2 | AT-HF | AT-205-NEW | AT-259-NEW | AT-261A-NEW | AT-264-NEW |
| 2023-06-27 | 14:23:00 | 58.43 | 0.21 | 8.72 | 47.66 | 14.3 | 9.19 | 1.73 | 2.8 | 171.35 | 7.03 | -3.84 | 3.47 | 3.9 | 20.69 | 0.3 |
| 2023-06-27 | 14:24:00 | 50.98 | 0.21 | 8.65 | 47.32 | 13.8 | 9.19 | 2.05 | 4 | 172.49 | 9.73 | -3.84 | 37.88 | 10.1 | 9.68 | 0.3 |
| 2023-06-27 | 14:25:00 | 49.84 | 0.21 | 8.65 | 47.35 | 15.5 | 9.19 | 4.58 | 4 | 147.62 | 12.41 | 8.08 | 37.54 | 12.2 | 9.27 | 0.3 |
| 2023-06-27 | 14:26:00 | 50.16 | 0.21 | 8.68 | 47.93 | 13.8 | 9.47 | 1.93 | 4 | 145.64 | 12.41 | -0.07 | 38.57 | 13.2 | 9.82 | 0.3 |
| 2023-06-27 | 14:27:00 | 50.03 | 0.21 | 8.61 | 47.74 | 13.4 | 9.47 | 2.16 | 7.4 | 133.49 | 12.88 | -0.07 | 38.36 | 11.4 | 9.61 | 0.3 |
| 2023-06-27 | 14:28:00 | 50.02 | 0.21 | 8.6 | 47.77 | 15.5 | 9.47 | 1.55 | 9.3 | 133.49 | 12.88 | -0.07 | 40.2 | 13.2 | 9.19 | 0.3 |
| 2023-06-27 | 14:29:00 | 50.02 | 0.21 | 8.67 | 48.02 | 18.1 | 9.47 | 2 | 9.3 | 133.49 | 14.32 | -0.07 | 37.86 | 11.2 | 9.6 | 0.3 |
| 2023-06-27 | 14:30:00 | 50.2 | 0.21 | 8.78 | 48.3 | 20.5 | 9.47 | 2.35 | 2.3 | 123.73 | 11.8 | -0.07 | 41.15 | 15 | 8.98 | 0.3 |
| 2023-06-27 | 14:31:00 | 51 | 0.21 | 8.86 | 48.43 | 10.7 | 9.26 | 1.73 | 2.3 | 107.94 | 10.14 | -0.07 | 39.6 | 14.8 | 9.52 | 0.3 |
| 2023-06-27 | 14:32:00 | 50.35 | 0.21 | 8.73 | 48.06 | 14.1 | 9.26 | 2.18 | 2.3 | 106.25 | 11.27 | -0.07 | 37.98 | 11.2 | 9.52 | 0.3 |
| 2023-06-27 | 14:33:00 | 47.2 | 0.21 | 8.66 | 47.88 | 13.6 | 9.26 | 1.75 | 2.3 | 130.62 | 11.27 | -0.07 | 40.32 | 12.5 | 9.32 | 0.3 |
| 2023-06-27 | 14:34:00 | 46.36 | 0.21 | 8.62 | 47.75 | 12.2 | 9.26 | 2 | 6.4 | 144.81 | 11.27 | -0.07 | 37.59 | 9.9 | 9.9 | 0.3 |
| 2023-06-27 | 14:35:00 | 43.87 | 0.21 | 8.6 | 47.64 | 15.2 | 9.47 | 2.21 | 7.6 | 129.46 | 11.27 | -0.07 | 41.71 | 12.4 | 9.27 | 0.3 |
| 2023-06-27 | 14:36:00 | 42.76 | 0.21 | 8.67 | 47.8 | 11.1 | 9.47 | 1.71 | 7.6 | 110.9 | 12.49 | 0.17 | 44.3 | 13.8 | 9.76 | 0.3 |
| 2023-06-27 | 14:37:00 | 45.03 | 0.21 | 8.67 | 47.77 | 18.1 | 9.47 | 2.05 | 2.4 | 119.89 | 12.49 | 0.17 | 45.4 | 12.1 | 9.56 | 0.3 |
| 2023-06-27 | 14:38:00 | 48.42 | 0.21 | 8.68 | 47.85 | 17.1 | 9.47 | 1.73 | 2.4 | 117.58 | 12.49 | 0.17 | 42.41 | 14.8 | 9.15 | 0.3 |
| 2023-06-27 | 14:39:00 | 51.01 | 0.21 | 8.71 | 48.05 | 13.1 | 9.47 | 1.75 | 1.4 | 123.44 | 12.49 | 0.17 | 35.12 | 11.7 | 9.6 | 0.3 |
| 2023-06-27 | 14:40:00 | 51.01 | 0.21 | 8.79 | 48.13 | 18.9 | 9.27 | 2.17 | 1.4 | 129.34 | 11.11 | 0.17 | 45.44 | 13.9 | 9.19 | 0.3 |
| 2023-06-27 | 14:41:00 | 51.17 | 0.21 | 8.84 | 48.23 | 16.3 | 9.27 | 1.66 | 1.4 | 134.76 | 8.88 | 0.17 | 49.24 | 16.4 | 9.27 | 0.3 |
| 2023-06-27 | 14:42:00 | 51.71 | 0.21 | 8.76 | 48.09 | 12.8 | 9.27 | 2.1 | 1.4 | 121.7 | 11.63 | 0.17 | 40 | 10.4 | 9.59 | 0.3 |
| 2023-06-27 | 14:43:00 | 50.31 | 0.21 | 8.68 | 47.93 | 15.2 | 9.27 | 1.97 | 6.3 | 122.72 | 14.1 | 0.17 | 39.95 | 12.5 | 9.19 | 0.3 |
| 2023-06-27 | 14:44:00 | 48.55 | 0.21 | 8.71 | 47.92 | 11.7 | 9.27 | 1.86 | 6.3 | 111.36 | 14.1 | 0.17 | 38.93 | 11.8 | 9.77 | 0.3 |
| 2023-06-27 | 14:45:00 | 48.25 | 0.21 | 8.67 | 47.77 | 13.9 | 9.27 | 2.2 | 4.6 | 124.98 | 12.23 | 0.17 | 38.99 | 12.3 | 9.35 | 0.3 |
| 2023-06-27 | 14:46:00 | 48.42 | 0.21 | 8.68 | 47.79 | 16.3 | 9.27 | 1.82 | 2.8 | 125.22 | 9.08 | 1.42 | 52.14 | 17.1 | 9.15 | 0.3 |
| 2023-06-27 | 14:47:00 | 48.67 | 0.21 | 8.69 | 47.93 | 13.8 | 9.48 | 2.15 | 1.8 | 113.37 | 10.21 | 0.36 | 42.26 | 11.5 | 9.67 | 0.3 |
| 2023-06-27 | 14:48:00 | 48.67 | 0.21 | 8.64 | 47.81 | 17.4 | 9.48 | 3.05 | 1.6 | 114.61 | 7.51 | 0.36 | 45.79 | 14.1 | 9.26 | 0.3 |
| 2023-06-27 | 14:49:00 | 48.9 | 0.21 | 8.72 | 48.05 | 12.2 | 9.48 | 1.92 | 1.8 | 125.14 | 10.04 | 0.36 | 36.61 | 13.3 | 9.28 | 0.3 |
| 2023-06-27 | 14:50:00 | 49.15 | 0.21 | 8.79 | 48.21 | 17.4 | 9.48 | 2.21 | 1.6 | 125.14 | 10.04 | 0.36 | 46.64 | 14.7 | 9.11 | 0.3 |
| 2023-06-27 | 14:51:00 | 50.09 | 0.21 | 8.85 | 48.39 | 18.9 | 9.25 | 1.56 | 1.6 | 140.78 | 10.81 | 0.36 | 46.23 | 15.9 | 8.9 | 0.3 |
| 2023-06-27 | 14:52:00 | 51.49 | 0.21 | 8.83 | 48.3 | 12.5 | 9.25 | 2.07 | 0.6 | 139.15 | 9.57 | 0.36 | 37.29 | 11.3 | 9.7 | 0.3 |
| 2023-06-27 | 14:53:00 | 50.51 | 0.21 | 8.74 | 48.04 | 16.3 | 9.25 | 2.28 | 0.6 | 135.9 | 11.85 | 0.36 | 41.78 | 13.6 | 9.07 | 0.3 |
| 2023-06-27 | 14:54:00 | 48.16 | 0.21 | 8.75 | 48.07 | 13.1 | 9.25 | 1.82 | 0.6 | 117.28 | 8.24 | 0.36 | 39.29 | 13.2 | 10.02 | 0.3 |
| 2023-06-27 | 14:55:00 | 48.75 | 0.21 | 8.73 | 47.99 | 15.9 | 9.25 | 2.12 | 2.6 | 111.28 | 9.92 | 0.36 | 43.68 | 12.2 | 9.55 | 0.3 |
| 2023-06-27 | 14:56:00 | 48.75 | 0.21 | 8.67 | 47.91 | 18.3 | 9.25 | 1.63 | 2.6 | 119.02 | 9.92 | 0.36 | 48.93 | 16.4 | 9.15 | 0.3 |
| 2023-06-27 | 14:57:00 | 52.21 | 0.21 | 8.75 | 47.95 | 11.9 | 9.46 | 1.93 | 4.6 | 124.24 | 9.46 | 0.36 | 39.79 | 11.8 | 9.81 | 0.3 |
| 2023-06-27 | 14:58:00 | 53.82 | 0.21 | 8.68 | 47.72 | 15.4 | 9.46 | 2.18 | 3.2 | 120.62 | 6.67 | 0.36 | 48.23 | 13.8 | 9.4 | 0.3 |
| 2023-06-27 | 14:59:00 | 55.44 | 0.21 | 8.67 | 47.84 | 16 | 9.46 | 1.71 | 2.2 | 120.62 | 6.67 | 0.36 | 57.51 | 16.7 | 9.36 | 0.3 |
| 2023-06-27 | 15:00:00 | 57.62 | 0.21 | 8.7 | 48.02 | 18.5 | 9.46 | 2.07 | 1.1 | 122.73 | 9.31 | 0.36 | 56.37 | 15.1 | 9.36 | 0.3 |
| 2023-06-27 | 15:01:00 | 59.73 | 0.21 | 8.78 | 48.24 | 20.7 | 9.46 | 1.6 | 1.1 | 125.9 | 13.91 | 0.36 | 57.62 | 16.8 | 8.94 | 0.3 |
| 2023-06-27 | 15:02:00 | 62.66 | 0.21 | 8.85 | 48.31 | 13.7 | 9.46 | 2 | 5.2 | 125.94 | 13.91 | 0.36 | 51.18 | 13.2 | 9.74 | 0.3 |
| 2023-06-27 | 15:03:00 | 63.8 | 0.21 | 8.75 | 48.02 | 14.1 | 9.24 | 2.12 | 5.2 | 126.94 | 13.91 | 0.36 | 46.09 | 13.5 | 9.32 | 0.3 |
| 2023-06-27 | 15:04:00 | 63.8 | 0.21 | 8.71 | 47.96 | 16.3 | 9.24 | 1.77 | 2.4 | 133.8 | 13.52 | 0.36 | 57.31 | 16.8 | 9.54 | 0.3 |
| 2023-06-27 | 15:05:00 | 56.53 | 0.21 | 8.66 | 47.81 | 13.3 | 9.24 | 2.07 | 2.4 | 126.36 | 13.59 | 0.36 | 36.4 | 10.1 | 9.64 | 0.3 |
| 2023-06-27 | 15:06:00 | 55.95 | 0.21 | 8.64 | 47.72 | 19.2 | 9.44 | 2.01 | 2.4 | 128.4 | 13.59 | 0.36 | 59.21 | 17.7 | 9.23 | 0.3 |
| 2023-06-27 | 15:07:00 | 56.06 | 0.21 | 8.7 | 47.9 | 13.1 | 9.44 | 1.88 | 13.2 | 127.6 | 16.43 | 0.36 | 44.65 | 13.3 | 9.75 | 0.3 |
| 2023-06-27 | 15:08:00 | 56.77 | 0.21 | 8.66 | 47.75 | 18.1 | 9.44 | 2.2 | 13.2 | 126.31 | 11.97 | 0.36 | 52.8 | 13.8 | 9.54 | 0.3 |
| 2023-06-27 | 15:09:00 | 57 | 0.21 | 8.68 | 47.84 | 16.7 | 9.44 | 1.62 | 11.9 | 136.7 | 5.05 | 0.36 | 46.32 | 14.4 | 9.12 | 0.3 |
| 2023-06-27 | 15:10:00 | 57.15 | 0.21 | 8.73 | 47.93 | 16.7 | 9.44 | 2.07 | 10 | 127 | 5.05 | 0.36 | 44.65 | 12.4 | 9.56 | 0.3 |
| 2023-06-27 | 15:11:00 | 57.15 | 0.21 | 8.78 | 48.1 | 21.5 | 9.44 | 2.66 | 10 | 111.68 | 10.54 | 0.36 | 67.92 | 19.7 | 9.14 | 0.3 |
| 2023-06-27 | 15:12:00 | 59.43 | 0.21 | 8.82 | 48.21 | 12.4 | 9.44 | 1.86 | 5.8 | 127.15 | 7.15 | 0.36 | 47.16 | 16.5 | 9.61 | 0.3 |
| 2023-06-27 | 15:13:00 | 58.78 | 0.21 | 8.74 | 47.99 | 15.7 | 9.23 | 2.11 | 2.1 | 136.67 | 7.15 | 0.36 | 46.99 | 12.9 | 9.4 | 0.3 |
| 2023-06-27 | 15:14:00 | 50.53 | 0.21 | 8.73 | 47.96 | 15.3 | 9.23 | 1.6 | 2.1 | 145.95 | 9.7 | 0.36 | 45.33 | 13.9 | 9.18 | 0.3 |
| 2023-06-27 | 15:15:00 | 49.68 | 0.21 | 8.7 | 47.88 | 14.8 | 9.23 | 2.01 | 7.2 | 138.47 | 15.03 | 0.36 | 40.38 | 10.8 | 9.78 | 0.3 |
| 2023-06-27 | 15:16:00 | 51.3 | 0.21 | 8.66 | 47.73 | 18.7 | 9.43 | 4.45 | 9.8 | 137.38 | 15.03 | 0.36 | 60.87 | 16.8 | 9.36 | 0.3 |
| 2023-06-27 | 15:17:00 | 55.8 | 0.21 | 8.71 | 47.82 | 14.9 | 9.43 | 1.77 | 7.3 | 122.05 | 13.96 | 0.36 | 49.11 | 15.3 | 9.79 | 0.3 |
| 2023-06-27 | 15:18:00 | 56.18 | 0.21 | 8.67 | 47.75 | 17.2 | 9.43 | 2.08 | 1.6 | 114.77 | 11.5 | 0.36 | 55.94 | 14.8 | 9.56 | 0.3 |
| 2023-06-27 | 15:19:00 | 56.18 | 0.21 | 8.67 | 47.85 | 17 | 9.43 | 1.45 | 1.6 | 116.77 | 8 | 0.36 | 47.91 | 14.8 | 9.36 | 0.3 |
| 2023-06-27 | 15:20:00 | 56.35 | 0.21 | 8.74 | 48.05 | 13.9 | 9.43 | 1.96 | 1.6 | 128.78 | 10.76 | 0.36 | 40.68 | 11.5 | 9.77 | 0.3 |
| 2023-06-27 | 15:21:00 | 55.72 | 0.21 | 8.8 | 48.27 | 24.6 | 9.43 | 2.11 | 1.6 | 134.15 | 10.76 | 0.36 | 61.94 | 18.3 | 8.94 | 0.3 |
| 2023-06-27 | 15:22:00 | 63.08 | 0.21 | 8.91 | 48.52 | 16.6 | 9.43 | 1.62 | 3.5 | 106.37 | 15.31 | 0.36 | 73.74 | 20.8 | 9.61 | 0.3 |
| 2023-06-27 | 15:23:00 | 64.22 | 0.21 | 8.86 | 48.32 | 15.8 | 9.19 | 2.05 | 3.5 | 113.82 | 10.2 | 0.36 | 44.96 | 12.4 | 9.4 | 0.3 |

| Main Analyzers | | Backup Analyzers | | | | | | | | | | | |
|----------------|-------------|------------------|----------|-------------|-------------|-------------|------------|-------------|----------|----------|------------|-------------|-------------|
| CO | HCl | CO2 | H2O | THC | OZ | Opacity | SO2 | NO | NO2 | HF | THC | OZ | SO2 |
| AT-205-NEW | AT-213A-NEW | AT-213B-NEW | AT-213C | AT-259-NEW | AT-261A-NEW | AT-263 | AT-264-NEW | AT-NO | AT-NO2 | AT-HF | AT-205-NEW | AT-259-NEW | AT-261A-NEW |
| Units | 64.2 | 0.2 | 8.9 | 48.5 | 24.6 | 9.5 | 4.6 | 13.2 | 17.2 | 16.4 | 73.7 | 20.8 | 20.7 |
| Min | 42.8 | 0.2 | 8.6 | 47.3 | 15.6 | 9.2 | 1.5 | 10.6 | 10.6 | 3.1 | 3.8 | 3.9 | 8.9 |
| Max | 52.8 | 0.2 | 8.7 | 48.0 | 15.6 | 9.36 | 2.0 | 4.7 | 12.5 | 11.1 | 0.3 | 45.0 | 13.6 |
| Average | 25.71352459 | 9.47686E-32 | 0.006508 | 0.057343443 | 7.454551913 | 0.011605027 | 0.282901 | 10.78001093 | 166.8713 | 8.536884 | 1.627612 | 97.81985607 | 2.147114863 |
| Variance | 25.71352459 | 9.47686E-32 | 0.006508 | 0.057343443 | 7.454551913 | 0.011605027 | 0.282901 | 10.78001093 | 166.8713 | 8.536884 | 1.627612 | 97.81985607 | 2.147114863 |

June 27/2023

June 28/2023

Main Analyzers table with columns: SDate, STime, CO, HCl, CO2, H2O, THC, SO2, Opacity, SO2, NO, NO2, HF, CO, THC, O2, SO2. Rows include data for various analyzers from 2023-06-28 10:42:00 to 2023-06-28 11:42:00.

Backup Analyzers

Backup Analyzers summary table with columns: CO, HCl, CO2, H2O, THC, SO2, Opacity, SO2, NO, NO2, HF, CO, THC, O2, SO2. Includes units, max, min, average, and variance values.

June 28/2023